LLCHD HS000653

AUG 13 2012

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS000653

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 7400 W Bluff Rd (no rural route) City Malcolm, NE Zip 68402

Legal Description SE 14 11 5 29

1/4 1/4 Section Township Range Subdivison Addition Block Lot

Geographical Location (if known): Lat/Long: PID 05-14-400-008-000

B. Owner

Name Andrew J. Semerad Signature Andrew J. Semerad

Address PO Box 73 City/State/Zip Malcolm, NE 68402

Home Phone (402) 499-7388 Work Phone (402) 499-7388

C. Certified Installer

Name: Lloyd Jakoubek, Raymond Contracting Signature Lloyd Jakoubek

Address 13800 NW 70th St City/State/Zip Raymond, NE 68428

Work Phone 402-783-2103 or 402-890-6009

D. Engineer

☐ Check and complete if engineer designed system P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☐ Residential Dwelling Number of Bedrooms 4 Is there a Whirlpool Bathtub? ☐ Yes ☐ No Total Acres 20.10

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic Well Permit Applied for ☐ Yes ☐ No ☐ Not Applicable

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits
Date rec'd 8/14/12
Date frwd 8/14/12
ACTION ☐ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments
Date rec'd 8/14/12
Date frwd 8/14/12
ACTION ☒ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments
Date rec'd 8-14-12
Date frwd 8-14-12
ACTION ☒ Approved ☐ Disapproved
Signature Jim Blough

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 8-14-12 Amount Paid 345-
Received By BD Cash/Check No. 7942

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 5/10

8-15-2012 8:31:48

C


Lincoln-Lancaster County Health Department
Environmental Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

Permit Number:

Sewage Disposal System

Preliminary Plan Specifications

Draw a plot plan showing system location, lines, distribution box, tank and laterals, percolation test hole locations, well, residence, compass direction and property lines. Indicate on drawing if residence and well are existing or proposed.



Approximate Scale: _____ ft. = _____ grid line/s

A. System Location (Indicate correct number and street)

Address (no rural route) 7400 W Bluff Rd City Malcolm NE, Zip 68402

B. Proposed Septic Tank/s

Tank Material: ☐ Concrete ☐ Plastic ☐ Other _____

C. Proposed Absorption System (See Form B for Percolation Information)

Percolation Rate _____ (min. per inch) Soil Type: _____ Land Slope: _____ %

Type of Absorption System: ☐ Trench ☐ Bed ☐ Other _____

Total Square Feet of Field Required: _____ sq. ft.

Type of Lateral: ☐ Half-Moon ☐ Perforated Pipe ☐ Other Lateral Material: _____

Capacity of Septic Tank _____ gals Number of Absorption Beds: _____ Number of Distribution Laterals per Bed _____

Total Length of Laterals _____ ft. Number of Trenches _____ Trench Width _____

D. Setbacks Check the Boxes Below if the Required Setback has been Satisfied

Distance From	Private Well	Public Well	Surface Water	Gound Water	Pressure Water Lines	Property Lines	Foundations Yours	Foundations Neighbors	All Other Setbacks
Tank (ft)	50 ☐	500 ☐	50 ☐	NA ☐	25 ☐	20 ☐	15 ☐	25 ☐	☐
Field (ft)	100 ☐	500 ☐	50 ☐	4 ☐	30 ☐	20 ☐	30 ☐	40 ☐	☐
Lagoon (ft)	100 ☒	500 ☒	50 ☒	N/A ☐	30 ☒	50 ☒	100 ☒	200 ☒	☒

E. Required Signatures

Home Building Contractor Andrew J Semerad Date 8-9-12

Installer Lloyd J Gilbert Date 8/9/12.

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, NE 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT

No. HS000653

System Type: LAGOON

Situs: 7400 W. Bluff Rd.

Legal Description: T11N-R05E-S14-Lot 29

Owner:

Permit Fee:	$345.00
Variance Fee:	$0.00
Extension Fee:	$0.00
Total Fees:	$345.00

Issued:	08/14/2012
Expires:	08/14/2013

Judith A Halstead

Judith A. Halstead, MS, Health Director


On-site Waste System Permit Holder:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead

Judith A. Halstead, MS
Health Director

RAYMOND CONTRACTING
13800 NW 70TH
RAYMOND NE 68428


PAWNEE CLAY, 2 TO 7 PERCENT SLOPES, SEVERELY ERODED
WATER
PAWNEE CLAY, 2 TO 7 PERCENT SLOPES, SEVERELY ERODED
SHARPSBURG SILTY CLAY LOAM, 5 TO 9 PERCENT SLOPES
PAWNEE CLAY LOAM, 2 TO 7 PERCENT SLOPES, ERODED
WATER
BURCHARD-NODAWAY COMPLEX, 2 TO 30 PERCENT SLOPES
14-11-05
WATER
SHARPSBURG SILTY CLAY LOAM, 2 TO 5 PERCENT SLOPES
BLUFF
23-11-05
NODAWAY SILT LOAM, CHANNELED
JUDSON SILT LOAM, 2 TO 6 PERCENT SLOPES