Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS000715

System Type: Lagoon

Situs: 25800 Ironhorse Ct.

Permit Fee: $355.00

Description: IRONHORSE ACRES ADDITION, Lot 6

Issued: 1/31/2013

Expires: 1/31/2014

Owner: ZUCHEGNA, ANTHONY W & SHERI C
& FRANCIL, CYNTHIA J
3025 ORWELL
LINCOLN, NE 68516

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

JAMES MCANDREW
3007 N ST
LINCOLN, NE 68510

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number H8000715

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 25800 Ironhorse CT (no rural route) City Firth NE Zip 68358

Legal Description 23 7 7 Ironhorse 12 6

1/4 1/4 Section Township Range Subdivison Addition Block Lot

Geographical Location (if known): Lat/Long: PID

B. Owner

Name Goings Homes Signature

Address 2909 Beaver City/State/Zip Lincoln NE 68503

Home Phone Work Phone 402-641-3231

C. Certified Installer

Name: Brad Southwick Signature Brad Southwick

Address City/State/Zip

Work Phone

D. Engineer ☐ Check and complete if engineer designed system P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 3 Is there a Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 3-4

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic Well Permit Applied for ☐ Yes ☐ No ☐ Not Applicable

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☒ County Resolution No. 02-30

1. Health Department Date rec'd 1/28/13 ACTION ☒ Approved ☐ Disapproved

Site visits Date frwd 1/28/13 Signature

2. Supt. Bldg. Insp. or Village Clerk Date rec'd ACTION ☐ Approved ☐ Disapproved

Comments Date frwd Signature See attached

3. City or County Engineer Date rec'd ACTION ☒ Approved ☐ Disapproved

Comments Date frwd Signature See attached

Installation Final Written Approval

By

Date

Business Office Use Only
Date Received 1-29-13 Amount Paid $355.00
Received By Brad Cash/Check No. 1039

White - Health Department Yellow - Engineer Pink - Building & Safety Form A Updated: 5/10

Nate C. Hartman

From: Mike J. Petersen
Sent: Monday, January 28, 2013 9:19 AM
To: Nate C. Hartman
Subject: 25800 Ironhorse
Attachments: Mike Petersen.vcf

Nate- According to Todd, lot 6 Ironhorse acres is a legal buildable lot which is not in the flood plain. -Mp



Mike Petersen
Building & Safety Dept.
Plans Examiner II

(402) 441-6445 Work
mjpetersen@lincoln.ne.gov

555 S. 10th Street Room 203
Lincoln, NE 68508


Nate C. Hartman

From: Ken D. Schroeder
Sent: Monday, January 28, 2013 10:14 AM
To: Nate C. Hartman
Subject: sewage disposal system for 25800 Ironhorse Ct.
Attachments: part of sec. 23-7-7.pdf

Nate,
Lancaster County Engineering Department indicates approval for a sewage disposal system for lot 6, "IRONHORSE ACRES ADDITION" located in the SW 1/4 of Section 23, T7N, R7E of the 6th P.M., Lancaster County, Nebraska. *(see attached part of sec.23-7-7)*
As always, subject to confirmation of and compliance with any floodplain elevation requirements prior to construction.
Ken

Kenneth D. Schroeder, RLS
Lancaster County Surveyor
444 Cherrycreek Road, Bldg. "C"
Lincoln, Nebraska 68528
kschroeder@lancaster.ne.gov
Phone (402) 441-7681
Fax (402) 441-8692

Part of Sec. 23 (7-7)



SSCANNED

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number H5000715

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 25800 Ironhorse CT (no rural route) City Firth NE Zip 68358

Legal Description 23 7 7 Ironhorse ~~12~~ 6

1/4 | 1/4 | Section | Township | Range | Subdivison | Addition | Block | Lot

Geographical Location (if known): Lat/Long: _____ PID _____

B. Owner

Name Goings Homes Signature _____

Address 2909 Beaver City/State/Zip Lincoln NE 68503

Home Phone _____ Work Phone 402-641-3231

C. Certified Installer

Name: Brad Southwick Signature Brad Southwick

Address _____ City/State/Zip _____

Work Phone _____

D. Engineer ☐ Check and complete if engineer designed system P.E. License Number: _____

Designer Name _____ Firm _____ Work Phone _____

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 3 Is there a Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 3-4

☐ Commercial Establishment/Other Facility Specify _____ Design flow in gallons per day _____

Type of Wastewater ☐ Domestic ☐ Non-Domestic Well Permit Applied for ☐ Yes ☐ No ☐ Not Applicable

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☒ County Resolution No. 02-30

1. Health Department
Site visits 4/26/13 - Need fence
5/16/13 - Too close to property line
- Lagoon needs moved
Date rec'd 1/28/13
Date frwd 1/28/13
ACTION ☑ Approved ☐ Disapproved
Signature _____

2. Supt. Bldg. Insp. or Village Clerk
Comments _____
Date rec'd _____
Date frwd _____
ACTION ☒ Approved ☐ Disapproved
Signature See attached

3. City or County Engineer
Comments _____
Date rec'd _____
Date frwd _____
- Lagoon Moved
- Fence Installed
ACTION ☒ Approved ☐ Disapproved
Signature See attached

Installation Final Written Approval
By Doug Rauh
Date 8/29/13

Business Office Use Only
Date Received 1-29-13 Amount Paid #355.00
Received By Bfaul Cash/Check No. 1030

White - Health Department | Yellow - Engineer | Pink - Building & Safety

Form A Updated: 5/10

01/26/2013 14:42 14024752462 BRAD SOUTHWICK PAGE 07