Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number
HSCCC865

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☒ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 23700 S 68th (no rural route) City Firth, NE Zip 68358

Legal Description NW 15 7 7 6th Principal Meridian LOT 9
(1/4 | 1/4 | Section | Township | Range | Subdivison | Addition | Block | Lot)

PID 14-15-100-004-000

B. Owner

Name Annette Wiltgen Signature

Address 31277 Chardonnay PT City/State/Zip Waukee, IA 50263

Home Phone 402-525-8292 Work Phone

C. Certified Installer

Name: Jason Kubik Signature

Address 105 Locust St City/State/Zip Hickman NE 68372

Work Phone 402-475-2462

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☒ Yes ☐ No Total Acres 76.23
Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits Date rec'd
Date frwd
Comments
ACTION ☐ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 1/22/14 Amount Paid 365.00
Received By SB Cash/Check No. 2013

White - Health Department Yellow - Engineer Pink - Building & Safety

Lincoln-Lancaster County Health Department
Environmental Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number: HS000865

Sewage Disposal System

Soil Absorption Test Data Report

Annex to Application

PLEASE PRINT OR TYPE

SE Corner of S. 68 & Olive Creek Rd.

System Location (Indicate correct number and street)

Address Olive Ck Rd. (no rural route) City Hickman NE, Zip 68372

Owner Annette Wiltgren Addresss

Soil Type (SCS): Percolation Rate: min./inch

Date of Tests 5/25 to 5/27 Weather: Precipitation .75" Temperature 70s

T7 R7 SEC 15

Percolation Test Data Table

A.	B.	C.	D.	E.	F.	G.	H.	I.	J.	K.	L.	M.	N.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time (Min)	Water Level Drop (in)	Percolation Rates (Min/in)
1	34	5/25	10/00	5/27	7/30	5/27	12/00	6	5/27	12/40	30	7/8	34
2			AM		AM		PM	6		PM		1	30
3								6				1 1/8	27
4								6				1 5/8	16
5								6				1 1/8	27
6	↓							6				1 1/2	20

Sum of Percolation Rates: 154
Average of Rates: 24
Rate Used for Calculation: 30

Person Conducting Percolation Tests

Name: Brad Southwick
Phone: 430-7606
Address 105 Locust 196
Hickman, Ne 68372

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Remarks

Signature of Reviewing Official Date

FORM 23-101 10-96

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS000865

System Type: Standard

Situs: No Site Address Specified

Issued: 1/23/2014

Expires: 1/23/2015

Description: S15, T7, R7, 6th Principal Meridian, LOT 9 NW

Owner: WILTGEN, ANNETTE M
31277 CHARDONNAY PT
WAUKEE, IA 50263-7065

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

SOUTHWICK LIQUID WASTE INC
105 LOCUST ST
HICKMAN, NE 68372



Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number: HS0009865

Onsite Wastewater Treatment System

Inspection Sheet

Date 3/1/2016 Legal Description NW ¼ ¼ 15/7/17 Section/Township/Range

Onsite System Location

Address (no rural route) 23700 S 68th City Firth

Owner AnneHee Wiltgen Address 31277 Chardonnay Pt Wahkee IA 50263

Mark One: [X] Dwelling ☐ Non-dwelling

[X] New System ☐ Alteration [☐ Tank Only ☐ Trench Only] ☐ Lateral Only

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification): _____

Drainfield Absorption System:

[X] Lateral ☐ Bed ☐ Non-standard (engineer-designed and NDEQ approved) ☐ Holding Tank ☐ Trench

Total square feet of drainfield 1058 Sq. Ft. Tank Size 2000 gals

Total length of laterals 312 Type of Distribution: [X] Chamber ☐ Perforated Pipe ☐ Other (describe)_____

No. of Absorption Laterals 3 Width 40.5 inches No. of Drop Boxes 0 Distribution Box 0

Leveling Method Used Lazer

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☑	500 ☐	50 ☑	NA ☑	10 ☐	5 ☑
Field (ft)	100 ☑	500 ☐	50 ☑	4 ☑	25 ☑	5 ☑

See attached well logs static water levels

Geographical Coordinates to 6 Decimals:

Tank na

Lateral #1 na Lateral #3 na

Lateral #2 na Lateral #4 na

Comments:

Inspections prior to Final Approval
Initial JAM Date 3/1/2016

Follow-Up _____ Date _____


Follow-Up _____ Date _____

Installation Final Written Approval
By James Neumann provisional
Date 3/2/16

Field Note Drawing (See Reverse Side):

3 Bdrm 1 residency 750 ft²

Quick 4 standard 3.375ft W


N
Olive Creek Rd
Horse Barn
Tk-Fence
clean out 75' Inlet (s, not visible
2k
100'
105'
24'
System, except was
covered w/out inspection
Lateral
Lateral
Lateral