MAR 1 2 2014

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number
HS000872

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ❑ Septic System ❑ Lagoon ❑ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 13701 Silver Fox Lane (no rural route) City Lincoln, NE Zip

Legal Description Beaver Creek 3

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID

B. Owner

Name Bryce Kleen Signature

Address 5900 S 72nd St. City/State/Zip Lincoln NE. 68516

Home Phone 402-419-3579 Work Phone

C. Certified Installer

Name: Melvin Eagner Signature Melvin Eagner

Address 4810 W Claire Ave City/State/Zip Lincoln NE. 68523

Work Phone 402-432-5698

D. Engineer

❑ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 4 Whirlpool Bathtub? ❑ Yes ☒ No Total Acres 3.01 3.03 NH

Garbage Grinder? ☒ Yes ❑ No

❑ Commercial Establishment/Other Facility Specify Design flow in gallons per day 500

Type of Wastewater ☒ Domestic ❑ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ❑ Municipal Code 24.38 ☑ County Resolution No. 02-30

1. Health Department
Site visits Date rec'd ACTION ❑ Approved ❑ Disapproved
Date frwd Signature
Comments

2. Supt. Bldg. Insp. or Village Clerk
Comments Date rec'd ACTION ❑ Approved ❑ Disapproved
Date frwd Signature

3. City or County Engineer
Comments Date rec'd ACTION ❑ Approved ❑ Disapproved
Date frwd Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 3-12-14 Amount Paid 345.00
Received By SB Cash/Check No. 7492

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS000872

System Type: Lagoon

Situs: 13701 SILVERFOX LN, RURAL, NE

Issued: 3/13/2014

Expires: 3/13/2015

Description: BEAVER CREEK ADDITION, Lot 3

Owner: KLEEN, BRYCE & CHARLOTTE
5900 S 72 ST
LINCOLN, NE 68516

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

GAGNER CONSTRUCTION COMPANY
4810 W CLAIRE AVE
LINCOLN, NE 68523

MAR 1 2 2014

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number
HS000872

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☑ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 13701 Silverfox Lane (no rural route) City Lincoln, NE Zip

Legal Description 28 10 8 Beaver Creek 3

1/4 | 1/4 | Section | Township | Range | Subdivison | Addition | Block | Lot

PID

B. Owner

Name Bryce Kleen Signature

Address 5900 S 72nd St. City/State/Zip Lincoln NE. 68516

Home Phone 402-419-3579 Work Phone

C. Certified Installer

Name: Melvin Gagner Signature Melvin Gagner

Address 4810 'W' Claire Ave City/State/Zip Lincoln NE. 68523

Work Phone 402-432-5698

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 4 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 3.01 3.03NH

Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day 500

Type of Wastewater ☒ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☑ County Resolution No. 02-30

1. Health Department
Site visits 7/15 & 7/16 Date rec'd 3/13/14
Date frwd 3/13/14
Comments

ACTION ☑ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments Date rec'd
Date frwd

ACTION ☑ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments Date rec'd
Date frwd

ACTION ☑ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By
Date 7/16/14

Business Office Use Only
Date Received 3-12-14 Amount Paid 365.00
Received By SB Cash/Check No. 7492

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
LAGOON/SEPTIC INSPECTION REPORT

Permit No. HS000872 Certified Installer: Gagner

Address: 13701 Silver Fox

Circle compliance status for each item. **IN = in compliance OUT = not in compliance NA = not applicable NO = not observed**

LAGOON SETBACKS

				Item	MIN. SETBACK DISTANCE – FT. (METERS)
IN	OUT	NA	NO	Surface Wtr. Distance from Wtr. Mark	50 ft. (15.2 m)
IN	OUT	NA	NO	Private Drinking Water Wells	100 ft. (30.5 m)
IN	OUT	NA	NO	Public Drinking Water Supply Wells:	
IN	OUT	NA	NO	Non-Community	100 ft. (30.5 m)
IN	OUT	NA	NO	Community	Evaluated by a professional engineer for potential impact on the well and submitted to the Dept. for approval l if less than 1000 ft. (304.8 m)
IN	OUT	NA	NO	All Other Water Wells	100 ft. (152.4 m)
IN	OUT	NA	NO	Water Lines:	
IN	OUT	NA	NO	Pressure Main	25 ft. (7.6 m)
IN	OUT	NA	NO	Pressure-Service Connection	25 ft. (7.6 m)
IN	OUT	NA	NO	Suction Line	100 ft. (30.5 m)
IN	OUT	NA	NO	Property Lines	50 ft. (15.2 m)
IN	OUT	NA	NO	Trees and Brush	50 ft. (15.2 m)
IN	OUT	NA	NO	Foundations: (see definition above)	
IN	OUT	NA	NO	Except Neighbor's Foundation:	
IN	OUT	NA	NO	Class 1	100 ft. (30.5 m)
IN	OUT	NA	NO	Class 2	100 ft. (30.5 m)
IN	OUT	NA	NO	Class 3	50 ft. (15.2 m)
IN	OUT	NA	NO	Neighbor's Foundation:	
IN	OUT	NA	NO	Class 1	200 ft. (61.0 m)
IN	OUT	NA	NO	Class 2	200 ft. (61.0 m)
IN	OUT	NA	NO	Class 3	100 ft. (30.5 m)

COMMENTS

Lagoon Dimensions:

TANK AND SOIL ABSORPTION SYSTEM SETBACKS

				Item	MIN. SETBACK DISTANCE – FT. (METERS) Tanks	Absorption, Infiltrative & Evaporative Systems
IN	OUT	NA	NO	Surface Water	50 ft. (15.2 m)	50 ft. (15.2 m)
IN	OUT	NA	NO	Private Drinking Water Wells	50 ft. (15.2 m)	100 ft. (30.5 m)
IN	OUT	NA	NO	Public Drinking Water Supply Wells:		
IN	OUT	NA	NO	Non-Community System	50 ft. (15.2 m)	100 ft. (30.5 m)
IN	OUT	NA	NO	Community System	500 ft. (152.4 m)	500 ft. (152. 4 m)
IN	OUT	NA	NO	Community System when a septic system or soil absorption system of > 1000 gpd is proposed	500 ft. (152.4 m)	Evaluated by professional engineer for potential impact on the well and submitted to the Depart. for approval if less than 1000 ft.
IN	OUT	NA	NO	All Other Water Wells	50 ft. (15.2 m)	100 ft. (30.5 m)
IN	OUT	NA	NO	Water Lines:		
IN	OUT	NA	NO	Pressure-Main	10 ft. (3.1 m)	25 ft. (7.6 m)
IN	OUT	NA	NO	Pressure-Service – Connection	10 ft. (3.1 m)	25 ft. (7.6 m)
IN	OUT	NA	NO	Suction Lines	50 ft. (15.2 m)	100 ft. (30.5 m)
IN	OUT	NA	NO	Property Lines	5 ft. (1.5 m)	5 ft. (1.5 m)
IN	OUT	NA	NO	Parking area, driveway, sidewalk or other impermeable surface or cover	5 ft. (1.5 m)	5 ft. (1.5 m)
IN	OUT	NA	NO	Foundations: (see definitions above)		
IN	OUT	NA	NO	Except Neighbor's Foundation:		
IN	OUT	NA	NO	Class 1	15 ft. (4.6 m)	30 ft. (9.1 m)
IN	OUT	NA	NO	Class 2	10 ft. (3.1 m)	20 ft. (6.1 m)
IN	OUT	NA	NO	Class 3	7 ft. (2.1 m)	10 ft. (3.1 m)
IN	OUT	NA	NO	Neighbor's Foundation:		
IN	OUT	NA	NO	Class 1	25 ft. (7.6 m)	40 ft. (12.2 m)
IN	OUT	NA	NO	Class 2	20 ft. (6.1 m)	30 ft. (9.1 m)
IN	OUT	NA	NO	Class 3	15 ft. (4.6 m)	20 ft. (6.1 m)

COMMENTS

Septic Tank Size: 1500

Lateral Sq. Footage:


- Partially Complete

Inspected By: Doug Smith **Date:** 7/15/14

13701 Silverfox Lane
Lincoln NE 68520

HS000872

JUL 15 2014



SCANNED