Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

APR 01 2014

A

Permit Number
HS000882

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 1700 S 134 St (no rural route) City ~~Lincoln~~ WALTON NE Zip 68461

Legal Description ____ 33 10 8 ____ 17NW
1/4 1/4 Section Township Range Subdivison Addition Block Lot

Geographical Location (if known): Lat/Long: ____ PID 23-33-100-004-000

B. Owner

Name Bart & Brenda Herrick Signature

Address 1700 S 134 St City/State/Zip Nt Walton, Ne, 68461

Home Phone 402-730-4373 Work Phone No

C. Certified Installer

Name: Kurt Viral Signature

Address 4620 W Mary Louise LN City/State/Zip Lincoln / Ne / 68524

Work Phone

D. Engineer

☐ Check and complete if engineer designed system P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 4 Is there a Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 4.65

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic Well Permit Applied for ☐ Yes ☐ No ☐ Not Applicable

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 4/2/14 Amount Paid 345.00
Received By SB Cash/Check No. 1058

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated 5/10

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022


C

Permit Number: 17S000882

Onsite Wastewater Treatment System

Preliminary Plan Specifications

Draw a plot plan showing onsite system sewer lines, drop of distribution boxes, tank, drainfields, percolation test holes, well, residence, direction of groundwater flow, property lines, and reserve area for replacement onsite system.



Approximate Scale: 1203 ft. = 17 grid line/s

A. Onsite System Location

Address (no rural route) 1700 S 134 St City Walton NE, Zip 68461

B. Proposed Septic Tank/s

Septic Tank Cap._____ gals Tank Material: ☐ Concrete ☐ Plastic ☐ Other_____ ☐ Lagoon(Max. seepage 1/8" per day)

C. Reserve Area for Replacement Onsite System

☐ Drainfield Absorption Area (percolation test required) ☒ Lagoon

D. Drainfield Absorption System

Percolation Rate_____ (min/inch = mpi) No. of Bedrooms_____ Soil Type_____ Land Slope_____%

☐ Trench ☐ Bed ☐ Non-Standard (engineer designed and NDEQ approved Total Square feet of drainfield_____sq.ft.

Total length of laterals_____ Type of distribution: ☐ Perforated pipe ☐ Half-Round ☐ Chamber ☐ Other

No. of absorption trenches_____ Width_____ No. of drop boxes_____ Distrubtion Box_____

No. of absorption beds_____ Width_____ No of Distribution lines per bed_____

E. Setbacks Check the Boxes Below if the Required Setback has been Satisfied

Distance From	Private Well	Public Well	Surface Water	Gound Water	Pressure Water Lines	Property Lines	Foundations Yours	Foundations Neighbors	All Other Setbacks
Tank (ft)	50 ☐	500 ☐	50 ☐	NA ☐	25 ☐	20 ☐	15 ☐	25 ☐	☐
Field (ft)	100 ☐	500 ☐	50 ☐	4 ☐	30 ☐	20 ☐	30 ☐	40 ☐	☐
Lagoon (ft)	100 ☒	500 ☒	50 ☒	N/A ☒	30 ☒	50 ☒	100 ☒	200 ☒	☒

F. Required Signatures

Home Building Contractor_____ Date_____

Installer_____ Date 3-29-14

Onsite Form C 12_06

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS000882

System Type: Lagoon

Situs: 1700 S 134 ST, RURAL, NE

Issued: 4/4/2014

Expires: 4/4/2015

Description: S33, T10, R8, 6th Principal Meridian, LOT 17 NW

Owner: HERRICK, BART C & BRENDA L
1700 S 134 ST
WALTON, NE 68461

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

KURT VIRGIL EXCAVATING INC
4620 W. MARY LOUISE LANE
LINCOLN, NE 68528

HEALTH DEPARTMENT

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
LAGOON/SEPTIC INSPECTION REPORT

Permit No. H5000882 Certified Installer: Kurt Virgil

Address: 1700 S 134th

Circle compliance status for each item. **IN = in compliance OUT = not in compliance NA = not applicable NO = not observed**

LAGOON SETBACKS

				Item	MIN. SETBACK DISTANCE – FT. (METERS)	COMMENTS
IN	OUT	NA	NO	Surface Wtr. Distance from Wtr. Mark	50 ft. (15.2 m)	
IN	OUT	NA	NO	Private Drinking Water Wells	100 ft. (30.5 m)	
IN	OUT	NA	NO	Public Drinking Water Supply Wells:		
IN	OUT	NA	NO	Non-Community	100 ft. (30.5 m)	
IN	OUT	NA	NO	Community	Evaluated by a professional engineer for potential impact on the well and submitted to the Dept. for approval if less than 1000 ft. (304.8 m)	
IN	OUT	NA	NO	All Other Water Wells	100 ft. (152.4 m)	
IN	OUT	NA	NO	Water Lines:		
IN	OUT	NA	NO	Pressure Main	25 ft. (7.6 m)	
IN	OUT	NA	NO	Pressure-Service Connection	25 ft. (7.6 m)	
IN	OUT	NA	NO	Suction Line	100 ft. (30.5 m)	
IN	OUT	NA	NO	Property Lines	50 ft. (15.2 m)	32 to south fence
IN	OUT	NA	NO	Trees and Brush	50 ft. (15.2 m)	
IN	OUT	NA	NO	Foundations: (see definition above)		
IN	OUT	NA	NO	Except Neighbor's Foundation:		
IN	OUT	NA	NO	Class 1	100 ft. (30.5 m)	
IN	OUT	NA	NO	Class 2	100 ft. (30.5 m)	
IN	OUT	NA	NO	Class 3	50 ft. (15.2 m)	
IN	OUT	NA	NO	Neighbor's Foundation:		
IN	OUT	NA	NO	Class 1	200 ft. (61.0 m)	Lagoon Dimensions: 68 dia.
IN	OUT	NA	NO	Class 2	200 ft. (61.0 m)	
IN	OUT	NA	NO	Class 3	100 ft. (30.5 m)	

TANK AND SOIL ABSORPTION SYSTEM SETBACKS

				Item	MIN. SETBACK DISTANCE – FT. (METERS) Tanks	Absorption, Infiltrative & Evaporative Systems	COMMENTS
IN	OUT	NA	NO	Surface Water	50 ft. (15.2 m)	50 ft. (15.2 m)	
IN	OUT	NA	NO	Private Drinking Water Wells	50 ft. (15.2 m)	100 ft. (30.5 m)	
IN	OUT	NA	NO	Public Drinking Water Supply Wells:			
IN	OUT	NA	NO	Non-Community System	50 ft. (15.2 m)	100 ft. (30.5 m)	
IN	OUT	NA	NO	Community System	500 ft. (152.4 m)	500 ft. (152. 4 m)	
IN	OUT	NA	NO	Community System when a septic system or soil absorption system of > 1000 gpd is proposed	500 ft. (152.4 m)	Evaluated by professional engineer for potential impact on the well and submitted to the Depart. for approval if less than 1000 ft.	
IN	OUT	NA	NO	All Other Water Wells	50 ft. (15.2 m)	100 ft. (30.5 m)	
IN	OUT	NA	NO	Water Lines:			
IN	OUT	NA	NO	Pressure-Main	10 ft. (3.1 m)	25 ft. (7.6 m)	
IN	OUT	NA	NO	Pressure-Service – Connection	10 ft. (3.1 m)	25 ft. (7.6 m)	
IN	OUT	NA	NO	Suction Lines	50 ft. (15.2 m)	100 ft. (30.5 m)	
IN	OUT	NA	NO	Property Lines	5 ft. (1.5 m)	5 ft. (1.5 m)	
IN	OUT	NA	NO	Parking area, driveway, sidewalk or other impermeable surface or cover	5 ft. (1.5 m)	5 ft. (1.5 m)	
IN	OUT	NA	NO	Foundations: (see definitions above)			
IN	OUT	NA	NO	Except Neighbor's Foundation:			
IN	OUT	NA	NO	Class 1	15 ft. (4.6 m)	30 ft. (9.1 m)	
IN	OUT	NA	NO	Class 2	10 ft. (3.1 m)	20 ft. (6.1 m)	Septic Tank Size:
IN	OUT	NA	NO	Class 3	7 ft. (2.1 m)	10 ft. (3.1 m)	
IN	OUT	NA	NO	Neighbor's Foundation:			
IN	OUT	NA	NO	Class 1	25 ft. (7.6 m)	40 ft. (12.2 m)	Lateral Sq. Footage:
IN	OUT	NA	NO	Class 2	20 ft. (6.1 m)	30 ft. (9.1 m)	
IN	OUT	NA	NO	Class 3	15 ft. (4.6 m)	20 ft. (6.1 m)	

Inspected By: _____ Date: 4/9/14

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

APR 01 2014

A

Permit Number
HS000882

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C.
Submit correct fee
with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 1700 S 134 St (no rural route) City ~~Lincoln~~ WALTON NE Zip 68461

Legal Description ____ 33 10 8 17NW
1/4 1/4 Section Township Range Subdivison Addition Block Lot

Geographical Location (if known): Lat/Long: ____ PID 23-33-100-004-000

B. Owner

Name Bart & Brenda Herrick Signature ____

Address 1700 S 134 St City/State/Zip Nt Walton, Ne, 68461

Home Phone 402-730-4373 Work Phone No

C. Certified Installer

Name: Kurt Viral Signature ____

Address 4620 W Mary Louise LN City/State/Zip Lincoln / Ne / 68528

Work Phone ____

D. Engineer

☐ Check and complete if engineer designed system P.E. License Number: ____

Designer Name ____ Firm ____ Work Phone ____

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 4 Is there a Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 4.65

☐ Commercial Establishment/Other Facility Specify ____ Design flow in gallons per day ____

Type of Wastewater ☐ Domestic ☐ Non-Domestic Well Permit Applied for ☐ Yes ☐ No ☐ Not Applicable

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits Kurt Cayon - DPH 4/8/14
Date rec'd 4/4/14
Date frwd 4/4/14
ACTION ☒ Approved ☐ Disapproved
Signature ____

2. Supt. Bldg. Insp. or Village Clerk
Comments ____
Date rec'd ____
Date frwd ____
ACTION ☐ Approved ☐ Disapproved
Signature ____

3. City or County Engineer
Comments ____
Date rec'd ____
Date frwd ____
ACTION ☐ Approved ☐ Disapproved
Signature ____

Installation Final Written Approval
By Doug Rustad
Date 7/1/14

Business Office Use Only
Date Received 4/2/14 Amount Paid 345.00
Received By SB Cash/Check No. 1058

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 5/10