Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

APR 17 2014

A

Permit Number
HS000893

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 110th Panama Rd (no rural route) City ~~SB~~, NE Zip

Legal Description 12 7 7 59
1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 14-12-400-005-000

B. Owner

Name Eric + Deagne Stieb Signature

Address 26651 S. 176th St ~~NE~~ City/State/Zip Adams NE 68301

Home Phone Work Phone

C. Certified Installer

Name: Nathan Peterson Signature

Address 7701 Cornhusker Hwy Suite 5 City/State/Zip Lincoln NE 68507

Work Phone

D. Engineer ☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 5 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 3+
Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits Date rec'd **ACTION** ☐ Approved ☐ Disapproved
Date frwd Signature
Comments

2. Supt. Bldg. Insp. or Village Clerk
Comments Date rec'd **ACTION** ☐ Approved ☐ Disapproved
Date frwd Signature

3. City or County Engineer
Comments Date rec'd **ACTION** ☐ Approved ☐ Disapproved
Date frwd Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 4-21-14 Amount Paid 305.00
Received By SB Cash/Check No. 4000

White - Health Department Yellow - Engineer Pink - Building & Safety

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS000893

System Type: Lagoon

Situs: No Site Address Specified

Issued: 4/25/2014

Expires: 4/25/2015

Description: S12, T7, R7, 6th Principal Meridian, LOT 59 SE

Owner: STIEB, ERIC & DEANNE
26651 S 176 ST
ADAMS, NE 68301

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

INFINITY EXCAVATING LLC
7701 CORNHUSKER HWY STE 5
LINCOLN, NE 68507

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

APR 17 2014

A

Permit Number
HS000893

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location 22977 So. 110th St

Address 110th Panama Rd (no rural route) City ~~Lincoln~~, NE Zip

Legal Description 12 7 7 59

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 14-12-400-005-000

B. Owner

Name Eric + Deanne Stieb Signature 560-7555 Matt Kurl

Address 26651 S. 176th St City/State/Zip Adams NE 68301

Home Phone Work Phone

C. Certified Installer

Name: Nathan Peterson Signature

Address 7701 Cornhusker Hwy Suite 5 City/State/Zip Lincoln NE 68507

Work Phone

D. Engineer ☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 5 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 3+

Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits 6/18/14
Comments Line + Lagoon - Need fence
Date rec'd 4/24/14
Date frwd 4/24/14
ACTION ☒ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments
Date rec'd 4/24/14
Date frwd 4/24/14
ACTION ☒ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments
Date rec'd 4-24-2014
Date frwd 4-24-2014
ACTION ☒ Approved ☐ Disapproved
Signature Jim Plauck

Installation Final Written Approval
By
Date 11/19/14

Business Office Use Only
Date Received 4-24-14 Amount Paid 305.00
Received By SB Cash/Check No. 4000

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
LAGOON/SEPTIC INSPECTION REPORT

Permit No. HS 000893 Certified Installer: Nate Peterson

Address: 22977 S. 110th

Circle compliance status for each item. **IN = in compliance OUT = not in compliance NA = not applicable NO = not observed**

LAGOON SETBACKS

				Item	MIN. SETBACK DISTANCE – FT. (METERS)	COMMENTS
IN	OUT	NA	NO	Surface Wtr. Distance from Wtr. Mark	50 ft. (15.2 m)	
IN	OUT	NA	NO	Private Drinking Water Wells	100 ft. (30.5 m)	
IN	OUT	NA	NO	Public Drinking Water Supply Wells:		
IN	OUT	NA	NO	Non-Community	100 ft. (30.5 m)	
IN	OUT	NA	NO	Community	Evaluated by a professional engineer for potential impact on the well and submitted to the Dept. for approval I if less than 1000 ft. (304.8 m)	
IN	OUT	NA	NO	All Other Water Wells	100 ft. (152.4 m)	
IN	OUT	NA	NO	Water Lines:		
IN	OUT	NA	NO	Pressure Main	25 ft. (7.6 m)	
IN	OUT	NA	NO	Pressure-Service Connection	25 ft. (7.6 m)	
IN	OUT	NA	NO	Suction Line	100 ft. (30.5 m)	Fence is
IN	OUT	NA	NO	Property Lines	50 ft. (15.2 m)	
IN	OUT	NA	NO	Trees and Brush	50 ft. (15.2 m)	Not installed
IN	OUT	NA	NO	Foundations: (see definition above)		
IN	OUT	NA	NO	Except Neighbor's Foundation:		
IN	OUT	NA	NO	Class 1	100 ft. (30.5 m)	
IN	OUT	NA	NO	Class 2	100 ft. (30.5 m)	
IN	OUT	NA	NO	Class 3	50 ft. (15.2 m)	
IN	OUT	NA	NO	Neighbor's Foundation:		
IN	OUT	NA	NO	Class 1	200 ft. (61.0 m)	Lagoon Dimensions: 65'
IN	OUT	NA	NO	Class 2	200 ft. (61.0 m)	
IN	OUT	NA	NO	Class 3	100 ft. (30.5 m)	

TANK AND SOIL ABSORPTION SYSTEM SETBACKS

				Item	MIN. SETBACK DISTANCE – FT. (METERS) Tanks	Absorption, Infiltrative & Evaporative Systems	COMMENTS
IN	OUT	NA	NO	Surface Water	50 ft. (15.2 m)	50 ft. (15.2 m)	
IN	OUT	NA	NO	Private Drinking Water Wells	50 ft. (15.2 m)	100 ft. (30.5 m)	
IN	OUT	NA	NO	Public Drinking Water Supply Wells:			
IN	OUT	NA	NO	Non-Community System	50 ft. (15.2 m)	100 ft. (30.5 m)	
IN	OUT	NA	NO	Community System	500 ft. (152.4 m)	500 ft. (152. 4 m)	
IN	OUT	NA	NO	Community System when a septic system or soil absorption system of > 1000 gpd is proposed	500 ft. (152.4 m)	Evaluated by professional engineer for potential impact on the well and submitted to the Depart. for approval if less than 1000 ft.	
IN	OUT	NA	NO	All Other Water Wells	50 ft. (15.2 m)	100 ft. (30.5 m)	
IN	OUT	NA	NO	Water Lines:			
IN	OUT	NA	NO	Pressure-Main	10 ft. (3.1 m)	25 ft. (7.6 m)	
IN	OUT	NA	NO	Pressure-Service – Connection	10 ft. (3.1 m)	25 ft. (7.6 m)	
IN	OUT	NA	NO	Suction Lines	50 ft. (15.2 m)	100 ft. (30.5 m)	
IN	OUT	NA	NO	Property Lines	5 ft. (1.5 m)	5 ft. (1.5 m)	
IN	OUT	NA	NO	Parking area, driveway, sidewalk or other impermeable surface or cover	5 ft. (1.5 m)	5 ft. (1.5 m)	
IN	OUT	NA	NO	Foundations: (see definitions above)			
IN	OUT	NA	NO	Except Neighbor's Foundation:			
IN	OUT	NA	NO	Class 1	15 ft. (4.6 m)	30 ft. (9.1 m)	
IN	OUT	NA	NO	Class 2	10 ft. (3.1 m)	20 ft. (6.1 m)	Septic Tank Size:
IN	OUT	NA	NO	Class 3	7 ft. (2.1 m)	10 ft. (3.1 m)	
IN	OUT	NA	NO	Neighbor's Foundation:			
IN	OUT	NA	NO	Class 1	25 ft. (7.6 m)	40 ft. (12.2 m)	Lateral Sq. Footage:
IN	OUT	NA	NO	Class 2	20 ft. (6.1 m)	30 ft. (9.1 m)	
IN	OUT	NA	NO	Class 3	15 ft. (4.6 m)	20 ft. (6.1 m)	

Inspected By: Doug Arnold Date: 6/18/14