Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

AUG 12 2014

A

Permit Number
HS000951

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 6950 SW 29th Cir (no rural route) City Lincoln, NE Zip 68523

Legal Description _____ Twin Pines 3 5

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 09-17-403-005-000

B. Owner

Name Vaughn Hinrichsen Signature _____

Address 6801 S 70th ST City/State/Zip Lincoln NE 68516

Home Phone _____ Work Phone _____

C. Certified Installer

Name: Jason Kubik Signature Jason Kubik

Address 105 Locust ST City/State/Zip Hickman NE 68372

Work Phone _____

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number: _____

Designer Name _____ Firm _____ Work Phone _____

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 5 Whirlpool Bathtub? ☐ Yes ☐ No Total Acres _____

Garbage Grinder? ☐ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify _____ Design flow in gallons per day _____

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits _____ Date rec'd _____ ACTION ☐ Approved ☐ Disapproved
Date frwd _____ Signature _____
Comments _____

2. Supt. Bldg. Insp. or Village Clerk
Comments _____ Date rec'd _____ ACTION ☐ Approved ☐ Disapproved
Date frwd _____ Signature _____

3. City or County Engineer
Comments _____ Date rec'd _____ ACTION ☐ Approved ☐ Disapproved
Date frwd _____ Signature _____

Installation Final Written Approval
By _____
Date _____

Business Office Use Only
Date Received 8-12-14 Amount Paid 365.00
Received By SB Cash/Check No. 2124

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS000951

System Type: Lagoon

Situs: 6950 SW 29TH CIR RURAL NE

Issued: 8/14/2014

Expires: 8/14/2015

Description: TWIN PINES ADDITION, BLOCK 3, Lot 5

Owner: HINRICHSEN, VAUGHN &
JACQUELINE
6801 S 70 ST
LINCOLN, NE 68516

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

SOUTHWICK LIQUID WASTE
105 LOCUST STREET
HICKMAN, NE 68372

SCANNED

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

AUG 12 2014

A

Permit Number
HS000951

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 6950 SW 29th Cir City Lincoln, NE Zip 68523
(no rural route)

Legal Description 17 9 6 Twin Pines 3 5
1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 09-17-403-005-000

B. Owner

Name Vaughn Hinrichsen Signature

Address 6801 S 70th ST City/State/Zip Lincoln NE 68516

Home Phone Work Phone

C. Certified Installer

Name: Jason Kubik Signature Jason Kubik

Address 105 Locust ST City/State/Zip Hickman NE 68372

Work Phone

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 5 Whirlpool Bathtub? ☐ Yes ☐ No Total Acres
Garbage Grinder? ☐ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits 12/16/14
line + partial on lagoon
Comments Need fence
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments
Date rec'd
Date frwd
ACTION ☑ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments
Date rec'd
Date frwd
ACTION ☑ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By Jim Newman
Date 3/25/2015

Business Office Use Only
Date Received 8-12-14 Amount Paid 365.00
Received By SB Cash/Check No. 2134

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
LAGOON/SEPTIC INSPECTION REPORT

Permit No. HS000951 Certified Installer: Blaine Johnson

Address: 6950 SW 29th

Circle compliance status for each item. **IN = in compliance OUT = not in compliance NA = not applicable NO = not observed**

LAGOON SETBACKS

				Item	MIN. SETBACK DISTANCE – FT. (METERS)
IN	OUT	NA	NO	Surface Wtr. Distance from Wtr. Mark	50 ft. (15.2 m)
IN	OUT	NA	NO	Private Drinking Water Wells	100 ft. (30.5 m)
IN	OUT	NA	NO	Public Drinking Water Supply Wells:	
IN	OUT	NA	NO	Non-Community	100 ft. (30.5 m)
IN	OUT	NA	NO	Community	Evaluated by a professional engineer for potential impact on the well and submitted to the Dept. for approval if less than 1000 ft. (304.8 m)
IN	OUT	NA	NO	All Other Water Wells	100 ft. (152.4 m)
IN	OUT	NA	NO	Water Lines:	
IN	OUT	NA	NO	Pressure Main	25 ft. (7.6 m)
IN	OUT	NA	NO	Pressure-Service Connection	25 ft. (7.6 m)
IN	OUT	NA	NO	Suction Line	100 ft. (30.5 m)
IN	OUT	NA	NO	Property Lines	50 ft. (15.2 m)
IN	OUT	NA	NO	Trees and Brush	50 ft. (15.2 m)
IN	OUT	NA	NO	Foundations: (see definition above)	
IN	OUT	NA	NO	Except Neighbor's Foundation:	
IN	OUT	NA	NO	Class 1	100 ft. (30.5 m)
IN	OUT	NA	NO	Class 2	100 ft. (30.5 m)
IN	OUT	NA	NO	Class 3	50 ft. (15.2 m)
IN	OUT	NA	NO	Neighbor's Foundation:	
IN	OUT	NA	NO	Class 1	200 ft. (61.0 m)
IN	OUT	NA	NO	Class 2	200 ft. (61.0 m)
IN	OUT	NA	NO	Class 3	100 ft. (30.5 m)

COMMENTS

- Lagoon Line and Partial on Lagoon

Lagoon Dimensions:

TANK AND SOIL ABSORPTION SYSTEM SETBACKS

				Item	MIN. SETBACK DISTANCE – FT. (METERS)	
					Tanks	Absorption, Infiltrative & Evaporative Systems
IN	OUT	NA	NO	Surface Water	50 ft. (15.2 m)	50 ft. (15.2 m)
IN	OUT	NA	NO	Private Drinking Water Wells	50 ft. (15.2 m)	100 ft. (30.5 m)
IN	OUT	NA	NO	Public Drinking Water Supply Wells:		
IN	OUT	NA	NO	Non-Community System	50 ft. (15.2 m)	100 ft. (30.5 m)
IN	OUT	NA	NO	Community System	500 ft. (152.4 m)	500 ft. (152. 4 m)
IN	OUT	NA	NO	Community System when a septic system or soil absorption system of > 1000 gpd is proposed	500 ft. (152.4 m)	Evaluated by professional engineer for potential impact on the well and submitted to the Depart. for approval if less than 1000 ft.
IN	OUT	NA	NO	All Other Water Wells	50 ft. (15.2 m)	100 ft. (30.5 m)
IN	OUT	NA	NO	Water Lines:		
IN	OUT	NA	NO	Pressure-Main	10 ft. (3.1 m)	25 ft. (7.6 m)
IN	OUT	NA	NO	Pressure-Service – Connection	10 ft. (3.1 m)	25 ft. (7.6 m)
IN	OUT	NA	NO	Suction Lines	50 ft. (15.2 m)	100 ft. (30.5 m)
IN	OUT	NA	NO	Property Lines	5 ft. (1.5 m)	5 ft. (1.5 m)
IN	OUT	NA	NO	Parking area, driveway, sidewalk or other impermeable surface or cover	5 ft. (1.5 m)	5 ft. (1.5 m)
IN	OUT	NA	NO	Foundations: (see definitions above)		
IN	OUT	NA	NO	Except Neighbor's Foundation:		
IN	OUT	NA	NO	Class 1	15 ft. (4.6 m)	30 ft. (9.1 m)
IN	OUT	NA	NO	Class 2	10 ft. (3.1 m)	20 ft. (6.1 m)
IN	OUT	NA	NO	Class 3	7 ft. (2.1 m)	10 ft. (3.1 m)
IN	OUT	NA	NO	Neighbor's Foundation:		
IN	OUT	NA	NO	Class 1	25 ft. (7.6 m)	40 ft. (12.2 m)
IN	OUT	NA	NO	Class 2	20 ft. (6.1 m)	30 ft. (9.1 m)
IN	OUT	NA	NO	Class 3	15 ft. (4.6 m)	20 ft. (6.1 m)

COMMENTS

Septic Tank Size:

Lateral Sq. Footage:

Inspected By: Doug Anderson **Date:** 12/16/14