Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001016

System Type: Lagoon

Situs: No Site Address Specified

Issued: 1/14/2015

Expires: 1/14/2016

Description: WHISPERING CREEK 1ST ADDITION, BLOCK 1, Lot 5

Owner: SPETHMAN, SCOTT G
3765 SAVANNAH CIR
LINCOLN, NE 68516

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

MANZITTO BUILDERS, INC
3341 PIONEERS BLVD
LINCOLN, NE 68526

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number: HS001016

Onsite Wastewater Treatment System

Inspection Sheet

Date 12/22/2015 Legal Description Blk1 Lot 5 18 / 9N / 8E

¼ ¼ Section/Township/Range

Onsite System Location

Address (no rural route) _____ City _____

Owner _____ Address _____

Mark One: ❑ Dwelling ❑ Non-dwelling

☒ New System ❑ Alteration [❑ Tank Only ❑ Trench Only] ❑ Lateral Only

❑ Temporary modification (Describe problem causing discharge and reason for temporary modification): _____

_____

Drainfield Absorption System:

❑ Lateral ❑ Bed ☒ Non-standard (engineer-designed and NDEQ approved) ❑ Holding Tank ❑ Trench

Total square feet of drainfield _____ Sq. Ft. Tank Size 2 Tanks gals

Total length of laterals _____ Type of Distribution: ❑ Chamber ❑ Perforated Pipe ❑ Other (describe) _____

_____

No. of Absorption Laterals 1 Width _____ No. of Drop Boxes _____ Distribution Box _____

Leveling Method Used _____

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☒	50 ☒	50 ☒	NA ☒	10 ☒	5 ☒
Field (ft)	100 ☒	500 ☒	50 ☒	4 ☒	25 ☒	5 ☒

Geographical Coordinates to 6 Decimals: On rural water

Tank _____

Lateral #1 _____ Lateral #3 _____

Lateral #2 _____ Lateral #4 _____

Comments:

- Covered prior to inspection
- Engineered System

Field Note Drawing (See Reverse Side):

Inspections prior to Final Approval

Initial _____ Date _____

Follow-Up _____ Date _____


Follow-Up _____ Date _____

Installation Final Written Approval

By _____

Date 12/22/15

Updated 4/15



- 5 ft between cleanouts wide
- 60 ft between cleanouts long