Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001029

System Type: Lagoon

Situs: No Site Address Specified

Issued: 2/24/2015

Expires: 2/24/2016

Description: MASEKS FIRST ADDITION, BLOCK 1, Lot 2

Owner: DAY, DUSTIN & ASHLEY
1120 GARDEN VALLEY RD
LINCOLN, NE 68521

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

SUBBERT WELLS & SEPTIC
1012 CO RD M
MEAD, NE 68041

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number:

Onsite Wastewater Treatment System

Inspection Sheet

Date 7/30/15 Legal Description ¼ ¼ 9 11 6 Section/Township/Range

Onsite System Location

Address (no rural route) 2525 Merrick Rd City Raymond

Owner _____ Address _____

Mark One: ❑ Dwelling ❑ Non-dwelling

☒ New System ❑ Alteration [❑ Tank Only ❑ Trench Only] ❑ Lateral Only

❑ Temporary modification (Describe problem causing discharge and reason for temporary modification): _____

_____

Drainfield Absorption System:

☒ Lateral ❑ Bed ❑ Non-standard (engineer-designed and NDEQ approved) ❑ Holding Tank ❑ Trench

Total square feet of drainfield 990 Sq. Ft. Tank Size 2000 gals

Total length of laterals 250 Type of Distribution: ☒ Chamber ❑ Perforated Pipe ❑ Other (describe) _____

No. of Absorption Laterals 2 Width 48" No. of Drop Boxes 1 Distribution Box _____

Leveling Method Used Laser

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☑	500 ☑	50 ☑	NA ☑	10 ☑	5 ☑
Field (ft)	100 ☑	500 ☑	50 ☑	4 ☑	25 ☑	5 ☑

Geographical Coordinates to 6 Decimals:

Tank NA

Lateral #1 _____ Lateral #3 _____

Lateral #2 _____ Lateral #4 _____

Comments:

Inspections prior to Final Approval
Initial 7/30/15 Date 06

Follow-Up _____ Date _____

Follow-Up _____ Date _____

Installation Final Written Approval
By Dean Smith

Date 7/30/15

Field Note Drawing (See Reverse Side):