Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS001114

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☒ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 9705 N 1ST St (no rural route) City LINCOLN, NE Zip 68531

Legal Description 22 11 6 6th Principal Meridian 3 NE

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 12-22-200-003-000

B. Owner

Name Patrick Faughn Signature

Address 9705 N 1st City/State/Zip LINCOLN, NE 68531

Home Phone Work Phone

C. Certified Installer Waverly Plumbing & Well Co

Name: Michael P Dietze Signature Michael P Dietze

Address PO Box 116 City/State/Zip Waverly NE 68462

Work Phone 402-786-5620

D. Engineer ☐ Check and complete if engineer designed system

P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 9

Garbage Grinder? ☐ Yes ☒ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature
Comments

2. Supt. Bldg. Insp. or Village Clerk
Comments Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature

3. City or County Engineer
Comments Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 8-6-15 Amount Paid $375.00
Received By SB Cash/Check No. 31789

White - Health Department Yellow - Engineer Pink - Building & Safety

AUG 06 2015

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number: HS001114

Onsite Wastewater Treatment System
Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 9705 N 1ST St (no rural route) City Lincoln NE, Zip 68531

Owner Patrick Faughn Address Legal S22 T11 R6 6th Principal Meridian Lot 3NE
Parcel ID 12-22-200-003-000

Date of Tests 07-31-2015 to 08-01-2015 Weather: Precipitation Ø Temperature 67°

Percolation Test Data Table

A.	B.	C.	D.	E.	F.	G.	H.	I.	J.	K.	L.	M.	N.
		Saturation/Swelling Time				Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					Results		
		Start		End		Start		Initial	End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (in)	Percolation Rates (Min/in = mpi)
1	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1	30
2	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1 1/4	24
3	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1 1/8	27
4	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1	30
5	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1 1/4	24
6	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1 1/4	24
								6					
								6					

Person Conducting Percolation Test

Name: Suzette Buls
Phone: 402
Address P.O. Box 308
Waverly, NE 68462

Sum of Percolation Rates: 159
Average of Rates: 26.5
Rate Used for Calculation: 27

Soil type (NRCS Maps/Other) Silty Clay Loam
Groundwater Depth 46 ft

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.) _____

Signature of Reviewing Official _____ Date _____

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001114

System Type: Standard

Situs: 9705 N 1 ST, RURAL, NE

Issued: 8/12/2015

Expires: 8/12/2016

Description: S22, T11, R6, 6th Principal Meridian, LOT 3 NE

Owner: FAUGHN, PATRICK M
9705 N 1 ST
LINCOLN, NE 68531

Judith A Halstead
Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead
Judith A. Halstead, MS
Health Director

WAVERLY PLUMBING & WELL CO
P.O. BOX 116
14150 LANCASHIRE
WAVERLY, NE 68462

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number: H5001114

Onsite Wastewater Treatment System

Inspection Sheet

Date 12/29/15 Legal Description ¼ ¼ 22/11/6 Section/Township/Range

Onsite System Location

Address (no rural route) 9705 N 1ST ST City Lincoln

Owner Patrick Fanghn Address Same

Mark One: ☑ Dwelling ☐ Non-dwelling

☐ New System ☐ Alteration [☐ Tank Only ☐ Trench Only] ☐ Lateral Only

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification): _____

Drainfield Absorption System:

☑ Lateral ☐ Bed ☐ Non-standard (engineer-designed and NDEQ approved) ☐ Holding Tank ☐ Trench

Total square feet of drainfield 754 Sq. Ft. Tank Size 1000 gals

Total length of laterals 208 Type of Distribution: ☑ Chamber ☐ Perforated Pipe ☐ Other (describe) _____

No. of Absorption Laterals 2 Width 36" No. of Drop Boxes na Distribution Box 1

Leveling Method Used na

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☑	500 ☑	50 ☑	NA ☑	10 ☑	5 ☑
Field (ft)	100 ☑	500 ☑	50 ☑	4 ☑	25 ☑	5 ☑

Geographical Coordinates to 6 Decimals:

Tank na

Lateral #1 na Lateral #3 —

Lateral #2 na Lateral #4 —

Comments:

Inspections prior to Final Approval
Initial _____ Date 12/29/15

Follow-Up _____ Date _____

Follow-Up _____ Date _____

Installation Final Written Approval
By _____
Date 12/29/15

Field Note Drawing (See Reverse Side):


Field Drawing

min 1000 TNK

Lateral 750 ft²
Area min

NOTES

ARC 36 3.625



Field Drawing

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

SCANNED

A

Permit Number
HS001114

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☒ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 9705 N 1ST St (no rural route) City LINCOLN, NE Zip 68531

Legal Description 22 11 6 6th Principal Meridian 3 NE

1/4 | 1/4 | Section | Township | Range | Subdivison | Addition | Block | Lot

PID 12-22-200-003-000

B. Owner

Name Patrick Faughn Signature

Address 9705 N 1st City/State/Zip LINCOLN, NE 68531

Home Phone Work Phone

C. Certified Installer Waverly Plumbing & Well Co

Name: Michael P Dietze Signature Michael P. Dietze

Address PO Box 116 City/State/Zip Waverly NE 68462

Work Phone 402-786-5620

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 9 8.76

Garbage Grinder? ☐ Yes ☒ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits Jim Nemmer 12/29/15
Comments
Date rec'd 8/12/15
Date frwd 8/12/15
ACTION ☒ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By Jim Nemmer
Date 12/29/2015

Business Office Use Only
Date Received 8-6-15 Amount Paid $375.00
Received By SB Cash/Check No. 31789

White - Health Department Yellow - Engineer Pink - Building & Safety

* Existing property - system replaced

Form A Updated: 1/13

AUG 06 2015

SCANNED

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number: HS00 1114

Onsite Wastewater Treatment System
Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 9705 N 1ST St (no rural route) City Lincoln NE, Zip 68531

Owner Patrick Faughn Address Legal S22 T11 R6 6th Principal Meridian Lot 3NE
Parcel ID 12-22-200-003-000

Date of Tests 07-31-2015 to 08-01-2015 Weather: Precipitation Ø Temperature 67°

Percolation Test Data Table

A.	B.	C.	D.	E.	F.	G.	H.	I.	J.	K.	L.	M.	N.
		Saturation/Swelling Time				Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					Results		
		Start		End		Start		Initial	End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (in)	Percolation Rates (Min/in = mpi)
1	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1	30
2	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1 1/4	24
3	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1 1/8	27
4	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1	30
5	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1 1/4	24
6	36	7/31	6:30p	8/01	7:30a	8/01	7:30a	6	8/01	8:00a	30	1 1/4	24
								6					
								6					

Person Conducting Percolation Test

Name: Suzette Buls
Phone: 402
Address PO Box 308
Waverly, NE 68462

Sum of Percolation Rates: 159
Average of Rates: 26.5
Rate Used for Calculation: 27

Soil type (NRCS Maps/Other) Silty Clay Loam
Groundwater Depth 46 ft

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date

Site Form B 12_06

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

SCANNED

Exhibit 5

Permit Number: H5001114

Onsite Wastewater Treatment System

Inspection Sheet

Date 12/29/15 Legal Description ¼ ¼ 22/11/6 Section/Township/Range

Onsite System Location

Address (no rural route) 9705 N 1ST ST City Lincoln

Owner Patrick Faughn Address same

Mark One: ☑ Dwelling ☐ Non-dwelling

☐ New System ☐ Alteration [☐ Tank Only ☐ Trench Only] ☐ Lateral Only

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification): _____

Drainfield Absorption System:

☑ Lateral ☐ Bed ☐ Non-standard (engineer-designed and NDEQ approved) ☐ Holding Tank ☐ Trench

Total square feet of drainfield 754 Sq. Ft. Tank Size 1000 gals

Total length of laterals 208 Type of Distribution: ☑ Chamber ☐ Perforated Pipe ☐ Other (describe)_____

No. of Absorption Laterals 2 Width 36" No. of Drop Boxes na Distribution Box 1

Leveling Method Used na

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☑	500 ☑	50 ☑	NA ☑	10 ☑	5 ☑
Field (ft)	100 ☑	500 ☑	50 ☑	4 ☑	25 ☑	5 ☑

Geographical Coordinates to 6 Decimals:

Tank na

Lateral #1 na Lateral #3 –

Lateral #2 na Lateral #4 –

Comments:

Inspections prior to Final Approval
Initial _____ Date 12/29/15

Follow-Up _____ Date _____

Follow-Up _____ Date _____


Installation Final Written Approval
By _____
Date 12/29/15

Field Note Drawing (See Reverse Side):

Updated 4/15

Field Drawing

min 1000 TNK
Lateral 750 ft²
Area Min
NOTES
ARC 360 3.625



Field Drawing