Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS001392

Onsite Wastewater Treatment System Permit Application

Include Form B and C. Submit correct fee with this Application

☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

PLEASE PRINT OR TYPE

A. Onsite System Location

Address* 11388 Old Cheney (no rural route) City Walton, NE Zip 68461

Legal Description SW 5 7 9 8 Shultz Add 25

1/4 | 1/4 | Section | Township | Range | Subdivison | Addition | Block | Lot

PID 22-07-400-003-000 *Approx. Address (If to be determined)

B. Owner

Name Josh Miller Signature

Address 8035 Hunters Ridge Rd City/State/Zip Lincoln NE 68516

Home Phone Work Phone

C. Certified Installer

Name: Jason Kubik Signature

Address 105 Locust St City/State/Zip Hickman NE 68372

Work Phone

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 6 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 41.61

Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process

1. Health Department
Site visits
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 2-9-17 Amount Paid $395.00
Received By SB Cash/Check No. 2811

White - Health Department Yellow - Engineer Pink - Building & Safety

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001392

System Type: Lagoon

Situs: No Site Address Specified

Description: S7, T9, R8, 6th Principal Meridian, LOT 25 S1/2 & +- 5.84 AC OF LOT 2 SCHULTZ ADD (DESC IN 2012-062394)

Owner: MILLER, JOSHUA P SR & SARAH E
8035 HUNTERS RIDGE RD
LINCOLN, NE 68516

Issued: 2/10/2017

Expires: 2/10/2018

Judith A Halstead

Judith A. Halstead, MS, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Judith A Halstead

Judith A. Halstead, MS
Health Director

SOUTHWICK LIQUID WASTE INC
105 LOCUST ST
HICKMAN, NE 68372

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8643

B

Permit Number:

Onsite Wastewater Treatment System
Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 11388 OLD CHENEY RD (no rural route) City WALTON NE, Zip 68461

Owner JOSH MILLER Address 8035 HUNTERS RIDGE RD

Date of Tests 4/26/17 to 4/27/17 Weather: Precipitation 0 Temperature 50

Percolation Test Data Table

A.	B.	C. D. E. F. Saturation/Swelling Time				G. H. I. J. K. Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					L. M. N. Results		
		Start		End		Start			End				
Hole No.	Hole Depth(in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Initial Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop(in)	Percolation Rates (Min/in = mpi)
1	30	4/26	2:30	4/27	1:30	4/27	5:00	6	4/27	5:30	30	1.00	30
2	30	4/26	2:30	4/27	1:30	4/27	5:00	6	4/27	5:30	30	0.625	48
3	30	4/26	2:30	4/27	1:30	4/27	5:15	6	4/27	5:30	30	0.50	60
								6					
								6					
								6					
								6					
								6					

Person Conducting Percolation Test

Name: JASON KUBIK
Phone: 402-475-2462
Address 105 LOCUST ST P.O. BOX 191
HICKMAN NE 68372

Sum of Percolation Rates: 138
Average of Rates: 46
Rate Used for Calculation: 59 due to >20mpi variance

Soil type (NRCS Maps/Other) 7206 AKSARBEN SILTY CLAY LOAMP

Groundwater Depth > 12 FEET

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date