Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022


C

Permit Number: HS001576

Onsite Wastewater Treatment System

Preliminary Plan Specifications

Draw a plot plan showing onsite system sewer lines, drop of distribution boxes, tank, drainfields, percolation test holes, well, residence, direction of groundwater flow, property lines, and reserve area for replacement onsite system.



Approximate Scale: _____ ft. = _____ grid line/s

A. Onsite System Location

SILVERHAWK ESTATES

Address (no rural route) Lot 2, Block 3 ADDITION City ROCA NE, Zip 68430

B. Proposed Septic Tank/s

Septic Tank Cap._____ gals Tank Material: ☐ Concrete ☐ Plastic ☐ Other_____ ☐ Lagoon(Max. seepage 1/8" per day)

C. Reserve Area for Replacement Onsite System

☒ Drainfield Absorption Area (percolation test required) ☐ Lagoon

D. Drainfield Absorption System

Pending

Percolation Rate_____ (min/inch = mpi) No. of Bedrooms 4 Soil Type_____ Land Slope_____%

☐ Trench ☐ Bed ☐ Non-Standard (engineer designed and NDEQ approved Total Square feet of drainfield_____sq.ft.

Total length of laterals_____ Type of distribution: ☐ Perforated pipe ☐ Half-Round ☒ Chamber ☐ Other

No. of absorption trenches_____ Width_____ No. of drop boxes_____ Distrubtion Box_____

No. of absorption beds_____ Width_____ No of Distribution lines per bed_____

E. Setbacks Check the Boxes Below if the Required Setback has been Satisfied

Distance From	Private Well	Public Well	Surface Water	Gound Water	Pressure Water Lines	Property Lines	Foundations Yours	Foundations Neighbors	All Other Setbacks
Tank (ft)	50 ☐	500 ☐	50 ☐	NA ☐	25 ☐	20 ☐	15 ☐	25 ☐	☐
Field (ft)	100 ☐	500 ☐	50 ☐	4 ☐	30 ☐	20 ☐	30 ☐	40 ☐	☐
Lagoon (ft)	100 ☐	500 ☐	50 ☐	N/A ☐	30 ☐	50 ☐	100 ☐	200 ☐	☐

F. Required Signatures

Home Building Contractor Brad Becker - BECKER CONST., INC. Date 11/2/17

Installer _____ Date 11/20/17

Onsite Form C 12 dg

Nate C. Hartman

From: Diane Van Deun <villageofroca@gmail.com>
Sent: Tuesday, November 21, 2017 10:05 AM
To: Nate C. Hartman
Subject: Approval of Brad Becker's

I approve for Brad Becker. Block 3, Lot 2, Silverhawk.

Diane Van Deun
Village of Roca Clerk/Treasurer
Equal Opportunity Provider and Employer
villageofroca@gmail.com
http://villageofroca.com/
402-421-9577

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3140 N Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001576

System Type: Standard

Situs: No Site Address Specified

Issued: 12/1/2017

Expires: 12/1/2018

Description: SILVERHAWK ESTATES ADDITION, BLOCK 3, Lot 2

Owner: BECKER CONSTRUCTION INC
2549 COUNTY ROAD B
VALPARISO, NE 68065

Shavonna M. Lausterer, MPH, CPH, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Shavonna M. Lausterer, MPH, CPH
Health Director

BRAD BECKER
2549 COUNTY ROAD B
VALPARAISO, NE 68065