Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS001640

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 25855 SW 72 (no rural route) City Hallam, NE Zip 68368

Legal Description N½ E½ 23 7 5

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 01-23-400-004-000

B. Owner

Name Doug Rejcha Signature

Address 25855 SW 72nd City/State/Zip Hallam, Ne, 68368

Home Phone Work Phone

C. Certified Installer

Name: Brian Pribyl Signature

Address 135 E 28th City/State/Zip Crete, Ne, 68333

Work Phone 402-826-0192

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 39

Garbage Grinder? ☐ Yes ☒ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits 4/11/18 OS Date rec'd
Date frwd
Comments
ACTION ☐ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 4/4/18 Amount Paid $405
Received By 4-1-18 Cash/Check No. 6726

White - Health Department Yellow - Engineer Pink - Building & Safety

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number:

Onsite Wastewater Treatment System

Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 25855 SW 72nd (no rural route) City Hallam NE, Zip 68368

Owner Doug Rejcha Address 25855 SW 72nd

Date of Tests 3-21-18 to 3-22-18 Weather: Precipitation none Temperature 50

Percolation Test Data Table

A.	B.	C. D. E. F. Saturation/Swelling Time				G. H. I. J. K. Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					L. M. N. Results		
		Start		End		Start		Initial	End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (in)	Percolation Rates (Min/in = mpi)
1	28	3/21	10AM	3/22	9:30	3/22	9:30	6	3/22	10:00	30min	3/4	40.00 Mpi
2	26	3/21	10AM	3/22	9:30	3/22	9:30	6	3/22	10:00	30min	3/4	40 Mpi
3	29	3/21	10AM	3/22	9:30	3/22	9:30	6	3/22	10:00	30min	7/8	34 Mpi
4	26	3/21	10AM	3/22	9:30	3/22	9:30	6	3/22	10:00	30min	7/8	34 Mpi
								6					
								6					
								6					
								6					

Person Conducting Percolation Test

Name: Brian Pribyl

Phone: 402-826-0192

Address 135 E 25th

Creek, NE 68333

Sum of Percolation Rates: 148

Average of Rates: 37 Mpi

Rate Used for Calculation: 30-40 Mpi

Soil type (NRCS Maps/Other)

Groundwater Depth 30

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number:

Onsite Wastewater Treatment System

Inspection Sheet

N½ Ck

Date 4/11/18 Legal Description 23 / 7 / 5
¼ ¼ Section/Township/Range

Onsite System Location

Address (no rural route) 25855 Sw 72 City

Owner Address

Mark One: ☒ Dwelling ☐ Non-dwelling

☒ New System ☐ Alteration [☐ Tank Only ☐ Trench Only] ☐ Lateral Only

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification):

Drainfield Absorption System:

☐ Lateral ☐ Bed ☐ Non-standard (engineer-designed and NDEQ approved) ☐ Holding Tank ☐ Trench

Total square feet of drainfield 990 Sq. Ft. Tank Size 1,250 gals

Total length of laterals 220 Type of Distribution: ☐ Chamber ☐ Perforated Pipe ☒ Other (describe) E2 Flow

No. of Absorption Laterals 3 Width 4.5 factor - E2 flow No. of Drop Boxes Distribution Box 1

Leveling Method Used Laser

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☐	500 ☐	50 ☐	NA ☐	10 ☐	5 ☐
Field (ft)	100 ☐	500 ☐	50 ☐	4 ☐	25 ☐	5 ☐

Geographical Coordinates to 6 Decimals:

Tank

Lateral #1 Lateral #3

Lateral #2 Lateral #4

N

Comments:

Inspections prior to Final Approval
Initial DC Date 4/11/18


Follow-Up Date

Follow-Up Date

Installation Final Written Approval
By

Date

Field Note Drawing (See Reverse Side):


1,250
70'
70'
80'

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001640

System Type: Standard

Situs: 25855 SW 72ND ST, HALLAM, NE 68368

Issued: 4/11/2018

Expires: 4/11/2019

Description: S23, T7, R5, 6th Principal Meridian, N1/2 E1/2 SE

Owner: REJCHA, DOUGLAS A & LORI A
25705 SW 72 ST
HALLAM, NE 68368

Shavonna M. Lausterer, MPH, CPH, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Shavonna M. Lausterer, MPH, CPH
Health Director

PRIBYL PLUMBING AND HEATING INC
135 E 23RD
CRETE, NE 68333