SCANNED

#5001809

Application to Alter or Repair an Onsite Wastewater Treatment System

The applicant is applying for a permit to: ❐**ALTER** ❐**REPAIR** an existing Onsite Wastewater Treatment System, and agrees to comply with LMC 24.38 or County Resolution 02-0030.

1. **Street Address (No Rural Route):** 6300 SW 37 St.

   Legal Description of Property: Township: 9 Range: 6 Section: 17

   Block 5 Lot 1 SubDivsion Roberts Ironwood Estates Add: _____

   ***Parcel ID** 09 - 17 - 105 - 001 - 000 (i.e. 99-99-999-999-999)

2. **Property use:** ☑ Residential ❐ Commercial ❐ Other use (Describe: _____)
   Number of bedrooms 2 Does the system have a: ❐ Garbage Grinder ❐ Large Capacity Tub

3. **Type of Present Individual Disposal System** ☑ septic system ❐ lagoon ❐ other

4. **Description of proposed alteration or repair:** New Laterals, Old fail Water Softening, 120ft Quick 4 plus 22mpi Perc Rate 2 Bed House

5. **Current Type of Lateral-** _____ **Current Linear Ft. Of Lateral -** ~~Perc Rate 22 min/1"~~

   Current Tank Gallonage- 1000

6. Print Name Matt Taylor Address P.O. Box 23108 Phone: 402 450-6599

   Applicant Signature: _____

Please contact LLCHD for the current permit fee for this application
Fee must be included before the application will be processed. Incomplete information will delay processing.

HEALTH DEPARTMENT USE ONLY

❐Municipal Code 24.38 ❐County Resolution Number 02-30

Date received 4/19/19 REVIEW: ☑ Approved ❐ Disapproved By: _____

Comments (if any): _____

Site visits exact date uncertain
Date 4/9/19 By DC
Date ____/____/____ By _____

Installation final written approval
Date 4/16/19 By _____

Return application to:
Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 "N" Street, Lincoln, NE 68510
Phone: (402) 441-8643

Business Office Use Only
Received: Date: 04/12/19 Amount #225.00 Check No. 1992 Initials _____

Revised 4/8/13

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number: HS001809

Onsite Wastewater Treatment System

Inspection Sheet

Date 4/16/19 Legal Description ¼ ¼ 17 / 9 / 6 Section/Township/Range

Onsite System Location

Address (no rural route) 6300 SW 37th City

Owner Address

Mark One: ☒ Dwelling ☐ Non-dwelling

☐ New System ☒ Alteration [☐ Tank Only ☐ Trench Only] ☐ Lateral Only

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification):

Drainfield Absorption System:

☒ Lateral ☐ Bed ☐ Non-standard (engineer-designed and NDEQ approved) ☐ Holding Tank ☐ Trench

Total square feet of drainfield 600 Sq. Ft. Tank Size 1,000 gals

Total length of laterals 120' Type of Distribution: ☒ Chamber ☐ Perforated Pipe ☐ Other (describe) filter material covered trench = 5'

No. of Absorption Laterals 3 Width 5' No. of Drop Boxes Distribution Box 1

Leveling Method Used Laser

2 bd
22 mpi perc
500 sq. ft. required
120' of lateral installed
chamber dist. in a 5' trench using filter material

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☐	500 ☐	50 ☐	NA ☐	10 ☐	5 ☐
Field (ft)	100 ☐	500 ☐	50 ☐	4 ☐	25 ☐	5 ☐

Geographical Coordinates to 6 Decimals:

Tank

Lateral #1 N/A Lateral #3

Lateral #2 Lateral #4

Comments:

Inspections prior to Final Approval
Initial PJ Date 4/9/19

Follow-Up Date

Follow-Up Date

Installation Final Written Approval
By Doug Powell
Date 4/16/19

Field Note Drawing (See Reverse Side):