Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001895

System Type: Standard

Situs: 18566 VAN DORN ST, LINCOLN, NE 68461

Issued: 9/19/2019

Expires: 9/19/2020

Description: S36, T10, R8, 6th Principal Meridian, LOT 5 SE

Owner: FRANCKE FARMS INC
2500 S 176 ST
WALTON, NE 68461

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Interim Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Interim Health Director

HARPER WELL & PLUMBING INC
PO BOX 15
ADAMS, NE 68301

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS001895

Onsite Wastewater Treatment System Permit Application

Include Form B and C. Submit correct fee with this Application

☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

PLEASE PRINT OR TYPE Existing property

A. Onsite System Location

Address* 18566 (no rural route) VANDORN City Walton, NE Zip 68461

Legal Description 36 10 8 5

1/4	1/4	Section	Township	Range	Subdivison	Addition	Block	Lot

PID 23-36-400-004-000 *Approx. Address (If to be determined)

B. Owner

Name FRANCKE FARMS Signature

Address 2400 176th St City/State/Zip WALTON NE 68461

Home Phone Work Phone

C. Certified Installer

Name: HARPER WELL Signature

Address P.O. BOX 15 AD City/State/Zip ADAMS NE 68301

Work Phone

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☐ Yes ☑ No Total Acres 5.04

Garbage Grinder? ☐ Yes ☑ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process

1. Health Department
Site visits 9/17/19
Comments
Date rec'd 9/17/19
Date frwd 9/19/19
ACTION ☑ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 9-19-19 Amount Paid $430.00
Received By JAG Cash/Check No. 19666

White - Health Department Yellow - Engineer Pink - Building & Safety

Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number: H5001885

Onsite Wastewater Treatment System

Inspection Sheet

Date 9/20/19 Legal Description ¼ ¼ 36/10/8 Lot 5 Section/Township/Range

Onsite System Location

Address (no rural route) 18566 Van Dorn City

Owner Address

Mark One: ☒ Dwelling ☐ Non-dwelling

☒ New System ☐ Alteration [☐ Tank Only ☐ Trench Only] ☐ Lateral Only

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification):

Drainfield Absorption System:

☒ Lateral ☐ Bed ☐ Non-standard (engineer-designed and NDEQ approved) ☐ Holding Tank ☐ Trench

Total square feet of drainfield 1,350 Sq. Ft. Tank Size 1,500 gals

Total length of laterals 300 Type of Distribution: ☐ Chamber ☐ Perforated Pipe ☐ Other (describe)

No. of Absorption Laterals 3 Width 4.5 factor No. of Drop Boxes Distribution Box 1

Leveling Method Used Laser

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☐	500 ☐	50 ☐	NA ☐	10 ☐	5 ☐
Field (ft)	100 ☐	500 ☐	50 ☐	4 ☐	25 ☐	5 ☐

Geographical Coordinates to 6 Decimals:

Tank NA

Lateral #1 Lateral #3

Lateral #2 Lateral #4

Comments:

Inspections prior to Final Approval
Initial D.F Date 9/17/19

Follow-Up Date

Follow-Up Date

Installation Final Written Approval
By Doug Anders
Date 9/20/19

Field Note Drawing (See Reverse Side):