Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS001927

Onsite Wastewater Treatment System Permit Application

Include Form B and C. Submit correct fee with this Application

☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

PLEASE PRINT OR TYPE

A. Onsite System Location

Address* 20311 N 80th Street (no rural route) City Davey, NE Zip 68017

Legal Description Section 15-12-07 Lakewood Hills, Lot 7

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 1915201007000 *Approx. Address (If to be determined)

B. Owner

Name Joshua W Paisley Signature Joshua W Paisley

Address 20311 N 80th City/State/Zip Davey, NE 68017

Home Phone 402-613-7011 Work Phone 402-473-3702

C. Certified Installer

Name: Stuart Way Signature Stuart Way C-1981

Address 1597 CR10 Mead, Ne. 68041 City/State/Zip Mead, Ne. 6804

Work Phone 402-624-3895

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 4 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 3.79

Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Lagoon Design flow in gallons per day 500 gpd

Type of Wastewater ☒ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process

1. Health Department

Site visits Date rec'd ACTION ☐ Approved ☐ Disapproved

Date frwd Signature

Comments

2. Supt. Bldg. Insp. or Village Clerk

Comments Date rec'd ACTION ☐ Approved ☐ Disapproved

Date frwd Signature

3. City or County Engineer

Comments Date rec'd ACTION ☐ Approved ☐ Disapproved

Date frwd Signature

Installation Final Written Approval

By

Date

7206
7207
7585

Business Office Use Only
Date Received 11-05-19 Amount Paid $430.00
Received By JAO Cash/Check No CC2164

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 4/15

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001927

System Type: Standard

Situs: 20311 N 80TH ST, DAVEY, NE 68017

Issued: 11/6/2019

Expires: 11/6/2020

Description: LAKEWOOD HILLS, Lot 7

Owner: PAISLEY, JOSHUA & SARA
1340 CESSNA LN
LINCOLN, NE 68527

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Interim Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Interim Health Director

JOSHUA PAISLEY
20311 N 80TH ST
DAVEY, NE 68017

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

SCANNED

A

Permit Number HS001927

Onsite Wastewater Treatment System Permit Application

Include Form B and C. Submit correct fee with this Application

☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

PLEASE PRINT OR TYPE

A. Onsite System Location

Address* 20311 N 80th Street (no rural route) City Davey, NE Zip 68017

Legal Description Section 15-12-07 Lakewood Hills, Lot 7

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 1915201007000 *Approx. Address (If to be determined)

B. Owner

Name Joshua W Paisley Signature Joshua W Paisley

Address 20311 N 80th City/State/Zip Davey, NE 68017

Home Phone 402-613-7011 Work Phone 402-473-3702

C. Certified Installer

Name: Stuart Way Signature Stuart Way C-1981

Address 1597 CR10 Mead, Ne. 68041 City/State/Zip Mead, Ne. 6804

Work Phone 402-624-3895

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 4 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 3.79

Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Lagoon Design flow in gallons per day 500 gpd

Type of Wastewater ☒ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process

1. Health Department
Site visits 7/29/20
Comments
Date rec'd 11/6/19
Date frwd 11/6/19
ACTION ☒ Approved ☐ Disapproved
Signature

2. Supt. Bldg. Insp. or Village Clerk
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

3. City or County Engineer
Comments
Date rec'd
Date frwd
ACTION ☐ Approved ☐ Disapproved
Signature

Installation Final Written Approval
By Doug Ahrens
Date 9/9/20

7206
7207
7585

Business Office Use Only
Date Received 11-05-19 Amount Paid $430.00
Received By JAO Cash/Check No CC2164

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 4/15

Lincoln-Lancaster County HEALTH DEPARTMENT
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number: HS001927

Onsite Wastewater Treatment System

Inspection Sheet

4

Date 9/9/20 Legal Description Lakewood Hill Lot 7

¼ ¼ Section/Township/Range

Onsite System Location

Address (no rural route) 20311 N 80th City

Owner Address

Mark One: ☒ Dwelling ☐ Non-dwelling

☒ New System ☐ Alteration [☐ Tank Only ☐ Trench Only] ☐ Lateral Only

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification):

Drainfield Absorption System:

☒ Lateral ☐ Bed ☐ Non-standard (engineer-designed and NDEQ approved) ☐ Holding Tank ☐ Trench

Total square feet of drainfield 1,400 Sq. Ft. Tank Size 1,500 gals

Total length of laterals 280' Type of Distribution: ☒ Chamber ☐ Perforated Pipe ☐ Other (describe) – chamber + gravel fill

No. of Absorption Laterals 2 Width 5' – gravel fill used w/ fabric cover 5' wide trench No. of Drop Boxes – Distribution Box 1

Leveling Method Used Laser

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☐	500 ☐	50 ☐	NA ☐	10 ☐	5 ☐
Field (ft)	100 ☐	500 ☐	50 ☐	4 ☐	25 ☐	5 ☐

Geographical Coordinates to 6 Decimals:

Tank N/A

Lateral #1 Lateral #3

Lateral #2 Lateral #4

Comments:

Inspections prior to Final Approval 9/9/20

Initial DC. Date

Follow-Up Date


Follow-Up Date

Installation Final Written Approval By

Date 9/9/20

Field Note Drawing (See Reverse Side):

Updated 4/15


5' wide
gravel fill
fabric cover
140'
1,500
House
140'
North

Nate C. Hartman

From: Josh Paisley <josh@lincolnchrome.com>
Sent: Monday, November 04, 2019 4:38 PM
To: Nate C. Hartman
Subject: Re: Septic for 20311 N 80th ST, Ceresco NE 68017
Attachments: Perc Test.pdf

Good Afternoon Nate,

Thanks again for the time today. The attached document contains the perc test from the property. Please let me know if you have any questions.

Best Regards,
Josh Paisley
402-613-7011

Sent from my Verizon, Samsung Galaxy smartphone

-------- Original message --------
From: Josh Paisley <josh@lincolnchrome.com>
Date: 11/1/19 12:48 PM (GMT-06:00)
To: nhartman@lincoln.ne.gov
Subject: Septic for 20311 N 80th ST, Ceresco NE 68017

Good Afternoon Nate,

Thanks again for the time this morning. It sounds like Bryce would be able to meet me this weekend to pick up this paperwork and fill it out. Is there a place I can pick this up at? I'd be more than happy to come pick it up at the health department if feasible.

If not please mail it on to AWS at:
Audra Wirth
AWS Well Co., Inc.
1597 CO RD 10,
PO BOX 246
Mead, NE 68041

I had turned the rest of my permit applications into Todd at the Building and Safety office and he mentioned this needs to be done before the final approval. With winter sneaking up on us; I am pushing to get everything done on my end; so we can start the build yet in 2019. Please let me know if there is anything else I may need or anything that we can do to keep this moving forward.

Thanks again and have a great weekend,

Josh Paisley, *General Manager, Lincoln Chrome*
Customer Service: 888-966-6609 | 402-473-3702 (D) | 402-613-7011 (M) | 402-475-3674 (F)
600 West E Street | Lincoln, NE 68522 | www.Lincolnchrome.com

CONFIDENTIALITY NOTICE: This e-mail message, including any attachments, is for the sole use of the intended recipient(s) and may contain confidential and privileged information, including information protected by federal and state privacy laws. Any unauthorized review, use, disclosure or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply e-mail and destroy all copies of the original message.

SOIL ABSORPTION TEST DATA REPORT

Location: Precinct _____ Section _____
Township _____ Range _____
1/4 Section _____

Owner: Kevin - Salt Valley Constr.
Address: N. 460th Lot 7

Property Dimensions: _____ acres

Soil Type: Silty Clay ____ Silty Clay Loam ____ Sandy Loam ____ Silty Loam ____ Clay Loam X Sandy Clay ____

Dates of Tests: 3/31/18 to 4/1/18. **Weather:** Precip. True Temp. 40's

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.
		Pre-Saturation Period				Percolation Readings					Results	
		Start		End		Start			End			Water
	Hole	Date	Time	Date	Time	Date	Time	Water	Time	Water	Elapsed	Level
Hole	Depth	(Mo.	(Hr.	(Mo.	(Hr.	(Mo.	(Hr.	Level	(Hr.	Level	Time	Drop
No.	(in.)	Day)	Min.)	Day)	Min.)	Day)	Min.)	(in.)	Min.)	(in.)	(Min.)	(in.)
1	36	3/31	10:00am	3/31	2:00pm	4/1	11:15am	6	11:45am	5¼	30	¾
2	36	3/31	10:00am	3/31	2:00pm	4/1	11:15am	6	11:45am	5½	30	½
3	36	3/31	10:00am	3/31	2:00pm	4/1	11:15am	6	11:45am	5½	30	½


Sum of Water Level Drops (in.) [Column m]: 1.75
Average of Water Level Drops (in.) [Column m]: .58
~~Inches per Minute:~~ 51.72 MPI

PERSON CONDUCTING TEST:
Name: Justyn Peterson
Address: 322 - 238th Rd
Milford, NE 68405
Phone: 402-641-6174
Signature: Justyn

Square Feet of Lateral per Bedroom: 350

SKETCH SHOWING HOLE LOCATION:

N



Official's Signature