Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number
H5001970

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address Ettie Residence (no rural route) City _____, NE Zip _____

Legal Description _____ Wendelin Estates 3rd Addition

1/4	1/4	Section	Township	Range	Subdivison	Addition	Block	Lot
							1	1

PID _____

B. Owner

Name MK Builders Signature _____

Address _____ City/State/Zip _____

Home Phone _____ Work Phone _____

C. Certified Installer

Name: Scott Mueller Signature _____

Address 1945 N 26th Rd City/State/Zip Syracuse, NE 68446

Work Phone 402-430-2946

D. Engineer

☐ Check and complete if engineer designed system P.E. License Number: _____

Designer Name _____ Firm _____ Work Phone _____

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 5 Whirlpool Bathtub? ☒ Yes ☐ No Total Acres _____

Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify _____ Design flow in gallons per day _____

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits _____ Date rec'd _____ ACTION ☐ Approved ☐ Disapproved
Date frwd _____ Signature _____
Comments _____

2. Supt. Bldg. Insp. or Village Clerk
Comments _____ Date rec'd _____ ACTION ☐ Approved ☐ Disapproved
Date frwd _____ Signature _____

3. City or County Engineer
Comments _____ Date rec'd _____ ACTION ☐ Approved ☐ Disapproved
Date frwd _____ Signature _____

Installation Final Written Approval
By _____
Date _____

Business Office Use Only
Date Received 3-23-10 Amount Paid 430.00
Received By TC Cash/Check No. CC 7194

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated 1-13

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS001970

System Type: Lagoon

Situs: No Site Address Specified

Issued: 3/23/2020

Expires: 3/23/2021

Description:

Owner: ETTLE JOSEPH R & RACHEL M
8823 LINCOLN ST
LINCOLN, NE 68526

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Interim Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Interim Health Director

SCOTT MUELLER
1345 N 26 RD
SYRACUSE, NE 68446

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

SCANNED

A

Permit Number
HS001970

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☐ Septic System ☒ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address Ethe Residence (no rural route) City _____, NE Zip _____

Legal Description _____ Wendelin Estates 3rd Addition

1/4	1/4	Section	Township	Range	Subdivison	Addition	Block	Lot
							1	1

PID 0225308001/00

B. Owner

Name MK Builders Signature _____

Address _____ City/State/Zip _____

Home Phone _____ Work Phone _____

C. Certified Installer

Name Scott Mueller Signature _____

Address 1915 N 26th Rd City/State/Zip Syracuse, NE 68446

Work Phone 402-430-2946

D. Engineer

☐ Check and complete if engineer designed system P.E. License Number: _____

Designer Name _____ Firm _____ Work Phone _____

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☒ Yes ☐ No Total Acres 5.97

Garbage Grinder? ☒ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify _____ Design flow in gallons per day _____

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits 12/21/20
Comments _____
Date rec'd 3/23/20
Date frwd 3/23/20
ACTION ☒ Approved ☐ Disapproved
Signature _____

2. Supt. Bldg. Insp. or Village Clerk
Comments _____
Date rec'd _____
Date frwd _____
ACTION ☐ Approved ☐ Disapproved
Signature _____

3. City or County Engineer
Comments _____
Date rec'd _____
Date frwd _____
ACTION ☐ Approved ☐ Disapproved
Signature _____

Installation Final Written Approval
By Doug Ahlm
Date 12/22/20

Business Office Use Only
Date Received 3-23-20 Amount Paid 430.00
Received By JC Cash/Check No. CC 7194

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated 1-13

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 6

Permit Number: HS001970

Onsite Wastewater Treatment System-Lagoon

Inspection Sheet

Date 12/22/20 Legal Description Wendelin Estates 3rd – Blk 1, Lot 1

¼ ¼ Section/Township/Range

Onsite System Location

Address (no rural route) 18375 Willemma City _____

Owner _____ Address _____

Mark One: ☒ Dwelling ☐ Non-dwelling

☒ New System ☐ Repair

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification): _____

Lagoon constructed so not to receive surface water	Yes ✓ No ___
Lagoon floor is level	Yes ✓ No ___
Lagoon is equipped with a depth gage/concrete slab	Yes ✓ No ___
Influent line is at least 4 inches and slopes no less than 1/8 inch	Yes ✓ No ___
Clean outs located every 75 feet and one located 1 foot about highest water level	Yes ✓ No ___
Inside slope not steeper than three horizontal to one vertical	Yes ✓ No ___
Minimum width of the top of the dike shall be 4 feet	Yes ✓ No ___
Fence installed +50' rectangular	Yes ✓ No ___

Top of the Dike 20' Bottom of Lagoon [redacted]' Design Flow 300

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Surface Water distance from Water Mark	Private Drinking Water Wells	Public Drinking Water Supply Wells		All Other Water Wells	Property Lines	Trees and Brush	Neighbor's Foundation		All Other Setbacks
50 ft ☐	100 ft ☐	Non-Community	100ft ☐	100ft ☐	50ft ☐	50ft ☐	Class 1	100ft ☐	☐
		Community	* ☐				Class 2	200ft ☐	
							Class 3	100ft ☐	

*Evaluated by a professional engineer for potential impact on the well and submitted to Dept. for approval if less than 1000ft.

Geographical Coordinates to 6 Decimals: N/A

Dike North side

Comments:

Inspections prior to Final Approval
Initial DS Date 12/24/20

Follow-Up _____ Date _____

Follow-Up _____ Date _____

Installation Final Written Approval
By Doug Rudd

Date 12/22/20