Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS00 2051

Existing Home

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 7225 W McKelvie Rd (no rural route) City Malcolm, NE Zip 68402

Legal Description NE (1/4) NE (1/4) 26 (Section) 11N (Township) 5E (Range) _____ (Subdivison) _____ (Addition) _____ (Block) 27 (Lot)

PID 05-26-200-011-000

B. Owner

Name Brent Barta Signature _____

Address 7225 W McKelvie Rd City/State/Zip Malcolm, NE 68402

Home Phone 402-480-0683 Work Phone _____

C. Certified Installer

Name: Lloyd Jakoubek, Raymond Contracting Inc Signature _____

Address 13800 NW 70th St City/State/Zip Raymond, NE 68428

Work Phone 402-890-6009 or 402-783-2663

D. Engineer ☐ Check and complete if engineer designed system P.E. License Number: _____

Designer Name _____ Firm _____ Work Phone _____

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 5 Whirlpool Bathtub? ☑ Yes ☐ No Total Acres 5

Garbage Grinder? ☑ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify _____ Design flow in gallons per day _____

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits _____ Date rec'd _____ Date frwd _____
Comments _____
ACTION ☐ Approved ☐ Disapproved
Signature _____

2. Supt. Bldg. Insp. or Village Clerk
Comments _____ Date rec'd _____ Date frwd _____
ACTION ☐ Approved ☐ Disapproved
Signature _____

3. City or County Engineer
Comments _____ Date rec'd _____ Date frwd _____
ACTION ☐ Approved ☐ Disapproved
Signature _____

Installation Final Written Approval
By _____
Date _____

Business Office Use Only
Date Received 7-10-20 Amount Paid $430.00
Received By BM Cash/Check No. 9017

White - Health Department Yellow - Engineer Pink - Building & Safety

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number:

Onsite Wastewater Treatment System

Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 7225 W McKelvie Rd (no rural route) City Raymond NE, Zip 68402

Owner Matthew Bratrsovsky Address 7225 W McKelvie Rd, Malcolm, NE 68402

Date of Tests 6/5/19 to 6/6/19 Weather: Precipitation 0 Temperature 83°

Percolation Test Data Table

A.	B.	C. D. E. F. Saturation/Swelling Time				G. H. I. J. K. Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					L. M. N. Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Initial Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (in)	Percolation Rates (Min/in = mpi)
1	24	6/5	1:00	6/5	5:00p	6/6	5:00p	6	6/6	5:30p	30	2-5/8	11
2	20	"	"	"	"	"	"	6	"	"	"	3-3/8	9
3	30	"	"	"	"	"	"	6	"	"	"	1-3/8	22
4	23	"	"	"	"	"	"	6	"	"	"	11/16	44
								6					
								6					
								6					
								6					

Person Conducting Percolation Test

Name: Terri L Jakoubek, Raymond Contracting, Inc.

Phone: 402-783-2663 or 402-890-6009

Address 13800 NW 70th St

Raymond, NE 68428 Cert #1198

Sum of Percolation Rates: 86

Average of Rates: 22

Rate Used for Calculation: 44 (20 mpi variance)

Soil type (NRCS Maps/Other) Silty Clay Loam with some Sand

Groundwater Depth >8'

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022


C

Permit Number:

Onsite Wastewater Treatment System

Preliminary Plan Specifications

Draw a plot plan showing onsite system sewer lines, drop of distribution boxes, tank, drainfields, percolation test holes, well, residence, direction of groundwater flow, property lines, and reserve area for replacement onsite system.



Approximate Scale: _____ft. = _____ grid line/s

A. Onsite System Location

Address (no rural route) 7225 W McKelvie Rd City Malcolm NE, Zip 68402

B. Proposed Septic Tank/s

Septic Tank Cap. 2000 gals Tank Material: ☒ Concrete ☐ Plastic ☐ Other_____ ☐ Lagoon(Max. seepage 1/8" per day)

C. Reserve Area for Replacement Onsite System

☐ Drainfield Absorption Area (percolation test required) ☒ Lagoon

D. Drainfield Absorption System

Percolation Rate 44 (min/inch = mpi) No. of Bedrooms 5 Soil Type Aksarben SCL Land Slope_____%

☒ Trench ☐ Bed ☐ Non-Standard (engineer designed and NDEQ approved Total Square feet of drainfield 1,665 sq.ft.

Total length of laterals 370 Type of distribution: ☐ Perforated pipe ☐ Half-Round ☐ Chamber ☒ Other EZFlow 1203H

No. of absorption trenches 4 Width 40" No. of drop boxes 1 Distrubtion Box_____

No. of absorption beds_____ Width_____ No of Distribution lines per bed_____

E. Setbacks Check the Boxes Below if the Required Setback has been Satisfied

Distance From	Private Well	Public Well	Surface Water	Gound Water	Pressure Water Lines	Property Lines	Foundations Yours	Foundations Neighbors	All Other Setbacks
Tank (ft)	50 ☒	500 ☒	50 ☒	NA ☒	25 ☒	20 ☒	15 ☒	25 ☒	☒
Field (ft)	100 ☒	500 ☒	50 ☒	4 ☒	30 ☒	20 ☒	30 ☒	40 ☒	☒
Lagoon (ft)	100 ☐	500 ☐	50 ☐	N/A ☐	30 ☐	50 ☐	100 ☐	200 ☐	☐

F. Required Signatures


Home Building Contractor Existing Home Date _____

Installer [signature] Date 7/9/20

7225 W McKelvie Rd, Malcolm, NE 68402

GIS Viewer
CITY OF LINCOLN - LANCASTER COUNTY, NE

City of Lincoln\Lancaster County GIS Map



Printed: 6/7/2019

Map Scale
1: 1,128

DISCLAIMER: The information is presented on a best-efforts basis, and should not be relied upon for making financial, survey, legal or other commitments. If you have questions or comments regarding the data displayed on this map, please email assessor@lancaster.ne.gov and you will be directed to the appropriate department.

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS002051

System Type: Standard

Situs: No Site Address Specified

Issued: 7/13/2020

Expires: 7/13/2021

Description: S26, T11, R5, 6th Principal Meridian, LOT 27 NE

Owner: BARTA, BRENT J & KATIE M
7225 W MCKELVIE RD
MALCOLM, NE 68402

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Interim Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Interim Health Director

RAYMOND CONTRACTING
13800 NW 70TH ST
RAYMOND, NE 68428

SCANNED

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS00 2051

Existing Home

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 7225 W McKelvie Rd (no rural route) City Malcolm, NE Zip 68402

Legal Description NE 1/4 NE 1/4 Section 26 Township 11N Range 5E Subdivison ____ Addition ____ Block ____ Lot 27

PID 05-26-200-011-000

B. Owner

Name Brent Barta Signature ____

Address 7225 W McKelvie Rd City/State/Zip Malcolm, NE 68402

Home Phone 402-480-0683 Work Phone ____

C. Certified Installer

Name: Lloyd Jakoubek, Raymond Contracting Inc Signature ____

Address 13800 NW 70th St City/State/Zip Raymond, NE 68428

Work Phone 402-890-6009 or 402-783-2663

D. Engineer

☐ Check and complete if engineer designed system P.E. License Number: ____

Designer Name ____ Firm ____ Work Phone ____

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 5 Whirlpool Bathtub? ☑ Yes ☐ No Garbage Grinder? ☑ Yes ☐ No Total Acres 5

☐ Commercial Establishment/Other Facility Specify ____ Design flow in gallons per day ____

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☒ County Resolution No. 02-30

1. Health Department
Site visits ____
Comments ____
Date rec'd 3/13/20
Date frwd 3/17/20
ACTION ☑ Approved ☐ Disapproved
Signature ____

2. Supt. Bldg. Insp. or Village Clerk
Comments ____
Date rec'd ____
Date frwd ____
ACTION ☐ Approved ☐ Disapproved
Signature ____

3. City or County Engineer
Comments ____
Date rec'd ____
Date frwd ____
ACTION ☐ Approved ☐ Disapproved
Signature ____

Installation Final Written Approval
By ____
Date 8/5/20

Business Office Use Only
Date Received 7-10-20 Amount Paid $430.00
Received By ____ Cash/Check No. 40117

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13