Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
ALTERATION PERMIT
No. HS002063

System Type: Standard

Situs: No Site Address Specified

Description: VIEW POINTE NORTH, Lot 10

Issued: 8/4/2020

Expires: 8/4/2021

Owner: ENGEL, JOSHUA W & BRIGETTE
12401 EMMAWALTER RD
LINCOLN, NE 68517

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Interim Health Director

Dear Applicant:

The above document is your permit to alter an existing On-site Waste Water System at the location listed. Please contact this office once the alteration is complete to obtain final approval before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Interim Health Director

STEVEN LEWIS
3300 N 71ST ST
LINCOLN, NE 68507

SCANNED

Application to Alter or Repair an Onsite Wastewater Treatment System

HS002063

The applicant is applying for a permit to: ☒ **ALTER** ☐ **REPAIR** an existing Onsite Wastewater Treatment System, and agrees to comply with LMC 24.38 or County Resolution 02-0030.

1. **Street Address (No Rural Route):** 12401 Emma Walten Rd.

   Legal Description of Property: Township: 11 Range: 7 Section: 9

   Block ____ Lot 10 SubDivsion View Pointe North Add: ____

   ***Parcel ID** 18-09-401-010-000 (i.e. 99-99-999-999-999)

2. **Property use:** ☒ Residential ☐ Commercial ☐ Other use (Describe: ____)

   Number of bedrooms 5 Does the system have a: ☑ Garbage Grinder ☑ Large Capacity Tub

3. **Type of Present Individual Disposal System** ☒ septic system ☐ lagoon ☐ other

4. **Description of proposed alteration or repair:** Add 300' of EZ Flow to help with water usage in home

5. **Current Type of Lateral** Plastic ½ Rands **Current Linear Ft. Of Lateral** - 350

   Current Tank Gallonage 1750

6. Print Name Steven C Lewis Address 3300 N 71st Phone: 402 432 1082

   Applicant Signature: ____

Please contact LLCHD for the current permit fee for this application

Fee must be included before the application will be processed. Incomplete information will delay processing.

HEALTH DEPARTMENT USE ONLY

☐ Municipal Code 24.38 ☐ County Resolution Number 02-30

Date received 8/4/20 REVIEW: ☒ Approved ☐ Disapproved By: ____

Comments (if any): * needs to utilize a mechanism to regulate on 500 linear ft usage at one time

Site visits

Date ____/____/____ By ____

Date ____/____/____ By N/A

Installation final written approval

Date 6/18/21 By ____

Return application to: Lincoln-Lancaster County Health Department
Environmental Public Health Division
3131 "N" Street, Lincoln, NE 68510
Phone: (402) 441-8643

Business Office Use Only

Received: Date: 8/03/20 Amount $230 Check No. 1007 Initials ____

Revised 2/18

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

SCANNED

Exhibit 4

D

Permit Number:

Onsite Wastewater Treatment System
As-Built Description and Drawing

Type of Onsite Wastewater System: ☐ Lagoon (Skip to Back Page) ☒ Subsurface Septic ☐ Mound

Onsite Wastewater System Location

Address or Legal Description or Parcel Identification Number (PID) 180940101000

Owner: Josh Engel Address 12401 Emmawalter Rd

A. Wastewater Piping

1. Material: Sch 40 PVC Diameter: 4 in.
2. Distance between dwelling and septic tank: 53 ft.

B. Septic Tank

1. Material Concrete
2. Capacity: 1750
3. Depth to top of tank, below unfinished grade: 24 in.
4. Distance to:
   Well over 100 ft.
   Pressure line NA ft
   Property Line over 100 ft.
   Foundation 53 ft.

C Distribution Box or Drop Box

Distance **and** Direction from septic tank: 10 ft. South

10 ft

D. Drainfield/Absorption Field

☒ Trench ☐ Bed

1. Type: ☐ Perforated Pipe ☐ Chamberless ☒ Other
   Material brand and inside width of Chamberless:
   Infiltrator EZ Flow
2. Number of Laterals: 2 - New 4 total
3. Length of each lateral (linear): ft. 150 ft. 150 New ft. 150 ft. 150 existing Plastic Chambers
4. Drainfield size: 2437.5 sq. ft. (1050 Reg 12)
5. Distance to:
   Well over 100 ft.
   Pressure line NA ft.
   Property line over 100 ft.
   Depth of Groundwater over 12 ft

Was the Onsite Wastewater System covered prior to LLCHD inspection? ☒ Yes ☐ No

If Yes, the Certified Professional must sign below for final approval:

I swear and affirm that the system complies with Lincoln Municipal Code (LMC) 24.38 and/or County Resolution R-13-0062 requirements and that the information and documentation submitted are true and accurate.

Certified Professional Signature: _____ Date: 3 Aug 2020

Complete As-Built drawing on the back of this form.