HS002263

Application to Alter or Repair an Onsite Wastewater Treatment System

The applicant is applying for a permit to: ☑ALTER ☐REPAIR an existing Onsite Wastewater Treatment System, and agrees to comply with LMC 24.38 or County Resolution 02-0030.

1. **Street Address (No Rural Route):** 11300 N 14th St, Raymond, NE 68428

   Legal Description of Property: Township: 11N Range: 6E Section: 13 SW NW

   Block _____ Lot 7 SubDivsion _____ Add: _____

   ***Parcel ID** 12 . 13 . 100 . 005 . 000 (i.e. 99-99-999-999-999)

2. **Property use:** ☑ Residential ☐ Commercial ☐ Other use (Describe: _____)
   Number of bedrooms 2 Does the system have a: ☐ Garbage Grinder ☐Large Capacity Tub

3. **Type of Present Individual Disposal System** ☑ septic system ☐ lagoon ☐ other

4. **Description of proposed alteration or repair:** Replace failing drainfield with 200' of EZFlow (900sqft). Perc rate of 53 mpi, results included.

5. **Current Type of Lateral-** Unknown **Current Linear Ft. Of Lateral -** at least 100'

   Current Tank Gallonage- 1,000

6. Print Name Todd Munford Address 11300 N 14th St. Raymond, NE 68428 Phone: 402-560-6051

Applicant Signature: Todd Munford Nicole L. Jakubek Raymond Contracting

Please contact LLCHD for the current permit fee for this application

Fee must be included before the application will be processed. Incomplete information will delay processing.

HEALTH DEPARTMENT USE ONLY

☐Municipal Code 24.38 ☐County Resolution Number 02-30

Date received ____/____/____ REVIEW: ☐ Approved ☐ Disapproved By: _____

Comments (if any): _____

Site visits
Date ____/____/____ By _____
Date ____/____/____ By _____

Installation final written approval
Date ____/____/____ By _____

Return application to:

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 "N" Street, Lincoln, NE 68510
Phone: (402) 441-8643

Business Office Use Only

Received: Date: ____/____/____ Amount _____ Check No. _____ Initials _____

Revised 4/8/13

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3131 "O" Street • Lincoln, NE 68510-1514
Phone: 402-441-8643

B

Permit Number:

Onsite Wastewater Treatment System
Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 11300 N 14th St (no rural route) City Raymond NE, Zip 68428

Owner Todd Munford Address 11300 N 14th St, Raymond, NE 68428

Date of Tests 6/30/21 to 7/1/21 Weather: Precipitation 0 Temperature 86°

Percolation Test Data Table

A.	B.	C. D. E. F. Saturation/Swelling Time				G. H. I. J. K. Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					L. M. N. Results		
		Start		End		Start		Initial	End		Elapsed	Water	
Hole No.	Hole Depth(in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Time Interval	Level Drop(in)	Percolation Rates (Min/in = mpi)
1	25	6/30	2:00p	7/1	11:30a	7/1	3:00p	6	7/1	3:30p	30	9/16	53
2	21	"	"	"	"	"	"	6	"	"	"	1-1/4	24
3	23	"	"	"	"	"	"	6	"	"	"	1-5/8	18
4	21	"	"	"	"	"	"	6	"	"	"	5/8	48
5								6					
6								6					
7								6					
8								6					

Person Conducting Percolation Test

Name: Terri Jakoubek

Phone: 402-783-2663 or 402-890-3870

Address 13800 NW 70th St, Raymond, NE 68428

Sum of Percolation Rates: 143

Average of Rates: 36

Rate Used for Calculation: 53 (20 mpi variance)

Soil type (NRCS Maps/Other) Pawnee Clay Loam (loamy)

Groundwater Depth >8'

DO NOT WRITE BELOW THIS LINE

Reviewing Action


Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date

Todd Munford 402-560-6051 11300 N 14th St, Raymond, NE 68428

GIS Viewer
CITY OF LINCOLN / LANCASTER COUNTY, NE

City of Lincoln/Lancaster County GIS Map



Printed: 7/12/2021

1: 1,128

Disclaimer: The information is presented on a best efforts basis, and should not be relied upon for making financial, survey, legal or other commitments. If you have questions or comments regarding the data displayed on this map, please email assessor@lancaster.ne.gov and you will be directed to the appropriate department.

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
ALTERATION PERMIT
No. HS002263

System Type: Standard

Situs: No Site Address Specified

Issued: 7/20/2021

Expires: 7/20/2022

Description: S13, T11, R6, 6th Principal Meridian, LOT 7 SW NW

Owner: MUNFORD, TODD M & SHARON L
11300 N 14 ST
RAYMOND, NE 68428

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Interim Health Director

Dear Applicant:

The above document is your permit to alter an existing On-site Waste Water System at the location listed. Please contact this office once the alteration is complete to obtain final approval before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Health Director

RAYMOND CONTRACTING INC
13800 NW 70TH ST
RAYMOND, NE 68428

SCANNED

HS 00 2263

Application to Alter or Repair an Onsite Wastewater Treatment System

The applicant is applying for a permit to: ☑ **ALTER** ☐ **REPAIR** an existing Onsite Wastewater Treatment System, and agrees to comply with LMC 24.38 or County Resolution 02-0030.

1. **Street Address (No Rural Route):** 11300 N 14th St, Raymond, NE 68428

   Legal Description of Property: Township: 11N Range: 6E Section: 13 SW NW

   Block _____ Lot 7 SubDivsion _____ Add: _____

   ***Parcel ID** 12 .13 .100 .005 .000 (i.e. 99-99-999-999-999)

2. **Property use:** ☑ Residential ☐ Commercial ☐ Other use (Describe: _____)
   Number of bedrooms 2 Does the system have a: ☐ Garbage Grinder ☐ Large Capacity Tub

3. **Type of Present Individual Disposal System** ☑ septic system ☐ lagoon ☐ other

4. **Description of proposed alteration or repair:** Replace failing drainfield with 200' of EZFlow (900sqft). Perc rate of 53 mpi, results included.

5. **Current Type of Lateral-** Unknown **Current Linear Ft. Of Lateral -** at least 100'

   Current Tank Gallonage- 1,000

6. Print Name Todd Munford Address 11300 N 14th St, Raymond, NE 68428 Phone: 402-560-6051

   Applicant Signature: Todd Munford Nicole L. Jakeubek Raymond Contracting

Please contact LLCHD for the current permit fee for this application

Fee must be included before the application will be processed. Incomplete information will delay processing.

HEALTH DEPARTMENT USE ONLY

☐ Municipal Code 24.38 ☒ County Resolution Number 02-30

Date received 2/20/21 REVIEW: ☒ Approved ☐ Disapproved By: _____

Comments (if any): _____

Site visits
Date 3/16/21 By DH
Date ____/____/____ By _____

Installation final written approval
Date 5/16/21 By _____

Return application to:

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 "N" Street, Lincoln, NE 68510
Phone: (402) 441-8643

Business Office Use Only

Received: Date: ____/____/____ Amount _____ Check No. _____ Initials _____

Revised 4/8/13