Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS002286

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☒ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 11125 Rokeby Rd City Bennet, NE Zip 68526
(no rural route)

Legal Description S36 T9 R7 33
1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 16-36-200-002-000

B. Owner

Name Hussain Al-Sulltan Signature

Address 11125 Rokeby Rd City/State/Zip

Home Phone (402)890-2887 Work Phone

C. Certified Installer

Name: Steven Lewis Signature

Address 3300 N 71st Street City/State/Zip Lincoln NE, 68507

Work Phone (402)432-1082

D. Engineer

☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☒ Residential Dwelling Number of Bedrooms 4 Whirlpool Bathtub? ☐ Yes ☒ No Total Acres 9
Garbage Grinder? ☐ Yes ☒ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day 500

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department ACTION ☐ Approved ☐ Disapproved
Site visits Date rec'd Signature
Date frwd
Comments

2. Supt. Bldg. Insp. or Village Clerk ACTION ☐ Approved ☐ Disapproved
Comments Date rec'd Signature
Date frwd

3. City or County Engineer ACTION ☐ Approved ☐ Disapproved
Comments Date rec'd Signature
Date frwd

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 9-9-21 Amount Paid $450
Received By JAO Cash/Check No 004909

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number:

Onsite Wastewater Treatment System

Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 11125 Rokeby Rd (no rural route) City Bennet NE, Zip 68526

Owner Hussain Al-Sultan Address

Date of Tests 9/8 to 9/9 Weather: Precipitation None Temperature 87*

Percolation Test Data Table

A.	B.	C.	D.	E.	F.	G.	H.	I.	J.	K.	L.	M.	N.
		Saturation/Swelling Time				Water Level Drop: Last 30 mins of 4 hr or last 10 mins of 1 hr					Results		
		Start		End		Start		Initial	End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (in)	Percolation Rates (Min/in = mpi)
1	36	9/8	1520	9/9	1700	9/9	1700	6	9/9	1730	30	1	30
2	36	9/8	1520	9/9	1700	9/9	1700	6	9/9	1730	30	1.5	20
3	36	9/8	1520	9/9	1700	9/9	1700	6	9/9	1730	30	1	30
								6					
								6					
								6					
								6					
								6					

Person Conducting Percolation Test

Name: Steven Lewis
Phone: 402 432 1082
Address 3300 N 71st St.
Lincoln NE 68507

Sum of Percolation Rates: 80
Average of Rates: 26.666
Rate Used for Calculation: 20-30

Soil type (NRCS Maps/Other) 7211 - Nordaway
Groundwater Depth >10'

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date

Doug R. Smith

From: Nebraska Septic <nebraskaseptic@gmail.com>
Sent: Thursday, September 9, 2021 9:46 AM
To: Doug R. Smith
Subject: 210901 Permit Request
Attachments: A and B Sheet.pdf

Good Morning Doug,

I am trying out a new way to fill out pdf.'s let me know if you prefer my chicken scratch instead. I think I still have a little bit of time to have Jannet still call me to pay the fees before she leaves.

Thank You!

Steven C Lewis
Master Installer/ Inspector OSWWTS

Nebraska
SEPTIC
(402)432-1082

www.NebraskaSeptic.com

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS002286

System Type: Standard

Situs: No Site Address Specified

Issued: 9/17/2021

Expires: 9/17/2022

Description: S36, T9, R7, 6th Principal Meridian, LOT 33 NE

Owner: AL-SULTAN, HUSSAIN
2427 S 10 ST
LINCOLN, NE 68502

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Health Director

STEVEN LEWIS
3300 N 71ST ST
LINCOLN, NE 68507

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCT/ INSTALL EXTENSION PERMIT
No. HS002286

System Type: Standard

Situs: No Site Address Specified

Issued: 9/18/2022

Expires: 3/17/2023

Description: S36, T9, R7, 6th Principal Meridian, LOT 33 NE

Owner: AL-SULTAN, HUSSAIN
2427 S 10 ST
LINCOLN, NE 68502

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Health Director

STEVEN LEWIS
3300 N 71ST ST
LINCOLN, NE 68507

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCT/ INSTALL EXTENSION PERMIT
No. HS002286

System Type: Standard

Situs: No Site Address Specified

Issued: 3/18/2023

Expires: 9/17/2023

Description: S36, T9, R7, 6th Principal Meridian, LOT 33 NE

Owner: AL-SULTAN, HUSSAIN
2427 S 10 ST
LINCOLN, NE 68502

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Health Director

STEVEN LEWIS
3300 N 71ST ST
LINCOLN, NE 68507