Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS002415

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 9005 Whitstruck Rd. (no rural route) City Bennet, NE Zip 68430

Legal Description S14 T8 R7 37

1/4 | 1/4 | Section | Township | Range | Subdivison | Addition | Block | Lot

PID 15-14-200-011-000

B. Owner

Name John Schleich Signature

Address City/State/Zip

Home Phone Work Phone

C. Certified Installer

Name: Steven C Lewis Signature

Address 3300 N 71st. Street City/State/Zip Lincoln NE, 68507

Work Phone 402 432 1082

D. Engineer ☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 4 Whirlpool Bathtub? ☐ Yes ☐ No Total Acres 20.38

Garbage Grinder? ☐ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day 500

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department

Site visits Date rec'd **ACTION** ☐ Approved ☐ Disapproved

Date frwd Signature

Comments

2. Supt. Bldg. Insp. or Village Clerk

Comments Date rec'd **ACTION** ☐ Approved ☐ Disapproved

Date frwd Signature

3. City or County Engineer

Comments Date rec'd **ACTION** ☐ Approved ☐ Disapproved

Date frwd Signature

Installation Final Written Approval

By

Date

Business Office Use Only

Date Received 6-27-22 Amount Paid $450.00

Received By Cash/Check No. 6590

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number:

Onsite Wastewater Treatment System

Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 9005 Whitstruck Rd (no rural route) City Bennet NE NE, Zip 68430

Owner John Schleich Address 8644 Executive Woods Dr. Lincoln NE, 68512

Date of Tests 6/3/22 to 6/4/22 Weather: Precipitation <.1 Temperature 69*

Percolation Test Data Table

A.	B.	C. D. E. F. Saturation/Swelling Time				G. H. I. J. K. Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					L.	M. N. Results	
		Start		End		Start			End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Initial Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (in)	Percolation Rates (Min/in = mpi)
1	36	6/3	11/30	6/4	11/30	6/4	11/30	6	6/4	12/00	30	3/4	40
2	"	"	"	"	"	"	"	6	"	"	"	3/4	40
3	"	"	"	"	"	"	"	6	"	"	"	1/2	60
4	"	"	"	"	"	"	"	6	"	"	"	1/2	60
	"							6					
								6					
								6					
								6					

Person Conducting Percolation Test

Name: Steven C Lewis
Phone: 402-432-1082
Address 3300 N. 7.1st Street
Lincoln NE, 68507

Sum of Percolation Rates: 200
Average of Rates: 50
Rate Used for Calculation: 50 MPI

Soil type (NRCS Maps/Other)

Groundwater Depth

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date

Janet O'Neal

From: Nate C. Hartman
Sent: Tuesday, June 7, 2022 8:27 AM
To: Janet O'Neal
Subject: FW: 9005 Whitstruck Rd. New Installation Request
Attachments: 220508 A Sheet.pdf; B Sheet.pdf

Please make a file for this...

Thanks!

Nate Hartman REHS, QCIS, QPSWPPP
Senior Environmental Health Specialist
3131 'O' Street, Lincoln, NE 68510
O: 402-441-8643 F: 402-441-3890

From: Nebraska Septic <nebraskaseptic@gmail.com>
Sent: Monday, June 6, 2022 9:18 PM
To: Nate C. Hartman <nhartman@lincoln.ne.gov>
Cc: Doug R. Smith <drsmith@lincoln.ne.gov>
Subject: 9005 Whitstruck Rd. New Installation Request

Good Morning!

I have attached the A & B sheet for the alteration. I will be collapsing the existing tank and installing a 1500 g tank as well as 220' EZ Flow, to the north of their current system. Please give me a call if you have any questions, I do not yet know when I will be able to get to this one.

Thank You!

Steven C Lewis
Master Installer/ Inspector OSWWTS

Nebraska
SEPTIC
(402)432-1082

www.NebraskaSeptic.com

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS002415

System Type: Standard

Situs: No Site Address Specified

Issued: 6/9/2022

Expires: 6/9/2023

Description: S14, T8, R7, 6th Principal Meridian, LOT 37 NE

Owner: AKS REVOCABLE TRUST
8644 EXECUTIVE WOODS DR
LINCOLN, NE 68512

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Health Director

STEVEN LEWIS
3300 N 71ST ST
LINCOLN, NE 68507

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

SCANNED

A

Permit Number HS002415

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE Existing Home

A. Onsite System Location

Address 9005 Whitstruck Rd. (no rural route) City Bennet, NE Zip 68430

Legal Description S14 T8 R7 37

1/4	1/4	Section	Township	Range	Subdivison	Addition	Block	Lot

PID 15-14-200-011-000

B. Owner

Name John Schleich Signature

Address City/State/Zip

Home Phone Work Phone

C. Certified Installer

Name: Steven C Lewis Signature

Address 3300 N 21st. Street City/State/Zip Lincoln NE, 68507

Work Phone 402 432 1082

D. Engineer ☐ Check and complete if engineer designed system P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 4 Whirlpool Bathtub? ☐ Yes ☐ No Total Acres 20.38

Garbage Grinder? ☐ Yes ☐ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day 500

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☒ County Resolution No. 02-30

1. Health Department

Site visits 6/27/22 Date rec'd 6/9/22 ACTION ☒ Approved ☐ Disapproved

Date frwd 6/9/22 Signature

Comments

2. Supt. Bldg. Insp. or Village Clerk

Comments Date rec'd ACTION ☐ Approved ☐ Disapproved

Date frwd Signature

3. City or County Engineer

Comments Date rec'd ACTION ☐ Approved ☐ Disapproved

Date frwd Signature

Installation Final Written Approval

By Doug Theel

Date 6/29/22

Business Office Use Only

Date Received 6-27-22 Amount Paid $450.00

Received By Cash/Check No. 25909

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Exhibit 5

Permit Number: HS002415

Onsite Wastewater Treatment System

Inspection Sheet

Date 6/29/22 Legal Description _____

¼ ¼ Section/Township/Range

Onsite System Location

Address (no rural route) 9005 Wittstruck City _____

Owner _____ Address _____

Mark One: ☑ Dwelling ☐ Non-dwelling

☑ New System ☐ Alteration [☐ Tank Only ☐ Trench Only] ☐ Lateral Only

☐ Temporary modification (Describe problem causing discharge and reason for temporary modification): _____

_____

Drainfield Absorption System:

☐ Lateral ☐ Bed ☐ Non-standard (engineer-designed and NDEQ approved) ☐ Holding Tank ☐ Trench

Total square feet of drainfield 1,350 Sq. Ft. Tank Size 1,500 gals

Total length of laterals 300' Type of Distribution: ☐ Chamber ☐ Perforated Pipe ☑ Other (describe) E-Z Flow

No. of Absorption Laterals 3 Width 4.5 Factor No. of Drop Boxes _____ Distribution Box 1

Leveling Method Used Laser

Setbacks (Check the Boxes Below if the Required Setback has been Satisfied):

Distance From	Private Well	Public Well	Surface Water	Ground water	Pressure Water Lines	Property Lines
Tank (ft)	50 ☐	500 ☐	50 ☐	NA ☐	10 ☐	5 ☐
Field (ft)	100 ☐	500 ☐	50 ☐	4 ☐	25 ☐	5 ☑

Geographical Coordinates to 6 Decimals:

Tank _____ NA

Lateral #1 _____ Lateral #3 _____

Lateral #2 _____ Lateral #4 _____

Comments:

Inspections prior to Final Approval
Initial DS Date 6/27/22

Follow-Up _____ Date _____

Follow-Up _____ Date _____

Installation Final Written Approval
By Doug Mark

Date 6/29/22

Field Note Drawing (See Reverse Side):

Updated 4/15

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

D Exhibit 4

Permit Number H5002415

Onsite Wastewater Treatment System
As-Built Description and Drawing

Type of Onsite Wastewater System: ☐ Lagoon (Skip to Back Page) ☑ Subsurface Septic ☐ Mound

Onsite Wastewater System Location

Address or Legal Description or Parcel Identification Number (PID) 15-14-200-011-000

Owner John Schleich Address 9005 Whitstruck Rd. Bennet 68496

A. Wastewater Piping

1. Material: Sch 40 PVC Diameter: 4 in.
2. Distance between dwelling and septic tank: 40 ft.

B. Septic Tank

1. Material: Poly
2. Capacity: 1500
3. Depth to top of tank, below unfinished grade: 16 in.
4. Distance to:
   Well NA ft.
   Pressure line NA ft.
   Property Line >100 ft.
   Foundation 40 ft.

C Distribution Box or Drop Box

Distance and Direction from septic tank: 40 ft. E

D. Drainfield/Absorption Field

☑ Trench ☐ Bed

1. Type: ☐ Perforated Pipe ☐ Chamberless ☑ Other
   Material brand and inside width of Chamberless: EZ Flow Lateral B
2. Number of Laterals: 3
3. Length of each lateral (linear): ft. 100 ft. 100 ft 100 ft.
4. Drainfield size: 1350 sq. ft.
5. Distance to:
   Well NA ft.
   Pressure line NA ft.
   Property line 750 ft.
   Depth of Groundwater >10'

Was the Onsite Wastewater System covered prior to LLCHD inspection? ☑ Yes ☐ No

If Yes, the Certified Professional must sign below for final approval

I swear and affirm that the system complies with Lincoln Municipal Code (LMC) 24.38 and/or County Resolution R-13-0062 requirements and that the information and documentation submitted are true and accurate.

Certified Professional Signature: [signature] Date 6-27-22

Complete As-Built drawing on the back of this form

Updated = 1


9005 Whitstruck Rd.
40'
39'
54'
1500 Gal Infiltrator
Plastic Tank
Tank GPS:
N 40* 40.0875'
W096* 35.9434'
1350 sqft EZ Flow
Lateral Field