Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number
H5002464

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 10415 W Adams St. (no rural route) City Lincoln, NE Zip 68524

Legal Description S10 T10 R5 8

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 04-16-200-006-000

B. Owner

Name Brenton Kammers Signature

Address City/State/Zip

Home Phone 402 440 3962 Work Phone

C. Certified Installer

Name: Steven Lewis Signature

Address 3300 N 71st. Street City/State/Zip Lincoln NE 68507

Work Phone 402 432 1082

D. Engineer ☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☐ Yes ☑ No Total Acres 2
Garbage Grinder? ☐ Yes ☑ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature
Comments

2. Supt. Bldg. Insp. or Village Clerk
Comments Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature

3. City or County Engineer
Comments Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 9-16-22 Amount Paid $450
Received By JAD Cash/Check No. 005909

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number:

Onsite Wastewater Treatment System
Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 10415 W Adams St City Lincoln NE, Zip 68524

Owner Brenton Lamaars (no rural route) Address

Date of Tests 4-27-22 to 4-28-22 Weather: Precipitation Ø Temperature 60°

Percolation Test Data Table

A.	B.	C. D. E. F. Saturation/Swelling Time				G. H. I. J. K. Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					L. M. N. Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Initial Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (in)	Percolation Rates (Min/in = mpi)
1	36	4-27	10:00	4-28	10:00	4-28	10:00	6	4-28	10:50	50	1.5	20
2	36	"	"	"	"	"	"	6	"	"	"	1	30
3	36	"	"	"	"	"	"	6	"	"	"	1	30
4	36	"	"	"	"	"	"	6	"	"	"	1	30
								6					
								6					
								6					
								6					

Person Conducting Percolation Test

Name: Steven Lewis
Phone: 4024321082
Address 3300 N 71st Street
Lincoln NE 68507

Soil type (NRCS Maps/Other) 7867 Nodaway silt loam
Groundwater Depth 78'

Sum of Percolation Rates: 110
Average of Rates: 27.5
Rate Used for Calculation: 20-30

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date


10415 W Adams St.
100'
136'
234'
Optimum Lateral Area
Flood Plain
Property Line

Lincoln-Lancaster County Health Department
Environmental Public Health Division (402) 441-8027
3131 O Street Lincoln, Nebraska 68510-1514

ON-SITE WASTE WATER SYSTEM
CONSTRUCTION - INSTALLATION PERMIT
No. HS002464

System Type: Standard

Situs: No Site Address Specified

Issued: 10/10/2022

Expires: 10/10/2023

Description: S16, T10, R5, 6th Principal Meridian, LOT 8 NE

Owner: PAWNEE LAKE RENTAL CABIN LLC
4110 W THATCHER CIR
LINCOLN, NE 68528

Patricia D. Lopez

Patricia D. Lopez, RN, MSN, Health Director

Dear Applicant:

The above document is your permit to construct a new On-site Waste Water System at the location listed. Please contact this office once the sytem is complete in order to schedule a final inspection before use.

Patricia D. Lopez

Patricia D. Lopez, RN, MSN
Health Director

STEVEN LEWIS
3300 N 71ST ST
LINCOLN, NE 68507

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number HS002464

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 10415 W Adams St. (no rural route) City Lincoln, NE Zip 68524

Legal Description _____

1/4	1/4	Section	Township	Range	Subdivison	Addition	Block	Lot

PID 04-16-200-006-000

B. Owner

Name Brenton Kammers Signature _____

Address _____ City/State/Zip _____

Home Phone 402 440 3962 Work Phone _____

C. Certified Installer

Name: Steven Lewis Signature _____

Address 3300 N 71st. Street City/State/Zip Lincoln NE 68507

Work Phone 402 432 1082

D. Engineer ☐ **Check and complete if engineer designed system** P.E. License Number: _____

Designer Name _____ Firm _____ Work Phone _____

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☐ Yes ☑ No Total Acres 2

Garbage Grinder? ☐ Yes ☑ No

☐ Commercial Establishment/Other Facility Specify _____ Design flow in gallons per day _____

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☑ County Resolution No. 02-30

1. Health Department

Site visits _____ Date rec'd 10/10/22

Date frwd 10/12/22

Comments _____

ACTION ☑ Approved ☐ Disapproved

Signature _____

2. Supt. Bldg. Insp. or Village Clerk

Comments _____ Date rec'd _____

Date frwd _____

ACTION ☐ Approved ☐ Disapproved

Signature _____

3. City or County Engineer

Comments _____ Date rec'd _____

Date frwd _____

ACTION ☐ Approved ☐ Disapproved

Signature _____

Installation Final Written Approval

By _____

Date 10/5/23

Business Office Use Only

Date Received _____ Amount Paid _____

Received By _____ Cash/Check No. _____

White - Health Department Yellow - Engineer Pink - Building & Safety

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

SCANNED

A

Permit Number
A5002464

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 10415 W Adams St. (no rural route) City Lincoln, NE Zip 68524

Legal Description 10 T10 R5 8

1/4 1/4 Section Township Range Subdivison Addition Block Lot

PID 04-16-200-006-000

B. Owner

Name Brenton Kammers Signature

Address City/State/Zip

Home Phone 402 440 3962 Work Phone

C. Certified Installer

Name: Steven Lewis Signature

Address 3300 N 71st. Street City/State/Zip Lincoln NE 68507

Work Phone 402 432 1082

D. Engineer ☐ **Check and complete if engineer designed system** P.E. License Number:

Designer Name Firm Work Phone

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☐ Yes ☑ No Total Acres 2
Garbage Grinder? ☐ Yes ☑ No

☐ Commercial Establishment/Other Facility Specify Design flow in gallons per day

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department
Site visits Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature
Comments

2. Supt. Bldg. Insp. or Village Clerk
Comments Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature

3. City or County Engineer
Comments Date rec'd ACTION ☐ Approved ☐ Disapproved
Date frwd Signature

Installation Final Written Approval
By
Date

Business Office Use Only
Date Received 9-16-22 Amount Paid $450
Received By JMD Cash/Check No. 005909

White - Health Department Yellow - Engineer Pink - Building & Safety

Form A Updated: 1/13


Flood
Plain
Lift Station Using
Exsisting Pump
Tie onto
Exsisting
Sewer
10415 W Adams St
2"
Pressure
Line
765sqft
96'
80'
1000g Plastic Tank
GPS:
N 40° 50.5253'
W 096° 51.6069'
Tank & Laterals 6' setback
N

D Exhibit 4

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

Permit Number:

Onsite Wastewater Treatment System
As-Built Description and Drawing

Type of Onsite Wastewater System: ❑ Lagoon (Skip to Back Page) ❑ Subsurface Septic ❑ Mound

Onsite Wastewater System Location

Address or Legal Description or Parcel Identification Number (PID): 04-16-200-006-000

Owner: Brenton Lammers Address: 10415 W Adams St. Lincoln NE 68524

A. Wastewater Piping

1. Material: PVC Diameter: 4 in.
2. Distance between dwelling and septic tank: 228 ft.

B. Septic Tank

1. Material: Plastic
2. Capacity: 1000g
3. Depth to top of tank, below unfinished grade: 16 in.
4. Distance to:
   Well 237 ft.
   Pressure line ____ ft.
   Property Line 20 ft.
   Foundation 228 ft.

C Distribution Box or Drop Box

Distance and Direction from septic tank: 10 ft. W

D. Drainfield/Absorption Field

❑ Trench ☒ Bed

1. Type: ❑ Perforated Pipe ❑ Chamberless ☒ Other
   Material brand and inside width of Chamberless: EZ Flow
2. Number of Laterals: 2
3. Length of each lataral (linear): ft. 90 ft. 80 ft. ____ ft. ____
4. Drainfield size: 765 sq. ft. 780 Req'd
5. Distance to:
   Well 216 ft.
   Pressure line ____ ft.
   Property line 20 ft.
   Depth of Groundwater >10'

Was the Onsite Wastewater System covered prior to LLCHD inspection? ❑ Yes ☒ No

If Yes, the Certified Professional must sign below for final approval

I swear and affirm that the system complies with Lincoln Municipal Code (LMC) 24.38 and/or County Resolution R-13-0062 requirements and that the information and documentation submitted are true and accurate.

Certified Professional Signature: _____ Date: 20 Apr. 2022

Complete As-Built drawing on the back of this form.

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number:

Onsite Wastewater Treatment System
Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 10415 W Adams st City Lincoln NE, Zip 68524
(no rural route)

Owner Brenton Lamaars Address

Date of Tests 4-27-22 to 4-28-22 Weather: Precipitation Ø Temperature 60°

Percolation Test Data Table

A.	B.	C.	D.	E.	F.	G.	H.	I.	J.	K.	L.	M.	N.
		Saturation/Swelling Time				Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					Results		
		Start		End		Start		Initial	End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (In)	Percolation Rates (Min/in = mpi)
1	36	4-27	10:00	4-28	10:00	4-28	10:00	6	4-28	10:30	30	1.5	20
2	36	"	"	"	"	"	"	6	"	"	"	1	30
3	36	"	"	"	"	"	"	6	"	"	"	1	30
4	36	"	"	"	"	"	"	6	"	"	"	1	30
								6					
								6					
								6					
								6					

Person Conducting Percolation Test

Name: Steven Lewis
Phone: 4024321082
Address 3300 N 71st Street
Lincoln NE 68507

Sum of Percolation Rates: 110
Average of Rates: 27.5
Rate Used for Calculation: 20-30

Soil type (NRCS Maps/Other) 7867 Nodaway silt loam
Groundwater Depth 78"

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date

Nate C. Hartman

From: Nebraska Septic <nebraskaseptic@gmail.com>
Sent: Sunday, October 9, 2022 1:11 PM
To: Nate C. Hartman
Subject: 10415 W Adams Additional information request
Attachments: A and B Sheet (Detail Aditional Reserve Area).pdf

I have attached the results of the other holes on my percolation test. I removed for the official form as this was not a requirement for the percolation test information. Please let me know if there is anything else you require here, I will be trying to complete this system prior to me going out of town next Thursday. I will let you know when I can schedule with my dad to install it.

Thank You!

Steven C Lewis
Master Installer/ Inspector OSWWTS

Nebraska
SEPTIC
(402)432-1082

www.NebraskaSeptic.com

Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

A

Permit Number

Onsite Wastewater Treatment System
Request for Site Clearance and Permit

Include Form B and C. Submit correct fee with this Application

3 acres or more required for: ☑ Septic System ☐ Lagoon ☐ Other (Refer to Form C)

The undersigned hereby requests site clearance and permit to construct a Wastewater Treatment System in conformance with appropriate regulations.

PLEASE PRINT OR TYPE

A. Onsite System Location

Address 10415 W Adams St. (no rural route) City Lincoln, NE Zip 68524

Legal Description _____

1/4	1/4	Section	Township	Range	Subdivison	Addition	Block	Lot

PID 04-16-200-006-000

B. Owner

Name Brenton Kammers Signature _____

Address _____ City/State/Zip _____

Home Phone 402 440 3962 Work Phone _____

C. Certified Installer

Name: Steven Lewis Signature _____

Address 3300 N 71st. Street City/State/Zip Lincoln NE 68507

Work Phone 402 432 1082

D. Engineer ☐ **Check and complete if engineer designed system** P.E. License Number: _____

Designer Name _____ Firm _____ Work Phone _____

E. This system will serve a

☑ Residential Dwelling Number of Bedrooms 3 Whirlpool Bathtub? ☐ Yes ☑ No Total Acres 2

Garbage Grinder? ☐ Yes ☑ No

☐ Commercial Establishment/Other Facility Specify _____ Design flow in gallons per day _____

Type of Wastewater ☐ Domestic ☐ Non-Domestic

DO NOT WRITE BELOW THIS LINE

Approval Process ☐ Municipal Code 24.38 ☐ County Resolution No. 02-30

1. Health Department

Site visits _____ Date rec'd _____ **ACTION** ☐ Approved ☐ Disapproved

Date frwd _____ Signature _____

Comments _____

2. Supt. Bldg. Insp. or Village Clerk

Comments _____ Date rec'd _____ **ACTION** ☐ Approved ☐ Disapproved

Date frwd _____ Signature _____

3. City or County Engineer

Comments _____ Date rec'd _____ **ACTION** ☐ Approved ☐ Disapproved

Date frwd _____ Signature _____

Installation Final Written Approval

By _____

Date _____

Business Office Use Only
Date Received _____ Amount Paid _____
Received By _____ Cash/Check No. _____

White - Health Department Yellow - Engineer Pink - Building & Safety

Lincoln-Lancaster County Health Department (LLCHD)
Environmental Public Health Division
3140 "N" Street • Lincoln, NE 68510-1514
Phone: 402-441-8022

B

Permit Number:

Onsite Wastewater Treatment System
Soil Evaluation Report

PLEASE PRINT OR TYPE

Onsite System Location

Address 10415 W Adams St City Lincoln NE, Zip 68524

(no rural route)

Owner Brenton Lamaars Address

Date of Tests 4-27-22 to 4-28-22 Weather: Precipitation Ø Temperature 60°

Percolation Test Data Table

A.	B.	C. D. E. F. Saturation/Swelling Time				G. H. I. J. K. Water Level Drop Last 30 mins of 4 hr or last 10 mins of 1 hr					L. M. N. Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Date (Mo/Da)	Time (Hr/Min)	Initial Water Lev (in.)	Date (Mo/Da)	Time (Hr/Min)	Elapsed Time Interval	Water Level Drop (in)	Percolation Rates (Min/in = mpi)
1	36	4-27	10:00	4-28	10:00	4-28	10:00	6	4-28	10:30	30	1.5	20
2	36	"	"	"	"	"	"	6	"	"	"	1	30
3	36	"	"	"	"	"	"	6	"	"	"	1	30
4	36	"	"	"	"	"	"	6	"	"	"	1	30
5	"	"	"	"	"	"	"	6	"	"	"	3/4	40
6	"	"	"	"	"	"	"	6	"	"	"	3/4	40
								6					
								6					

Person Conducting Percolation Test

Name: Steven Lewis
Phone: 4024321082
Address 3300 N 71st Street
Lincoln NE 68507

Sum of Percolation Rates: 110
Average of Rates: 27.5
Rate Used for Calculation: 20-30

Soil type (NRCS Maps/Other) 7867 Nordaway silt loam
Groundwater Depth 78'

Holes 3, 5, & 6 are within "Reserve Area
These were removed from B Sheet for perc results

DO NOT WRITE BELOW THIS LINE

Reviewing Action

Comments (Soil type, groundwater, floodplain, etc.)

Signature of Reviewing Official Date

Nate C. Hartman

From: Jamie L. Hawkins
Sent: Friday, October 7, 2022 12:11 PM
To: Nate C. Hartman
Subject: Lot 8 16-10-5
Attachments: 72-5868.pdf; Lot 8 16-10-05.png

Attached are the files we discussed today on the phone.

Jamie Hawkins
Lancaster County Engineering
444 Cherry Creek Road
Lincoln, Nebraska 68528
402-441-7681

NEBRASKA DOCUMENTARY STAMP TAX
SEP 11 AM
8.25 M.M.

Project: Salt Creek & Tributaries, Nebr., Dam No. 14

Tract: 137

WARRANTY DEED

KNOW ALL MEN BY THESE PRESENTS:

That Ann E. McDonald, a widow, of the County of Lancaster, State of Nebraska, Grantor, for and in consideration of the sum of Seven Thousand One Hundred Forty and No/100 Dollars ($7,140.00), to her in hand paid, the receipt of which is hereby acknowledged, does hereby grant, bargain, sell and convey to the UNITED STATES OF AMERICA, Grantee, of Washington, D. C., and its assigns, the following real estate situate in the County of Lancaster, State of Nebraska, to-wit:

All that portion of the $W\frac{1}{2}NE\frac{1}{4}$ of Section 16, Township 10 North, Range 5 East of the Sixth Principal Meridian, Lancaster County, Nebraska, lying Westerly of the right bank of a drainage channel tributary to Middle Creek.

Excepting therefrom the following described 10-acre parcel of land: The $N\frac{1}{2}NW\frac{1}{4}NW\frac{1}{4}NE\frac{1}{4}$, the $SW\frac{1}{4}NW\frac{1}{4}NW\frac{1}{4}NE\frac{1}{4}$ and the $NW\frac{1}{4}SW\frac{1}{4}NW\frac{1}{4}NE\frac{1}{4}$ of said Section 16.

Also excepting the $NW\frac{1}{4}NE\frac{1}{4}NW\frac{1}{4}NE\frac{1}{4}$ of said Section 16.

The tract of land herein described contains 14.00 acres, more or less.

Subject to existing easements for public roads and highways, public utilities, railroads and pipelines.

To have and to hold the premises above described, together with all the tenements, hereditaments and appurtenances thereunto belonging unto the said UNITED STATES OF AMERICA and its assigns forever.

And the Grantor, for herself, her heirs and assigns hereby covenants with the UNITED STATES OF AMERICA and its assigns that said Grantor is lawfully seized of said premises; that premises are free from encumbrances and that said Grantor has good right and lawful authority to sell same, and that she and her heirs and assigns shall warrant and defend the same unto the said UNITED STATES OF AMERICA and its assigns forever against the lawful claims of all persons whomsoever.

The Grantor further quitclaims to the UNITED STATES OF AMERICA and its assigns all right, title, or interest which she may have in any streams, alleys, roads, streets, ways, strips, gores, or railroad rights of way abutting or adjoining said land.

IN WITNESS WHEREOF, the Grantor has hereunto set her hand this 14th day of MARCH, 1972.

Ann E. McDonald
ANN E. MCDONALD

of Irregular Tracts in the NE¼ of Section 16, T10N, R5E.

November 14, 1972.

A part of Lot 2, Irregular Tracts in the NW¼ NE¼ of Section 16, T10N, R
e 6th Principal Meridian, Lancaster County, Nebraska, more particularly
ibed as follows:

All of the NW¼ NE¼ NW¼ NE¼.

Containing 2.5 acres, more or less.

Nate C. Hartman

From: Steven Lewis <nebraskaseptic@gmail.com>
Sent: Thursday, October 6, 2022 9:38 PM
To: Nate C. Hartman
Subject: W Adam's road project

I will be replacing the existing lift station with a modern sealed one that includes a high water alarm. The new components that will replace the existing lagoon that is on the neighbors property will be installed outside of the flood plain. The flood pain and property line will be located by a surveyor prior to construction.

Nebraska Septic

Thursday, September 22, 2022

Pre-Installation Notes

Brenton Lammers
10415 W Adams St
Lincoln NE 68524

Job Number
220306

Dear; Nate Hartman

I have contacted Allen Surveying Services LLC to identify property lines and flood plain elevations on this site prior to the percolation testing of the site, and I will have them refresh the marks prior to installation to ensure accuracy.

The existing lagoon on this address is currently located outside of the property line. This is the major issue we are attempting to correct. Installation of the septic will be completely within the property lines after septic is installed.

Currently there exists a lift station just inside the property, within the flood plain that is aged and may not protect from flood waters entering the lift station in the situation of flooding. Our replacement lift station will be sealed to prevent leaking.

The only component of this system that will be located within the flood plain will be the lift station. I will ensure conduit into the lift station is sealed to prevent introduction of surface water into the lift station.

The tank and laterals will be installed outside of the flood plain marks provided by Allen Surveying Services, and within the property lines provided by the same company.

Owner

Name	Steven C Lewis
	3300 N 71st Street
	Lincoln NE, 68507
Phone #	(402) 432-1082
Email:	NebraskaSeptic@gamil.com

Nate C. Hartman

From: Nebraska Septic <nebraskaseptic@gmail.com>
Sent: Sunday, October 9, 2022 1:11 PM
To: Nate C. Hartman
Subject: 10415 W Adams Additional information request
Attachments: A and B Sheet (Detail Aditional Reserve Area).pdf

I have attached the results of the other holes on my percolation test. I removed for the official form as this was not a requirement for the percolation test information. Please let me know if there is anything else you require here, I will be trying to complete this system prior to me going out of town next Thursday. I will let you know when I can schedule with my dad to install it.

Thank You!

Steven C Lewis
Master Installer/ Inspector OSWWTS

Nebraska
SEPTIC
(402)432-1082

www.NebraskaSeptic.com