006

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

441-7800
2200 St Marys Avenue Phone (402) XXXXXXX Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☐ Evaluation of the Individual Water System Date: 5/17/96

☒ Evaluation of the Sewage Disposal System ☐ Enclosed is $150.00 # 3051

Legal Description of Property: TWP. 7N; RANGE 7E; SECTION Section 1 SW ¼ of; BLOCK —
LOT 38; ADDITION East of 6th PM; Street Address 10600 Panama Rd, Hickman, Ne 68

Directions to Property 1 mile south, 2½ miles east of Hickman Ne or ½ mile east of Holland Ne, North side of Rd (Yellow House)

Location of Well south of existing house (8ft) Tap Location: Inside ☐ Outside ☒

Location of Sewage System North of abl garage - east of metal Bldg. (200 ft.) Year Installed 1991

	NAME	ADDRESS	PHONE
Present Owner:	Glen Prange	10600 Panama Rd	792-2740
Tenant/Buyer:	Ken Mayors	3820 Wildbrier Lane	423-4307
Return to:	Commercial Federal attn Susan Hughes	70th & Adams Lincoln Ne 68507 3045 N. 70th Street	473-0765 FAX 464-0479

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Ken Mayors Address 3820 Wildbrier Lane Lincoln, Nebr 6851

HEALTH DEPARTMENT USE ONLY

Date Received 05/19/96 Received $150.00 Check ☐ Cash ☐

PRELIMINARY STATUS--DATE JUNE 7, 1996

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:	SITE VISIT:
Construction	☐	☒	Approved: ☐	Date 6/7/96 by J.C.H.
Bacteria	0 ☒	☐	Provisional: ☐	Date 6/12/96 by J.C.H. Diggs
Nitrate	<0.1 ☒	☐	Disapproved: ☒	Date 6/14/96 by J.C.H. Dilley Moved

Comments: WELL NEEDS A LITTLE DIRT FILLED JUST NORTH OF IT. NO WARNING SIGNS ON LAGOON FENCE. DIKES NEED MOWING. DIKE SLOPE IS GREATER THAN 3 TO 1. NO INSPECTION WAS REQUESTED WHEN LAGOON WAS BUILT. See Attached Letter ☐

FINAL STATUS

	WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
	Approved: ☒	Approved: ☐	Provisional Approval: ☒

APPROVED BY Jerrold C. Hood R.E.H.S. DATE JUNE 14, 1996

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska
INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

EQ 4120

'96 JUN -7 PM 2:25

RECEIVED

'96 JUN 11 PM 4 26

REPORTED

COMPLETE INFORMATION BELOW

WATER CHEMISTRY

STATE LAB NO. 154173

DATE COLLECTED 6 (MO.) 7 (DAY) 96 (YEAR) 11:45AM (HOUR)

SAMPLE COLLECTED BY JERROLD HOOD

SAMPLE LOCATION GLEN PRANGE

PROPERTY LEGAL DESCRIPTION: COUNTY LANCASTER

QRTR SE SECT 1 TWNSHP 7 N RANGE 7 E W

NAME AND ADDRESS OF PERSON TO RECEIVE EXTRA REPORT:

PLEASE PRINT COMPLETE ADDRESS

THIS LAB REPORT IS TO BE MAILED TO:

LINCOLN-LANCASTER COUNTY
ENVIRONMENTAL HEALTH
3140 "N" STREET
LINCOLN, NEBRASKA 68510

STATE OF NEBRASKA DEPARTMENT OF HEALTH LABORATORIES
3701 SOUTH 14th LINCOLN, NE 68502

FOR LABORATORY USE ONLY

TEST METHOD: USEPA METHOD 353.2

NITRATE ANALYSIS FOR DRINKING WATER

NITRATE — N Less than 0.1 mg/l

NOT TESTED BECAUSE OF:
☐ DAMAGE
☐ INSUFFICIENT AMOUNT
☐ IMPROPER CONTAINER

TEST(S) BY

FOR ACCOUNTING USE ONLY

LWN 88

WATER MICROBIOLOGY

STATE LAB NO 14/0857

COMPLETE INFORMATION BELOW

DATE COLLECTED 6 (MO.) 7 (DAY) 96 (YEAR) 11:45AM (HOUR)

SAMPLE COLLECTED BY JERROLD HOOD

SAMPLE LOCATION GLEN PRAIRIE

PROPERTY LEGAL DESCRIPTION: COUNTY LANCASTER

QRTR SE SECT 1 TWNSHP 9 N RANGE 7 E

NAME AND ADDRESS OF PERSON TO RECEIVE EXTRA REPORT:

PLEASE PRINT COMPLETE ADDRESS

THIS LAB REPORT IS TO BE MAILED TO:

LINCOLN-LANCASTER COUNTY
ENVIRONMENTAL HEALTH
3140 "N" STREET
LINCOLN, NEBRASKA 68510

RECEIVED '96 JUN 8 PM 1:23

'96 JUN -7 PM 2:25

STATE OF NEBRASKA DEPARTMENT OF HEALTH LABORATORIES
3701 SOUTH 14th LINCOLN, NE 68502

FOR LABORATORY USE ONLY

TEST METHOD: ☒ MEMBRANE FILTER ☐ MPN

COLIFORM PURITY TEST FOR DRINKING WATER

TOTAL COLIFORMS 0 PER 100 ML.

☒ THE WATER MEETS BACTERIOLOGICAL STANDARD

☐ WATER DOES NOT MEET BACTERIOLOGICAL STANDARD

☐ RESULTS MAY BE INVALID DUE TO EXCESSIVE AGE*

*SAMPLES RECEIVED BETWEEN 30-48 HRS. AFTER COLLECTION

SAMPLE NOT ANALYZED BECAUSE OF:

☐ EXCESSIVE AGE ☐ INSUFFICIENT AMOUNT

☐ DAMAGE ☐ IMPROPER CONTAINER

TEST METHOD NUMBER: NIPDWR 141.27

TEST(S) BY

FOR ACCOUNTING USE ONLY

LWB 91