LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 ST. MARYS
LINCOLN, NEBRASKA 68502

FILE NO. 2279-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

MAY 22, 1986 — THIS PERMIT EXPIRES

DAN RAND RAND OIL COMPANY ROUTE #1 — ISSUED TO

ADAMS, NE 68301 — ADDRESS

T7N; R8E; Sec 11; Addition NE¼ of SE¼ Section 11 — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE NEW CONSTRUCTION

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 60.00	$	$	$ 60.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY: FB — DATE: 11/25/85 — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH — ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

RECD NOV 22 1985

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☑

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $ 60.00

FILE NO. 2279-C

DATE: 11-20-85

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 7N ; Range 8E ; Section 11 ;
   Block _____ : Lot _____ : Addition NE¼ of SE¼ section 11
   Street Address _____

2. Property Use: Residential ☑ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 4 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☑ Lagoon

4. Distance to public sewer: _____ ft.

DAN RAND
Signature of Applicant (Owner or Lessee)

Route 1 Adams
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 11/22/85. Date Frwd. 11/25/85. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 11/25/85. Date Frwd. 11/25/85. ACTION: Approved ☑ Disapproved ☐ Signature: [illegible]

3. City or County Engineer: Date Rec'd. 11/25/85. Date Frwd. 11/25/85. ACTION: Approved ☑ Disapproved ☐ Signature: Lynn Worrell

REMARKS OR REASONS FOR DISAPPROVAL NO PERCOLATION TEST SO LAGOON MUST BE SEALED

Site Visits:
Date: 11-22-85 by: mm need drawing & fence.
Date: _____ by: _____
Date: _____ by: _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: _____ By: _____

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

C

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO. 2279-C

Indicate on sketch if residence and well are exisiting or proposed.



this residence is on rural water

REVIEWING ACTION

Remarks: _____

_____

Date: _____

Minimum Design Requirement
1. Capacity of Septic Tank _____ gals.
2. Total Length of Laterals _____ ft.
3. With a Trench Width of _____ in.
4. Total Area of Lateral needed _____ sq.ft.

_____
Signature of Reviewing Official

Lincoln-Lancaster County
Health Department

2200 St. Mary's Ave
Lincoln, NE 68502-3785
402-471-7800
M. Jane Ford, Director

December 4, 1986

Daniel Rand
Route #1, Box 77-A
Adams, NE 68301

Dear Mr. Rand:

The water supply for your property (T7N, R8E, Sec 11) near Panama, Nebraska is from the Lancaster County Rural Water District #1 public water system. This public water supply meets bacterial requirements of the Safe Drinking Water Act.

The permit for sewage disposal serving this property is complete except for one item. When a fence is constructed around the waste stabilization pond, the permit will be complete. Permit approval will be complete when the fence is constructed and inspected.

If there are any questions, please contact the Health Department.

Sincerely,

Ron Marquart

Ron Marquart, Field Sanitarian
Food/Water Section
Division of Environmental Health

RM:gl

REC'D NOV 26 1986

November 25, 1986

Mr. Jerry Hood
Lancaster County Dept. of Health
2200 St. Mary's Avenue
Lincoln, NE

Dear Mr. Hood:

Below please find a sketch of our lagoon set-up. The lagoon is an overall 270' north of the house. The first 5' are made of cast iron, then there is a couple with 75' to the next riser, 75' to the next riser, 75' to the next riser, and 40' to the lagoon. The pipe from the coupler to the lagoon is 4" 3033/3034.

If you have any questions, please call. Our home phone number is 788-2718.

Sincerely,

Marcia Rand

Marcia and Daniel Rand
Route 1, Box 77A
Adams, NE 68301

