Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

P6759-27

P6759-41 703

This form must be completed and returned with payment to request a real estate transfer

MAKE CHECK PAYABLE TO: "Lincoln-Lancaster County Health Department" or "LLCHD"

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

Legal Description of Property: Street Address 13900 OLIVE CREEK ROAD. HICKMAN NE 68372

Twp 7N Range 8E Section 9 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition ___

Directions to Property 1.75 MILES WEST OF HWY 43 & OLIVE CREEK RD. NORTH SIDE OF ROAD.

Location of Well EAST OF HOUSE - 20' Tap Location: Inside ☒ Outside ☒

Location of Sewage System EAST PASTURE Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	EUGENE HUENINK	13900 OLIVE CREEK RD HICKMAN NE 68372	788-2227
Tenant/Buyer:	TIM LOESCHE	15005 STAGECOACH RD. BENNET NE 68317	788-2857
Return to:	COLUMBUS FED. BANK ATTN: KIRK GOODNIGHT	770 N. COTNER LINCOLN NE 68505	464-4449

Signature of Applicant Tim Loesche Address 15005 STAGECOACH RD BENNET NE 68317 Date 2/16/99

HEALTH DEPARTMENT USE ONLY

RECEIVED

Date 02/18/99

Initials ks

Amount 150 ck

Check No. 3291

DATA ENTRY

Date ___/___/___

Case No. ___

Initials ___

PRELIMINARY STATUS--By JBaue **DATE:** 2/19/99

WATER SYSTEM:	Approved	Disapproved
Construction	☒	☐
Bacteria	☒ 0 /ml	☐ ___ /ml
Nitrate	☐ ___ ppm	☒ 17.6 ppm

SEWAGE SYSTEM	
Approved	☒
Provisional	☐
Disapproved	☐

Additional Site Visits

Date ___/___/___ by ___

Date ___/___/___ by ___

Date ___/___/___ by ___

Comments: Nitrate result exceeds maximum level of 10 ppm. Recommend a Treatment system be installed to reduce nitrates below 10 ppm. WARNING SIGNS needed for Lagoon fence. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved ☒ **SEWAGE DISPOSAL SYSTEM:** Approved ☒ Provisional Approval ☐

Approved by JBaue Date 3/2/99

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 10-95

FEB 2 2 1999

Nebraska Health and Human Services
Regulation and Licensure - Laboratory Services
3701 South 14th Street
Lincoln, NE 68502
(402) 471-2122
(402) 471-2080 (fax)

Laboratory Report Printed on FEB-22-99

LLCHD
LINCOLN LANCASTER COUNTY HEALTH DEPT.

3140 N STREET
LINCOLN, NE 68510

Results for: **PRIVATE T/E COLI**

Laboratory Number: **P6759-27**
Sampled By: **BARE, JIM**
Location: **HUENINK 7N8ESEC9**
Sample Point:

Date Collected: **19-Feb-1999 12:00 AM**
Date Received: **19-Feb-1999**

Parameters	Method	Analysis Date	Analyst	Results	Qual	Units	Report Level
TOTAL COLIFORM	COLILERT	02/20/99	SB	Total coliform negative - meets bacteriological standards		cfu/100ml	0
E. COLI	COLILERT	02/20/99	SB	E. coli negative		cfu/100ml	0

Note: see reverse side of report for description of acronyms and data qualifiers

Nebraska Health and Human Services
Regulation and Licensure - Laboratory Services
3701 South 14th Street
Lincoln, NE 68502
(402) 471-2122
(402) 471-2080 (fax)

MAR 1 1999

Laboratory Report printed on: FEB-25-99

LLCHD
LINCOLN LANCASTER COUNTY HEALTH DEPT.

3140 N STREET
LINCOLN, NE 68510

Results for: **NITRATE/NITRITE**

Laboratory Number: **P6759-41**
Sampled By: **BARE, JIM**
Location: **HUENINK**
Well ID:

Date Collected: **19-Feb-1999 12:00 AM**
Date Received: **22-Feb-1999**

Parameters	Method	Prep Date	Analysis Date	Analyst	Results	Qual	Units	Report Level
NITRATE+NITRITE (AS N)	353.2		02/23/99	EEDP	17.6		mg/l	.05

Note: see reverse side of report for description of acronyms and data qualifiers