Please Rush

# Lincoln-Lancaster County Health Department

Closing end of May

**2200 St. Mary's Avenue, Lincoln, Nebraska 68502 Phone: 441-8022**

## REAL ESTATE TRANSFER/LOAN APPROVAL FORM

**ORIGINAL LOAN APPROVAL FILE**
**PREVIOUS HISTORY UNKNOWN**

This form must be completed and returned to req

**MAKE CHECK PAYABLE TO:** Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address RR1 Crete Ne

Twp 8 Range 5 Section 32 1/4 NW 1/4 Block ___ Lot ___ Addition ___

Directions to Property Doane College - 3 miles east of Crete on 13th on Corner - Cream & green on Corner Ranch Style

Location of Well Pipe - down by Bigshed Tap Location: Inside ☐ Outside ☐

Location of Sewage System ___ Year Installed ___

| | NAME | ADDRESS | PHONE |
|---|---|---|---|
| Present Owner: | Roger & Marilyn Nelson | RR1 Crete Box 114A 68337 | 826-5643 |
| Tenant/Buyer: | Kent & Lisa Nelson | RR1 Crete Box 114AA Crete Ne. 68337 | 826-3815 |
| Return to: | 1st Tier | see envelope attached | |

Signature of Applicant Lisa J. Nelson Address RR1 Crete Ne Date 5/22/93

---

**HEALTH DEPARTMENT USE ONLY**

Date Received 5/26/93 Received $150.00 Check ☒ Cash ☐

**PRELIMINARY STATUS--By** Jerrold Wood **DATE:** 5/26/93

| **WATER SYSTEM:** | Approved | Disapproved |
|---|---|---|
| Construction | ☐ | ☒ |
| Bacteria | ☐ ____/ml | ☐ ____/ml |
| Nitrate | ☒ <0.1 ppm | ☐ ____ppm |

**SEWAGE SYSTEM**
Approved ☐
Provisional ☒
Disapproved ☐

**Additional Site Visits**
Date ___/___/___ by ___
Date ___/___/___ by ___
Date ___/___/___ by ___

**Comments:** OLD WELL TO CLOSE, PIT TOO CLOSE, LATERALS TOO CLOSE, MANURE TOO CLOSE. SEWAGE SYSTEM PREDATES REGULATIONS HENCE APPROVAL IS PROVISIONAL. See Attached Letter ☐

**FINAL STATUS**

**WATER SYSTEM:** Approved: ☐ **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☐

Approved by ___ Date ___/___/___

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.