LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 641-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF PERMIT

December 17, 1975
THIS PERMIT EXPIRES

John P. Kramer, 6530 Holdrege St., Lincoln
ISSUED TO ADDRESS

T8N; R6E; Sec. 2; Bl. 1; Lot 3; Wilderness Park Estates, 1st Addn.
LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624-1535	110.16	148.14	6-2
RECEIPTED BY	DATE	AMOUNT	

ISSUING OFFICER

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 641-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: June 16, 1975

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 8 N ; Range 6 E ; Section 2
Block 1 ; Lot 3 ; Addition Wilderness Park Estates First Addn.
Street Address 11601 South 7th Street

2. Property Use: Residential ☒ ; Commercial ☐
No. of Bedrooms 3 . Describe:
Other Use ☐
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: ft.

KRUEGER CONSTRUCTION CO.
John R. Krueger
Signature of Applicant (Owner or Lessee)

6530 Holdrege Street, Lincoln, Ne 68505
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 6/16/75 . Date Frwd. 6/17/75 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hoad

2. Supt. Bldg. Insp.: Date Rec'd. 6/18/75 . Date Frwd. 6/18/75 . ACTION: Approved ☒ Disapproved ☐ Signature: by Robert Sons

3. City or County Engineer : Date Rec'd. 6/18/75 . Date Frwd. 6/18/75 . ACTION: Approved ☒ Disapproved ☐ Signature: Allen L. Pearson

REMARKS OR REASONS FOR DISAPPROVAL

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 641-C

DATE: June 16, 1975

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 8 N ; Range 6 E ; Section 2 ; Block 1 ; Lot 3 ; Addition Wilderness Park Estates First
Street Address 11601 South 7th Street .

2. Property Use: Residential ☒; Commercial ☐
No. of Bedrooms 3
Describe:
Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

KRUEGER CONSTRUCTION CO.
John P. Krueger
Signature of Applicant (owner or lessee)

6530 Holdrege Street, Lincoln, Ne 68505
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
Filing Fee: $ 30.00

2. Site Visits:
Date: Aug-11-75 by: rm
Date: by:
Date: by:

3. Date: Approved ☒; Disapproved ☐ 8/17/75
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: Aug-11-75 by: Ron Maynard

FORM HD- 43(73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 475-6221)

FILE NO. 641 - C

PROPERTY WHERE SOIL TESTED:
Location: Township _____; Range _____
Section & ¼ Sect. _____
Property Dimensions: ____ft. x ____ ft.
Area: _____acres. (Attach sketch of property showing hole location).

Owner: _____
Address _____

Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☒; Sandy Clay ☐

Dates of Tests: June 12 75 to June 13 75. Weather: Precip. 0 Temp. 80s F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36"	6/12	6 PM	6/13	6 PM	6/13	6 PM	12"	8 PM	8"	30 M	3/4	
2										8"		3/4	
3										10½		1¼	
4										8¼		3/4	
5										9¼		½	
6										9		½	

Robert D Johnson
Signature of Person Conducting Test

Address 2618 N 32nd
Phone: 432 3595

Sum of Percolation Rates _____
Average of Rates: _____
Mean of Rates: _____

(Do not write below this line)

REVIEWING ACTION

REMARKS: _____

Approved Percolation Rate(s)
A. 53 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: June 17, 1975

Jerrold C. Hood
Signature of Reviewing Official

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM

(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 641-C

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material _____; Diameter ____ in.
2. Distance above basement floor ____in.; or below basement floor ____in.
3. Distance between dwelling and septic tank ____ft.
4. Number of clean-outs _____.
5. Distances To:
Well or Suction Line ____ft.;
Stream ____ft.; Pressure Line ____ft.;
Property Line ____ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Concrete; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth 51 in.
3. Factory Built: Yes ☒ (Company Precast)
No ☐
4. Manholes: Over Inlet; diam. 18 in.
Over Outlet; diam. 18 in.
Below Grade _____in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☒; or Tee ☐
Depth of outlet below inlet 1 in.
7. Depth of top of tank below finished grade ____in.
8. Distances To:
Well or Suction Line ____ft.;
Stream ____ft.; Pressure Line ____ft.;
Property Line ____ft.


C. DISTRIBUTION BOX
1. Material Concrete; No. available outlets 5.
2. Factory Built: Yes ☒, (Company Precast Slips) No ☐
3. Dimension: Length 20 in.; Width 14 in. Depth 18 in.
4. Distance from Septic Tank ____ft.
5. Serial Distribution: Yes ☐, No ☐
(If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: Half moon
2. Lateral Lines: Depth below grade ___in.
Number 3; Length of each line ___ft
Total length of Laterals 234 ft.;
Slope ____in/100 ft. Diameter of pipe 24 in.; Shape Half moon
Material: concrete ☒; fiber asbestos ☐; clay ☐; other _____
Distance between lateral lines ____ft.
3. Trench Dimensions: Depth ___in.; Width 48 in.
4. Filter Material: road gravel.
Depth of material from trench bottom _____in.
5. Distances To:
Well or Suction Line ____ft.;
Stream _____ft.; Pressure Line ____ft.
Property Line ____ft.
6. Percolation Rate: _____minutes/inch

TYPICAL SKETCHES




_____
Signature of Applicant




1160/ SOUTH, 7TH STREET

RESIDENCE MR & MRS WAYNE DANEKAS

CUSTOM by KRUEGER CONSTRUCTION Co.


5
4
6
3
1
2
80'
House.
Fence
Road


N
House
45'
Septic tank
Dist. Box
85' (4' wide bed)
Level
36' (2' wide trench)
3" drop
20'
80' (4' wide bed)
Level
96' (2' wide trench)
6" drop
(fence property line)

Aug-11-75