LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 ST. MARYS
LINCOLN, NEBRASKA 68502

FILE NO. 2337-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

DECEMBER 2, 1986 — THIS PERMIT EXPIRES

Lorance H. Newburn — ISSUED TO

7341 Garland, Lincoln, NE 68505 — ADDRESS

T8N; R6E; Sec 34; NW¼ SE¼; Lots 7, 16 & 17 in SE¼ — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE NEW CONSTRUCTION

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 60.00	$	$	$ 60.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY	DATE	AMOUNT
MG	6-2-86	

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH
ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $ 60.00

FILE NO. 2337-C

DATE: MAY 26, 1986

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 8N ; Range 6E ; Section 34 ;
   Block _____ : Lot _____ : Addition _____
   ~~Street Address~~ NW¼ SE¼ + LOTS 7+16, AND 17 IN SE¼

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒ LAGOON

4. Distance to public sewer: _____ ft.

Kenneth H. Kerstan II
Signature of Applicant (Owner or Lessee)

7341 GARLAND - LINCOLN, 68505
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 6/2/86. Date Frwd. 6/2/86. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 5/27/86. Date Frwd. 5/27/86. ACTION: Approved ☑ Disapproved ☐ Signature: Roger Palmer (clerk)

3. City or County Engineer: Date Rec'd. 6-2-86. Date Frwd. 6/2/86. ACTION: Approved ☑ Disapproved ☐ Signature: Harold E. Dalkan

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 8-14-86 by: [illegal] need [illegible] fence
Date: 6/29/87 by: J.C.H. fence up need sign + lock
Date: 7/20/87 by: J.C.H.


INSTALLATION FINAL WRITTEN APPROVAL
Date: 7/20/87 By: Jerrold Hood


White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

2337-C

WASTE STABILIZATION POND

LINCOLN-LANCASTER COUNTY HEALTH DEPT.
DIVISION OF ENVIRONMENTAL HEALTH





SECTION VIEW A-A
(APPLICABLE TO BOTH DESIGNS)

NUMBER OF BEDROOMS IN THE HOUSE	LAGOON DIMENSIONS (FEET)			
	SQUARE		ROUND	
	A	B	A	B
2-3	43	13	46	16
4	48	18	52	22

ADDITIONAL INFORMATION ON BACK

Thomas J. Deshner

APPLICANT'S SIGNATURE

FORM 20111-0278

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

B

FILE NO. 2337-C

PROPERTY WHERE SOIL TESTED:

Location: Township 8N ; Range 6E ; Section & ¼ Section 34, SE¼
Property Dimensions: IRREGULAR ft. x SEE "C" ft. Area: 6.37 acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: _____ to _____. Weather: Precip. _____ Temp. _____.

SOIL TYPE IS PAWNEE AND STEINAUER

OWNER: LORANCE NEWBURN

Address: 7341 GARLAND - LINCOLN 68505

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
		NO ABSORPTION TESTS WERE RUN. I INTEND TO INSTALL A											
		LAGOON AND SEAL IT WITH A LINER - EITHER PLASTIC OR											
		BENTONITE (WILL USE BENTONITE @ 6#/SQ FT)											

Thomas N. Newburn
Signature of Person Conducting Test

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Address 7341 GARLAND - LINCOLN Phone 466-7786 BUSINESS - 474-2233

(Do not write below this line)

REVIEWING ACTION

Remarks: _____

Soil Type (SCS): _____

Date: _____

Approved Percolation Rate (a)
A. _____ min./inch
B. _____ min./inch
C. _____ min./inch

_____
Signature of Reviewing Official

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

C

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO. 1337-C

Indicate on sketch if residence and well are exisiting or proposed.



REVIEWING ACTION

Remarks: _____

_____

Date: _____

Minimum Design Requirement
1. Capacity of Septic Tank _____ gals.
2. Total Length of Laterals _____ ft.
3. With a Trench Width of _____ in.
4. Total Area of Lateral needed _____ sq.ft.

_____
Signature of Reviewing Official