LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 807-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — November 2, 1976

TYPE OF PERMIT — THIS PERMIT EXPIRES

Eugene L. Habrock — 3093 Vine Street, Nincoln, NE 68503

ISSUED TO — ADDRESS

T8N: R7E: Sec. 21: Bl. 1: Lot 3: Jonathan Park Estates

LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624xxx	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

FRANK GOLDEN, Lancaster County Treasurer

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐

County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 807-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 4-27-76

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 8N ; Range 7E ; Section 21
   Block 1 ; Lot 3 ; Addition Jonathan Park Estates
   Street Address 6201 Roca Road

2. Property Use: Residential ☒ ; Commercial ☐
   No. of Bedrooms 3 . Describe:
   Other Use ☐
   Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☒ Lagoon

4. Distance to public sewer: 6-7mi ft.

Eugene L Habrak
Signature of Applicant (Owner or Lessee)

3093 Vine Linc 68503
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 5-5-76 . Date Frwd. . ACTION: Approved ☐ Disapproved ☒ Signature: Ron Marquart
2. Supt. Bldg. Insp.: Date Rec'd. . Date Frwd. 5-5-76 . ACTION: Approved ☐ Disapproved ☐ Signature:
3. City or County Engineer : Date Rec'd. 5-5-76 . Date Frwd. 5-5-76 . ACTION: Approved ☐ Disapproved ☒ Signature: Marvin A Ollis

REMARKS OR REASONS FOR DISAPPROVAL

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD- 43(73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 475-6221)

FILE NO. 807-C

PROPERTY WHERE SOIL TESTED:
Location: Township 8N ; Range 7E
Section & ¼ Sect. NE¼ Sec 21
Property Dimensions: 325 ft. x 421 ft.
Area: 3+ acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ☐; Silty Clay Loam ☒; Sandy Loam ☒
Silty Loam ☒; Clay Loam ☐; Sandy Clay ☐

Owner: Eugene L Habrock
Address 3093 Vine

Dates of Tests: 4-30 to 5-1. Weather: Precip. slight rain Temp. 65°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	24½	4-30	5:15	5-1	2:30	5-1	2:30	18	6:30	22½	240	4½	53.33
2	23	4-30	5:15	5-1	2:30	5-1	2:30	17¼	6:30	22	240	4¾	50.526
3	24	4-30	5:15	5-1	2:30	5-1	2:30	17⅜	6:30	21⅞	240	4½	53.33
4	24½	4-30	5:15	5-1	2:30	5-1	2:30	18⅛	6:30	21½	240	3⅜	71.1
5	23½	4-30	5:15	5-1	2:30	5-1	2:30	17½	6:30	22¼	240	4¾	50.526
6	24	4-30	5:15	5-1	2:30	5-1	2:30	17⅝	6:30	21⅜	240	3¾	64.00

Sum of Percolation Rates
Average of Rates:
Mean of Rates:

Eugene L Habrock
Signature of Person Conducting Test

Address 3093 Vine
Phone: 475-1682

(Do not write below this line) 600 800

REVIEWING ACTION

REMARKS:

Approved Percolation Rate(s)
A. 53 min./inch
B. _____ min./inch
C. _____ min./inch

DATE:

Ronald Maynard
Signature of Reviewing Official

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [ ]
County Resolution No. 2832 [X]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 807-C

DATE: 5-4-76

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 8N ; Range 7E ; Section 21 ; Block 1 ; Lot 3 ; Addition Jonathon Park 1st.
Street Address 6201 Rock .

2. Property Use: Residential [X]; Commercial [ ]
No. of Bedrooms 3
Describe:
Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank [ ]; Other [X] Lagoon

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Eugene L Hoburch
Signature of Applicant (owner or lessee)

3093 Union
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; 5-5-76
Filing Fee: $ 30 . 00

2. Site Visits:
Date: by:
Date: by:
Date: by:

3. Date: Approved [X]; Disapproved [ ] 5/5/76
by: Ron Magnuson

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: by:

	①	②	③	④	⑤	⑥
2:30	18	17 1/4	17 3/8	18 1/8	17 1/2	17 5/8
3:00	18 5/8	17 3/4	18 -	18 1/2	18 1/8	18 1/8
3:30	19 1/4	18 3/8	18 1/2	18 7/8	18 5/8	18 1/2
4:00	19 3/4	19	19 1/4	19 3/8	19 1/8	18 7/8
4:30	20 1/4	19 5/8	19 5/8	19 3/4	20 5/8	19 3/8
5:00	20 7/8	20 1/8	20 1/8	20 1/8	21	20
5:30	21 3/8	20 3/4	20 5/8	20 5/8	21 3/8	20 1/2
6:00	21 7/8	21 3/8	21 1/4	21 -	21 7/8	21
6:30	22 1/2	22	21 7/8	21 1/2	22 1/4	21 3/8
	5/8	5/8	5/8	1/2	5/8	3/8

① - 5/8 - .625
2 - 5/8 - .625
3 - 5/8 - .625
4 - 1/2 - .5
5 - 5/8 - .625
6 - 3/8 - .375

6 | 3.375
.563

53 min/circle