COLI N03 4/26/00 — 00060700 — 5/16/00 COLI

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY N03 5/8/00

This form must be completed and returned with payment to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: "Lincoln-Lancaster County Health Department" or "LLCHD"

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

LCR 4332

Legal Description of Property: Street Address 7800 Hickman Rd. Hickman LCN

Twp 8N Range 7E Section 27 1/4 SE 1/4 Block ___ Lot ___ Addition ___

Directions to Property Go S. to Saltillo Rd. Go S. 68TH to Hickman Rd (Corner of Caseys + First State Bank) then go East about 1 mile, Brick House on North side after x field

Location of Well East of the House just inside the Pasture area. Tap Location: Inside ☐ Outside ☐

Location of Sewage System SW of the House Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Donna Holsten RR for Lester Haake	142 Foothills Rd Benton, Ky 42025	270-474-0123
Tenant/Buyer: Buyer	Tiffiny Kunz Jason Critel	817 S. 29TH St Lincoln NE 68510	438-0500
Return to:	Kaz Lionberger c/o Woods Bros Realty	7141 "A" St Lincoln NE 68510	430-4074

Signature of Applicant Tiffiny J Kunz Address 817 S. 29TH Lincoln NE 68510 Date 4/18/00

HEALTH DEPARTMENT USE ONLY

RECEIVED		DATA ENTRY	
Date	04/25/00	Date	___/___/___
Initials	LS	Case No.	
Amount	150	Initials	
Check No.	985		

PRELIMINARY STATUS--By Jerrold C. Hood **DATE:** 4/26/00

WATER SYSTEM:	Approved	Disapproved
Construction	☒	☐
Bacteria	☒ 0 /ml	☐ ___ /ml
Nitrate	☒ ~~41.0~~ ppm THRU R.O. 41.0 P.M.	☐ 24.6 ppm 41.00

SEWAGE SYSTEM	
Approved	☐
Provisional	☒
Disapproved	☐

Additional Site Visits

Date 5/12/00 by LCH

Date 5/15/00 by LCH

Date 5/30/00 by LCH

Comments: SEPTIC SYSTEM PREDATES REGULATIONS. ALL OLD UNUSED WELLS MUST BE PROPERLY ABANDONED. 5/31/00 approval on water system is for that water only that comes through the treatment devices and only as long as the removal devices are properly maintained and operated. LCH

See Attached Letter ☒

FINAL STATUS

WATER SYSTEM: Approved ☒ **SEWAGE DISPOSAL SYSTEM:** Approved ☐ Provisional Approval ☒

Approved by Jerrold C. Hood R.E.H.S. Date 5/31/00

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 10-95

N03 VERIFICATION 5/12/00

COLI 5/15/00

Nebraska Health and Human Service
Regulation and Licensure - Laboratory Services
3701 South 14th Street
Lincoln, NE 68502
(402) 471-2122
(402) 471-2080 (fax)

JUN 5 2000

Laboratory Report Printed on **JUN-01-00**

LLCHD
LINCOLN LANCASTER COUNTY HEALTH DEPT.
JOHN CHESS
3140 N STREET
LINCOLN, NE 68510

Laboratory Analysis for: PRIVATE NITRATE

Sample Comments:

Laboratory Number: **P11685-25**
Sampled By: **JERROLD HOOD**
Location: **NG**
Well ID:

Date Collected **30-May-2000 09:35 AM**
Date Received: **30-May-2000**

Parameters	Report Level	Units	Method	Prep Date	Analysis Date	Analyst	Qual	Results
Nitrate+Nitrite (As N)	.05	mg/l	353.2		05/31/00	vr		3.1

Note: see reverse side of report for description of acronyms and data qualifiers
For inquiries on result interpretation call: (402) 471-2541