LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 ST. MARYS
LINCOLN, NEBRASKA 68502

FILE NO. 1795-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

DECEMBER 16, 1981 — THIS PERMIT EXPIRES

DARREL VER MAAS — ISSUED TO

BOX 3, HICKMAN NE 68372 — ADDRESS

T8N, R7E, Section 28, Lot 25 I.T. — LEGAL DESCRIPTION

NONTRANSFERABLE — REMARKS:

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 60.00	$	$	$ 60.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH — ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 60.00

FILE NO. 1795-C

DATE: 5-2-81

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 8N ; Range 7E ; Section 28 ;
   Block _____ : Lot 25 I.T. : Addition _____
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 2 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒ LAGOON

4. Distance to public sewer: 5,000 ft.

Darel V. Moore
Signature of Applicant (Owner or Lessee)

Box 3 Hickman Nebr.
Address

(Do not write below this double line)

artment: Date Rec'd. 6/15/81 . ACTION: Approved ☒ Disapproved ☐
Date Frwd. 6/16/81 . Signature: Jerrold C. Hood

: Date Rec'd. _____ . ACTION: Approved ☒ Disapproved ☐
Date Frwd. _____ . Signature: Myron Moser

te Rec'd. 6/16/81 . ACTION: Approved ☐ Disapproved ☒
Frwd. 6/16/81 . Signature: Larry V. Worrell

AL _____

INSTALLATION FINAL WRITTEN APPROVAL
Date: 8/14/81 By: Jerrold C. Hood

Copy

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

B

FILE NO. _____

PROPERTY WHERE SOIL TESTED:

Location: Township 8 ; Range 7 ; Section & ¼ Section 28 .
Property Dimensions: 309.94 ft. x 749.8 ft. Area: 5.34 acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☒ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 4-23 to 4-24 . Weather: Precip. 0 Temp. 63° .

OWNER: Darrel VerMaas

Address: Box 3 Hickman Nebr 68372

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	32"	4-23	1:00	4-24	5:00	4-24	5:00	8	5:30	8	30	0	30/0
2	32"	"	"	"	"	"	"	8	"	9	"	1	30/1
3	34"	"	"	"	"	"	"	7	"	8	"	2	30/2
4	33"	"	"	"	"	"	"	9½	"	18	"	1.5	30/1.5
5	34	"	"	"	"	"	"	9	"	10	"	1	30/1
6	36	"	"	"	"	"	"	8	"	8	"	0	30/0

Darrel Vs Maas
Signature of Person Conducting Test

Address Box 3 Hickman Nebr 68372 Phone 792-2517

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____


(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): Dawnee Clay Loam
Date: June 15, 1981

Approved Percolation Rate (a)
A. 32 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official



54th St

House to Lagoon - 110'

8-30-81
fenced
weeds
signs
& gate

Doryl Der Mass 54th & Martell Rd
Bouwens Rlty


U.S. SUPPLY CO.

901 Farnam Street — Omaha, Nebraska 68102 — Phone (402) 341 0831
Air Conditioning

Copy of Hickman Sewage agreement

5-29-81 - Lagoon slope 3½-1
15 Bags of Bentonite
21' inside edge of Dike
to water pressure line

6-15-81
Wes Bowman said that they put on additional bentonite
pressure line moved - now 32'
from inside edge of dike



8-20-81 - fenced