LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1422-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

March 29, 1979 — THIS PERMIT EXPIRES

Douglas Duff RFD, Bennet, NE 68317 — ISSUED TO / ADDRESS

T8N, R8E, Section 1 (N 1/20 of SE¼) — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE (Alter, Extend)

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 15.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY	DATE	AMOUNT
T. Lloyd	9-29-78	1 Fee

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH — ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

17 South

FILE NO. 1422-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: September 25, 1978

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☒, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 8N; Range 8E; Section 1; NW¼ SE¼;
Block _____; Lot _____; Addition _____
Street Address RFD Bennet, Neb

2. Property Use: Residential _____ ☒; Commercial _____ ☐
No. Bedrooms 4 Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: replacement of system; new bathroom on south side, discontinue use of old system and bathroom on north side, TANK 1250 gal. 100 ft. half moon in 4' trench

5. Work to be done by: Owner ☒; or ~~Contractor~~ and Contractor, Gerald A Sterns
Contractor's Name

6. Estimated cost of project:

a. Materials	$
b. Labor	$
c. Other	$
TOTAL	$ over → #200

Douglas Duff
Signature of Applicant (owner or lessee)

RFD Bennet
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 15.00

2. Site Visits:
Date: _____ by: _____
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: _____ by: _____

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

B

FILE NO. 1422-C

PROPERTY WHERE SOIL TESTED:

Location: Township 8N ; Range 8E ; Section & ¼ Section N½ of SE¼, Sec 1
Property Dimensions: _____ ft. x _____ ft. Area: 20 acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☒ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 9-21-78 to 9-22-78. Weather: Precip. _____ Temp. _____.

OWNER: Douglas J and Mary Duff
Address: Bennet Nebr 68317

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End		Elapsed	Water	
Hold No.	Hole Depth (in.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Water Level (in.)	Time (Hr./Day)	Water Level (in.)	Time (Min.)	Level Drop (in.)	Percolation Rates (Min./in.)
1	36"	9/21	9:00	9/22	9:00	9/22	11:00	6	11:10	1¼	10	4¾	2.1
2	36"	9/21	9:02	9/22	9:02	9/22	11:03	6	11:13	3½	10	2½	4
3	36"	9/21	9:04	9/22	9:04	9/22	11:04	6	11:14	2½	10	3½	2.9
4	36"	9/21	9:06	9/22	9:06	9/22	11:06	6	11:16	4	10	2	5
5	36"	9/21	9:08	9/22	9:08	9/22	11:08	6	11:18	3¾	10	2¼	4.4
6	36"	9/21	9:10	9/22	9:10	9/22	11:39	6	11:39	3¼	10	2¾	3.6

Doug Duff
Signature of Person Conducting Test

Sum of Percolation Rates: 22
Average of Rates: 3.6
Mean of Rates: 3.6

Address Bennet Nebr Phone 782-8125

(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): Shelby Clay Loam
Date: September 29, 1978

Approved Percolation Rate (a)
A. 3 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official

029

Lincoln-Lancaster County Health Department

2200 St. Mary's Avenue, Lincoln, Nebraska 68502 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

This form must be completed and returned to reques

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☑ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☑ Evaluation of the Sewage Disposal System LAGOON

Legal Description of Property: Street Address 12303 S 190th Bennett

Twp 8N Range 8E Section 1 1/4 1/4 Block Lot Addition

Directions to Property Hwy 2 East to Hwy 43; Hwy 43 South 1 mile to Saltillo Rd Saltillo Rd East 2¼ miles to 190th St; 190th St South ½ mile - yellow house on west side and

Location of Well RURAL WATER Tap Location: Inside ☐ Outside ☐

Location of Sewage System south of house Year Installed '79 ?

	NAME	ADDRESS	PHONE
Present Owner:	MARY DUFF	12303 S 190th Bennett, NE	782-8034
Tenant/Buyer:	Jack & Judy Johnson	Box 38 Merriman, NE 69218	308-684-3378
Return to:	CYNTHIA GARTON (REALTOR)	1141 "A" ST LINCOLN, NE 68510	483-4941

X

Signature of Applicant Address (TEMP) 6636 S 34th Date 1/10/95

LINCOLN, NE 68514 (421-6638)

HEALTH DEPARTMENT USE ONLY

Date Received 01/11/95 Received $150.00 Check ☑ Cash ☐ #3240

PRELIMINARY STATUS--By Jerrold C Nood DATE: 1/12/95

RURAL WATER DISTRICT 3/13/95 by J.C.H.

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM	Additional Site Visits
Construction	☐	☐	Approved ☐	Date / / by
Bacteria	☐ /ml	☐ /ml	Provisional ☐	Date / / by
Nitrate	☐ ppm	☐ ppm	Disapproved ☑	Date / / by

Comments: LAGOON UNFENCED. TREES AND BRUSH MUST BE REMOVED FROM AROUND LAGOON. JUNK SOUTHWEST AND WEST OF HOUSE MUST BE REMOVED. Lagoon fenced but gate not secured or locked. No warning signs on fence. 3/13/95 When growing season starts again in spring, cattails must be killed out, J.C.H.

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☐ RURAL WATER DISTRICT 3/13/95

SEWAGE DISPOSAL SYSTEM Approved: ☑ Provisional Approval: ☐

Approved by Jerrold C. Nood R.E.H.S. Date 3/13/95

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

2/24/95 JUNK OUT, GATE UP, SIGNS UP, STILL SOME TREES TO GO.

MICKEY HALL N.B.C. FAX 434-4816