01091 0006

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

This form must be completed and returned with payment to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: "Lincoln-Lancaster County Health Department" or "LLCHD"

☒ Enclosed is $200.00. Allow two weeks for processing. Incomplete information will delay processing.

LCR 4636

Legal Description of Property: Street Address 14800 Bennet Road

Parcel ID 21 - 03 - 300 - 001 - 600 (i.e. 99-99-999-999-999)

Twp 8N Range 5E Section 3 1/4 SW 1/4 Block ___ Lot 46 Addition ___

Directions to Property 3

Location of Well ___ Tap Location: Inside ☐ Outside ☐

Location of Sewage System Approx 50' S.E. of House Year Installed ?

Site Hazards (dogs, etc.) ___

	NAME	ADDRESS	PHONE
Present Owner:			
Tenant/Buyer:	Kathleen Tenopir	4351 Allendale Dr. Lot 11	483-7372
Return to:	CAPITOL TITLE ATTN: (TINA)	SUITE 150, 4645 NORMAL BLVD. LINCOLN, NEBRASKA	434-3737 434-3736 (Fax)
Signature of Applicant	Kathy Tenopir	Address 4351 Allendale Dr. Lincoln NE 68506	Date 8/22/01

HEALTH DEPARTMENT USE ONLY

RECEIVED Date 08/28/01 Amount 200.00 Check No. 3283 Initials ks MAIL

DATA ENTRY Date ___/___/___ Case No. ___ Initials ___

PRELIMINARY STATUS--By Carroll C. Hood **DATE:** 8/30/01

RURAL WATER

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM	
Construction	☐	☐	Approved	☐
Bacteria	☐ ___/ml	☐ ___/ml	Provisional	☒
Nitrate	☐ ___ppm	☐ ___ppm	Disapproved	☐

Additional Site Visits

Date 9/6/01 by J.C.H.

Date ___/___/___ by ___

Date ___/___/___ by ___

Comments: CHECK OPEN ENDED PIPE TO EAST. CHECK COVERED AREA NEXT TO DECORATIVE WINDMILL. CHECK CISTERN APPEARING STRUCTURE NORTH OF HOUSE. BAMBI GLEASON IS REALTOR. Owner says open ended pipe is interceptor drain for natural wet spot. Covered area near windmill is well ☐ See Attached Letter

FINAL STATUS

WATER SYSTEM: Approved ☒ RURAL WATER **SEWAGE DISPOSAL SYSTEM:** Approved ☐ Provisional Approval ☒

Approved by Carroll C. Hood R.E.H.S. Date 9/10/01

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

SEPTIC SYSTEM APPARENTLY PREDATES PERMITS AND INSPECTIONS HENCE APPROVAL IS PROVISIONAL.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 9-00

well in use for livestock. Cistern should be properly abandoned. Septic tank should be checked to see if it is in need of pumping.