9708140002
T-38157

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

check # 1115

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☒ Evaluation of the Sewage Disposal System

Legal Description of Property: Lot 67, of Irregular Tracts, Located in the SE¼ of Section 3, T8N, R8E Street Address 65 Apple Bennett Ne. 3404

Twp T8N Range R8E Section 3 1/4 SE 1/4 Block ___ Lot 67 Addition ___

Directions to Property Three Blocks west of Hwy 43 in Bennet - South Side

Location of Well None - City water Tap Location: Inside ☐ Outside ☐

Location of Sewage System North Side of House - Front yard Area Year Installed 1976

	NAME	ADDRESS	PHONE
Present Owner:	Terry & Karen Hatcher	65 Apple Bennett Ne.	782-8043
Tenant/Buyer:	DEANNA KAPKE	3003 Sequoia Dr Lincoln Ne 68516	420-5505
Return to:	Marlin Lyon	NBC BANK (Loan Office) 3934 So. Lincoln Ne 68510	434-4277

Signature of Applicant Deanna Kapke Address 3003 Sequoia Dr Lincoln Ne 68516 Date 8/4/97

HEALTH DEPARTMENT USE ONLY

Date Received 08/11/97 Received $150.00 Check ☒ Cash ☐ #1115

PRELIMINARY STATUS--By Paul Dittmann **DATE:** 8/12/97

WATER SYSTEM:	Approved	Disapproved
Construction	☐	☐
Bacteria	☐ _____/ml	☐ _____/ml
Nitrate	☐ _____ppm	☐ _____ppm

SEWAGE SYSTEM	
Approved	☐
Provisional	☒
Disapproved	☐

Additional Site Visits
Date ___/___/___ by ____
Date ___/___/___ by ____
Date ___/___/___ by ____

Comments: Tank should be pumped if not done in past 2 years. No records of inspection during installation of septic system there by only provisional approval can be granted. No visible signs of malfunction. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ Public Water **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☒

Approved by Paul Dittmann Date 8/12/97

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.