LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 794-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — October 14, 1976
TYPE OF PERMIT — THIS PERMIT EXPIRES

Robert Helter — 4200 North 44
ISSUED TO — ADDRESS

T8N; R8E; Sec. 17-8-8; LAGOON
LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

FRANK JOLDEN, Lancaster County Treasurer
VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 794-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: _____

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 8N; Range 8E; Section 17
   Block _____; Lot 3 I.T.; Addition _____
   Street Address _____

2. Property Use: Residential _____ ☒ ; Commercial _____ ☐
   No. of Bedrooms 3.
   Describe: _____
   Other Use _____ ☐
   Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒

4. Distance to public sewer: ✓ ft.

15710 So. 120th

Robert Helter
Signature of Applicant (Owner or Lessee)

4200 To #4
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 4-16-76. Date Frwd. 4-16-76. ACTION: Approved ☒ Disapproved ☐ Signature: Ronald Margent

2. Supt. Bldg. Insp.: Date Rec'd. _____. Date Frwd. _____. ACTION: Approved ☐ Disapproved ☐ Signature: _____

3. City or County Engineer: Date Rec'd. 4-20-76. Date Frwd. 4-20-76. ACTION: Approved ☒ Disapproved ☐ Signature: Leroy Graf
Asst Manager 4/20/76

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [ ]
County Resolution No. 2832 [X]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 794-C

DATE: 3-28-76.

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 8N ; Range 8E ; Section 17 ; Block ; Lot 3 I.T. ; Addition .
Street Address Route 8.

2. Property Use: Residential ✓ [ ]; Commercial [ ]
No. of Bedrooms 2.
Describe:

Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank [ ]; Other [✓]

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Robert Helton
Signature of Applicant (owner or lessee)

4200 N 44
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; 4-16-76
Filing Fee: $ 30 . 00

2. Site Visits:
Date: 4-13-78 by:
Date: 1/29/82 by: L.C.H. still need fence + drawing
Date: by:

3. Date: Approved [X]; Disapproved [ ]
by: Ronald Mayeur

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: by:

FORM HD- 43(73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 475-6221)

FILE NO. 794-C

PROPERTY WHERE SOIL TESTED:
Location: Township 8 ; Range 8
Section & ¼ Sect. 17-8-8.
Property Dimensions: 1700 ft. x 1700 ft.
Area: 25 acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay [X]; Silty Clay Loam [ ]; Sandy Loam [ ]
Silty Loam [ ]; Clay Loam [ ]; Sandy Clay [ ]

Owner: Robert Heltzi
Address 4200 No 44

Dates of Tests: 3-27-76 to 3-28-76. Weather: Precip. NONE Temp. 50°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36	3-27	1:30	3-27	4:00	3-28	9:15	30"	12:00	30"	60	0	
2	35	"	"	"	"	"	"	27¾	"	27¾	"	0	
3	35	"	"	"	"	"	"	27	"	27	"	0	
4	36	"	"	"	"	"	"	27¾	"	27¾	"	0	
5	37	"	"	"	"	"	"	28	"	27	"	1	

Sum of Percolation Rates
Average of Rates:
Mean of Rates:

Robert Heltzi
Signature of Person Conducting Test

Address 4200 No 44.
Phone: 464-3352.

(Do not write below this line)

REVIEWING ACTION

REMARKS: percolation is too slow for a septic system. A sewage stabilization pond is recommended

Approved Percolation Rate(s)
A. _____ min./inch
B. _____ min./inch
C. _____ min./inch

DATE: 4-16-76

Ronald Magnuson
Signature of Reviewing Official

The W 1089.0 of SW¼ Section 17-8-8.
of th 6th PM Lancaster County, Neb. except
th S 1634.88 thereof.

Contractor : Terry Bourne

517.69
517.69
599.50
1634.88