LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1613-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

April 22, 1980 — THIS PERMIT EXPIRES

R. Edward Hall — ISSUED TO

1535 Crestline Drive, Lincoln, NE — ADDRESS

T8N; R8E 4th PM, Section SE¼ of NW¼ of Section 20 — LEGAL DESCRIPTION

NONTRANSFERABLE — REMARKS:

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 60.00	$	$	$ 60.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH — ISSUING OFFICER

2832

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. _____

20109-0977

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☑

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $60.00

FILE NO. 1613-C

DATE: 11-22-79

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 8N ; Range 8E Section SE¼ of NW¼ of Sec. 20
   Block _____ : Lot _____ : Addition _____
   Street Address _____

2. Property Use: Residential ☑ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 2 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☑ Waste Stabilization Pond

4. Distance to public sewer: 6 miles ~~ft.~~

R. Edward Hall
Signature of Applicant (Owner or Lessee)

1535 Crestline Dr.
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 10/22/79. Date Frwd. 10/22/79. ACTION: Approved ☑ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk: Date Rec'd. _____. Date Frwd. _____. ACTION: Approved ☑ Disapproved ☐ Signature: Don S. Herz

3. City or County Engineer: Date Rec'd. 10-22-79. Date Frwd. 10-22-79. ACTION: ~~Approved~~ ☑ Disapproved ☐ Signature: Henry J. Raff

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 11-19-79 by: JW
Date: 6/23/81 by: D.S. Renee only
Date: _____ by: _____

INSTALLATION FINAL WRITTEN APPROVAL
Date: 6/23/81 By: D.S.

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

C

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO. 1613-C

Indicate on sketch if residence and well are exisiting or proposed.



REVIEWING ACTION

Remarks: _____

Date: October 22, 1979

Minimum Design Requirement
1. Capacity of Septic Tank _____ gals.
2. Total Length of Laterals _____ ft.
3. With a Trench Width of _____ in.
4. Total Area of Lateral needed ____ sq.ft.

Jerrold C. Hood
Signature of Reviewing Official

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

B

FILE NO. 1613-C

PROPERTY WHERE SOIL TESTED:

Location: Township 8N ; Range 8E 6PM; Section & ¼ Section S.E.Q. of N.W.Q. of Sec 20
Property Dimensions: _____ ft. x _____ ft. Area: 40 acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 10-16-79 to 10-17-79 . Weather: Precip. 0 Temp. 70°.

OWNER: R. Edward Hall

Address: 1535 Crestline Dr.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	35	10/16	12:15	10/17	12:15	10/17	12:15	25 7/8	12:45	25 7/8	30	0	
2	31	10/16	12:20	10/17	12:20	10/17	12:20	21 4/8	12:50	21 5/8	30	1/8	240
3	32	10/16	12:25	10/17	12:25	10/17	12:25	22 3/8	12:55	22 4/8	30	1/8	240
4	26	10/16	12:27	10/17	12:27	10/17	12:27	16 1/8	12:57	16 1/8	30	0	
5	34	10/16	12:30	10/17	12:30	10/17	12:30	24 1/8	1:00	24 1/8	30	0	
6	28	10/16	12:32	10/17	12:32	10/17	12:32	18 3/8	1:02	18 3/8	30	1/8	240

R. Edward Hall
Signature of Person Conducting Test

Address 1535 Crestline Dr. Phone 488-6060

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

(Do not write below this line)

REVIEWING ACTION


Remarks: _____

Soil Type (SCS): Pawnee Clay Loam

Date: October 22, 1979

Approved Percolation Rate (a)
A. 480 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official



As-Built Site Plan
R. Edward Hall
1535 Crestline Dr.
Lincoln Ne
68506

Lagoon + New Residence
At 120th + Roca Rd. ½ mi. so + ½ mi E.
Permit No. 1613-C