LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2744

FILE NO. 1160-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

March 6, 1978 — THIS PERMIT EXPIRES

Gordon Winton — ISSUED TO

1500 Pioneers, Lincoln, NE 68502 — ADDRESS

T9N, R5E, Section NE¼ of 3

LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

9-8-77

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒

County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1160-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: August 9 1977

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

SEE ATTACHED

1. Legal description of property: Twp. 9N ; Range 5E ; Section NE¼ 3
   Block _____; Lot _____; Addition _____
   Street Address Denton Road

2. Property Use: Residential _____ [X] ; Commercial _____ [ ]
   No. of Bedrooms 3 . Describe: _____
   Other Use _____ [ ]
   Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X] ; Other [ ]

4. Distance to public sewer: N/A ft.

Note: Attatched descriptions contains errors to be corrected & corrective deed filed. The tract is ~~outlined~~ shown on the attached sketch ~~correctly~~ except for the dimensions ~~corrected~~ to be corrected by the surveyor & shown in the corrective deed.

Gordon Winton
Signature of Applicant (Owner or Lessee)
c/o Pottyco Plbg Co.
1520 PIONEER BLVD. LINCOLN 68502
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 8/30/77 . Date Frwd. 8/6/77 . ACTION: Approved [X] Disapproved [ ] Signature: Jerrold C. Hood
2. Supt. Bldg. Insp.: Date Rec'd. _____ . Date Frwd. 9-7-77 . ACTION: Approved [X] Disapproved [ ] Signature: Tom Baasch
3. City or County Engineer : Date Rec'd. 9-7-77 . Date Frwd. 9-7-77 . ACTION: Approved [X] Disapproved [ ] Signature: Henry Krafft

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 [X]
County Resolution No. 2832 [X]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1160 C

DATE: August 9, 1977

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto. SEE ATTACHED

1. Legal description of property: Twp. 9N ; Range 5E ; Section NE¼ 3 ; Block ; Lot ; Addition .
Street Address Denton Road .

2. Property Use: Residential [X] Commercial [ ]
No. of Bedrooms 3
Describe:
Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Gordon Denton
Signature of Applicant (owner or lessee)

c/o Pottyco Plbg Co.
1520 Pioneer Blvd. Lincoln, Ne.
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
Filing Fee: $ 30.00

2. Site Visits:
Date: 9/7/77 by: J.C.H.
Date: by:
Date: by:

3. Date: Approved [X]; Disapproved [ ] 8/30/77
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 9/8/77 by: Jerrold C. Hood

FORM HD- 43(73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 475-6221)

FILE NO. 1160-C

PROPERTY WHERE SOIL TESTED:
Location: Township 9N; Range 5E
Section & ¼ Sect. NE¼ 3
Property Dimensions: IRREG. ft. x ____ ft.
Area: 6.3 acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☐

Owner: Gordon Winton
Address Denton Road

Dates of Tests: July 28 to July 29. Weather: Precip. dry Temp. 90°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	32	7/28	9:00 AM	7/29	9:30 AM	7/29	2:30	7	3:00	5 3/4	30	1¼	
2	32						2:30	6	3:00	5	30	1	
3	32						2:40	6	3:10	4 7/8	30	1⅛	
4	32						2:40	6½	3:10	5 5/8	30	⅞	
5	32						2:50	6	3:20	5¼	30	¾	
6	32						2:50	6	3:20	5⅛	30	⅞	

Sum of Percolation Rates
Average of Rates:
Mean of Rates:

Don Pentico
Signature of Person Conducting Test

Address Pettyco P/log. 1520 Pioneer
Phone: 423-0121

(Do not write below this line)

REVIEWING ACTION

REMARKS: Judson Silt Loam (J.C.d.) Confirmed at least part of system (north) 9/8/77

DATE: August 30, 1977

Approved Percolation Rate(s)
A. 30 min./inch
B. ____ min./inch
C. ____ min./inch

Jerrold C. Hook
Signature of Reviewing Official

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1160-C

SPECIFICATIONS

DATE: August 9, 1977


A. BUILDING SEWER:
1. Material cast iron; Diameter 4 in.
2. Distance above basement floor 30 in.; or below basement floor ___ in.
3. Distance between dwelling and septic tank 50 ft.
4. Number of clean-outs 0.
5. Distances To:
Well or Suction Line 200 ft.;
Stream 240 ft.; Pressure Line 80 ft.;
Property Line 60 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material fiberglass; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth ___ in.
3. Factory Built: Yes ☒ (Company calvary) No ☐
4. Manholes: Over Inlet; diam. 20 in.
Over Outlet; diam. ___ in.
Below Grade 30" in.
5. Inlet: Baffle ☐; or Tee ☒
6. Outlet: Baffle ☐; or Tee ☒
Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade 30" in.
8. Distances To:
Well or Suction Line 80 ft.;
Stream 280 ft.; Pressure Line 60 ft.;
Property Line 140 ft.

C. DISTRIBUTION BOX
1. Material fiberglass; No. available outlets ___.
2. Factory Built: Yes ☒, (Company calvary -) No ☐
3. Dimension: Length ___ in.; Width ___ in. Depth ___ in.
4. Distance from Septic Tank 10 ft.
5. Serial Distribution: Yes ☐, No ☒ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: 4" Perf. Plastic Pipe
2. Lateral Lines: Depth below grade 36 in. Number ___; Length of each line ___ ft. Total length of Laterals 250 ft.; Slope 6" in/100 ft. Diameter of pipe 4 in.; Shape Round Material: concrete ☐; fiber asbestos ☐; clay ☐; other P.V.C. Distance between lateral lines 10 ft.
3. Trench Dimensions: Depth 36 in.; Width 36 in.
4. Filter Material: gravel. Depth of material from trench bottom 6-8 in.
5. Distances To:
Well or Suction Line 80 ft.;
Stream 180 ft.; Pressure Line 60 ft.
Property Line 60 ft.
6. Percolation Rate: 30 minutes/inch

TYPICAL SKETCHES



SEPTIC TANK

DISTRIBUTION BOX

TRENCH & LATERAL

Signature of Applicant

OFFICIAL SURVEY RECORD

LANCASTER COUNTY, NEBRASKA


Survey of: I.T. in Part of the Northeast ¼,
Section 3, T 9 N, R 5 E,
of 6th. P.M.

County Survey No. ____

Surveyor's Proj No. ____

Date July 13 1974 Weather 100°

Field Notes: Origin of Survey, descriptions of corners found and restored; distances chained; angles measured



Pipes set at all points marked thus °


Gordon Winton

Signed this 15 day of July 1974

Name: Eugene R. Schug

Surveyor's license No. L.S. 288

Land Surveyor's Seal


Well
House
5' cast IRON
45'
TO GROUND SURFACE
10'
10'6" solid
6'8" solid
5'2"
15'
14'
75'
100'
63'
22'
20'
24'
Fenced Lot Line
S
N