LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

3140 "N" STREET ENVIRONMENTAL HEALTH DIVISION (402) 441-8000

Lincoln, NE 68510-1514

NON TRANSFERABLE

PERMIT

Permit

SEWAGE SYSTEM REPAIR

No. 95390045701

Issued 07/24/95
Expires 01/24/96
Revenue Code 18754

Establishment

PAUL DAY
T9N R5E SEC 4
10705 W VAN DORN ST

FEES: $50.00

TOTAL $50.00

Permittee

BRAD SOUTHWICK
17201 S 72 ST
HICKMAN NE 68372

Issued By M. Jane Ford
Health Director

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW "POST IN A PROMINENT PLACE"

FORM HL-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. 953900457

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 7-21-95

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☒, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 9N ; Range 5E ; Section 4 ;
Block ____ ; Lot ____ ; Addition ____
Street Address 10705 West Van Dorn

2. Property Use: Residential ____ ☒; Commercial ____ ☐
No. Bedrooms ~~2~~ 3 BS
Describe ____
Other Use ☐
Describe ____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: install 1,000 gal tank
± 190' of Perforated Pipe lateral

5. Work to be done by: Owner ☐ ; or Contractor ☐ , Southwick Sewer & Drain
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$ 2400	00

Paul Day by Brad Southwick
Signature of Applicant (owner or lessee)

10705 West Van Dorn 17201 S. 72
Address
Hickman Ne

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: ____
Filing Fee: $ 50.00

2. Site Visits:
Date: 7/19/95 by: D.C.H.
Date: 7/19/95 by: D.C.H.
Date: 7/21/95 by: D.C.H.

3. Date: Approved ☒; Disapproved ☐
by: Jerold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 7/31/95 by: J.C. Hood

Lincoln-Lancaster County Health Department

ENVIRONMENTAL HEALTH DIVISION
3140 N STREET · LINCOLN, NE 68510-1514 (402) 441-8000

Permit

SEWAGE SYSTEM REPAIR
SEWAGE REPAIR-ADD LATERAL

Permit # 00390068301

Issued 11/01/00
Expires 05/01/01
Revenue Code 3157

Establishment

PAUL DAY
T9N R5E SEC 4
LOT 18
10705 W VAN DORN ST-DENTON

FEES: $100.00

Permitee

PAUL DAY
10705 W VAN DORN ST
LINCOLN NE

TOTAL: $100.00

Leon F. Vinci, MPH, Health Director

• POST IN A PROMINENT PLACE • NOT TRANSFERABLE

013880

Application to Alter, Extend or Repair an Individual Sewage Disposal System

Paul Day

☐ Municipal Code 24.38 ☒ County Resolution Number 2832

The undersigned hereby applies for a permit to: ☐ **ALTER** ☐ **EXTEND** ☒ **REPAIR** an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. **Legal description of property:**
   Township 9 Range 5 Section 4 1/4 Section _____
   Block North part Lot 18 Addition _____
   Parcel ID ____-____-_____-_____-_____ (i.e. 99-99-999-999-999)
   Street Address 10705 W. Van Dorn St. Denton Ne. 68339

2. **Property use:** ☒ residential ☐ commercial ☐ other use
   Number of bedrooms 2 Describe _____

3. **Type of Present Individual Disposal System** ☒ septic tank ☐ lagoon ☐ other

4. **Description of proposed alteration, extension or repair** - Add less than 100' of lateral.

5. **Work to be done by:** ☒ owner ☐ contractor's name —

6. **Estimated project:** a. Repair, replace or minor extension with a cost less than $400 (no fee required).
   (b.) Total cost is greater than $400 (Return fee with this application) 430-0108
   c. A "construction permit" is required if the use, operation, location, or type of the system is being change.

Print Name PAUL L DAY Address 10705 West Vandorn work 479-5452 Phone 477-2263
Applicant Signature (owner or lessee) _____

Please include the permit fee ($100) with this application
Fee must be included before the application will be processed. Incomplete information will delay processing

---

HEALTH DEPARTMENT USE ONLY

Date received 10/31/00 REVIEW: ☒ Approved ☐ Disapproved By: Doug Smith

Site visits
Date 10/06/2000 By DS
Date ____/____/____ By _____
Date ____/____/____ By _____


Installation final written approval
Date 11/06/2000 By Doug Smith

Return application to: Lincoln-Lancaster County Health Department - Environmental Health Division
3140 "N" Street, Lincoln, NE 68510
Phone: 441-8022

Business Office Use Only
Received: Date: 11/01/00 Amount 100 ⁰⁰ Check No. 4786 Initials AS

White - Division Copy Pink - Business Office Revised 9/00

2000


West Vandorn St. Denton NE.
10705
HOUSE
Parking Area
Lift Station
3'
42'
well
well
101'
64'
20'
existing lateral
existing lateral
76'
FENCE
Property line ~ 200'
Sewer line
50'
FENCE
WATER WAY
20" Drop
40'
Junction Box 14' from Corner of Bldg
20" Drop
40'
19'
17'
FENCE

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☒ Evaluation of the Individual Water System ☒ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 10705 W. Van Dorn Denton, NE 68336

Twp 9N Range 5E Section 4 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition ___

Directions to Property Approximately 8 miles west of 1st Street, Lincoln, NE

Location of Well ___ Tap Location: Inside ☐ Outside ☐

Location of Sewage System ___ Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Michael K. Becker Tammy S. Becker	10705 W. Van Dorn Denton, NE 68336	476-6676
Tenant/Buyer:	Paul L. Day Debbora A. Day	3727 Dunn Ave. Lincoln, NE 68502	423-0621 479-5552
Return to:	Capitol Title Co. MARILYN	P.O. Box 6577 Lincoln, NE 68506	434-3737

Signature of Applicant Debbora A. Day Address 3727 Dunn Ave Lincoln, NE 68502 Date 05/03/95

HEALTH DEPARTMENT USE ONLY

Date Received 5/15/95 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By Jerrold C. Hoag **DATE:** 5/15/95

7/2/95 by J.C.H.

WATER SYSTEM:	Approved	Disapproved
Construction	☒	☐
Bacteria	☒ 0 /ml	☒ 4 /ml
Nitrate (treated)	☒ 0.5 ppm	☒ 15.1 ppm

SEWAGE SYSTEM
Approved ☐
Provisional ☐
Disapproved ☒

Additional Site Visits
Date 6/19/95 by ___
Date 7/19/95 by J.C.H.
Date 7/19/95 by J.C.H.

Comments: IF THE WELL UNDER THE WIND MILL IS NOT GOING TO BE USED THEN IT MUST BE PROPERLY ABANDONED. SOME PORTION OF THE SEWAGE SYSTEM DRAINS OUT BEHIND THE METAL SHED. Provisional approval on sewage system because of poor soil percolation test. J.C.H. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☒

Septic System. On water only that water coming through the reverse Osmosis unit and only as long as the unit is properly operated and maintained.

Approved by Ron Magnuson Date 7/24/95

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.