006

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

This form must be completed and returned with payment to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: "Lincoln-Lancaster County Health Department" or "LLCHD"

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

Legal Description of Property: Street Address 12000 W. Denton Rd.

Twp 9N Range 5E Section 5 1/4 ___ 1/4 ___ Block ___ Lot 61 Addition ___

Directions to Property ___

Location of Well ___ Tap Location: Inside ☐ Outside ☐

Location of Sewage System ___ Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Paula Noble		467-4466
Tenant/Buyer:			
Return to:	Christo Const. Co. 641 So. 21st Lincoln, NE.	68510	432-0590

Signature of Applicant Jim Quick Address 641 So. 21st Date 9/16/96

HEALTH DEPARTMENT USE ONLY

RECEIVED

Date 9/16/96
Initials T.C.H
Amount 150.00
Check No. 21237

DATA ENTRY

Date ___/___/___
Case No. ___
Initials ___

PRELIMINARY STATUS--By Jerrold C. Hood **DATE:** 9/16/96

WATER SYSTEM:	Approved	Disapproved
Construction	☒ P.D 12-27-96	☒
Bacteria	☒ 0 /ml	☐ ___ /ml
Nitrate	☒ 0.6 ppm 1-3-97	☒ 20.4 ppm

SEWAGE SYSTEM	
Approved	☐
Provisional	☐
Disapproved	☒

Additional Site Visits

Date 12/27/96 by P.D.
Date ___/___/___ by ___
Date ___/___/___ by ___

Comments: WELL NOT FINISHED OFF. ALSO DEPRESSIONS AROUND AND WITHIN TEN FEET OF WELL. TREES IN AND AROUND LAGOON. FENCE IN BAD SHAPE AND NOT 4 FEET HIGH. NEED WARNING SIGNS. See Attached Letter ☐ NEED MORE BERM ON UPHILL SIDE. LAGOON NEEDS TO BE SLIGHTLY LARGER.

FINAL STATUS BROKEN CLEANOUT AND CAP NEED TO BE REPLACED. NO RECORD OF THIS LAGOON. 12-27-96 FENCE ERECTED. WATER SAMPLES COLLECTED P.D.

WATER SYSTEM: Approved ☒ **SEWAGE DISPOSAL SYSTEM:** Approved ☐ Provisional Approval ☒


Approved by Jerrold C. Hood R.E.H.S. Date 1/3/97

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 10-95

* APPROVAL IS FOR WATER RUN THROUGH THE REVERSE OSMOSIS UNIT ONLY.


N
CO
8'
120
NW Denton
Rd
27'
CO
5'8" Deep