Lincoln-Lancaster County Health Department

ENVIRONMENTAL PUBLIC HEALTH DIVISION

3140 N STREET · LINCOLN, NE 68510-1514

003673

(402) 441-8000

Permit SEWAGE SYSTEM REPAIR
SEWAGE REPAIR-REPLACE CRUSHED SEWER PIPE

Permit # 04390077801

Issued 02/25/04
Expires 08/25/04
Revenue Code 3157

Establishment LEWIS KAVAN
T9N R5E SEC 8 QTR NE
LOT 21IT
4447 SW 112 ST-DENTON

FEES: $100.00

Permittee LEWIS KAVAN
4447 SW 112 ST
DENTON NE 68339

TOTAL: $100.00

Bruce D. Dart

Bruce D. Dart, Health Director

EPH COPY

Individual Sewage Disposal System
Application to Alter, Extend or Repair

☐ Municipal Code 24.38 ☒ County Resolution Number 2832

Date: Feb 25-04	File No.: 043900778

The undersigned hereby applies for a permit to: ☐ **ALTER** ☐ **EXTEND** ☒ **REPAIR** an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. **Legal description of property:**
   Township 9N Range 5E Section 8 1/4 Section NE 1/4
   Block _____ Lot 2 F.I. Addition _____
   Street Address 4447 S. W. 112th - Denton, NE 68339

2. **Property use:** ☒ residential ☐ commercial ☐ other use
   Number of bedrooms _____ Describe _____

3. **Type of Present Individual Disposal System:** ☐ septic tank ☒ lagoon ☐ other

4. **Description of proposed alteration, extension or repair:** replace crushed sewer pipe

5. **Work to be done by:** ☐ owner ☐ contractor's name Yagner Const.

6. **Estimated project:** a. Repair, replace or minor extension with a cost of less than $400.00 (no fee required).
   b. Total cost is greater than $400.00 (Return fee with this application).
   c. A "construction permit" is required if the use, operation, location, or type of the system is being changed.

Print Name LEWIS KAVAN Address 4447 S. W. 112th Phone 402-795-6160
Applicant Signature (owner or lessee) Melvin Yagner Const.

Please include the permit fee ($50.00) with this application

(Please do not write below this line)

Date rec'd 2/25/04 cw REVIEW: ☒ approved ☐ disapproved By: Gerald C. Hood
CR# 3957 $100.00

Site visits:
Date _____ By _____
Date _____ By _____
Date _____ By _____

Installation final written approval

Date 12/1/04 By Doug Kruse

Return to: Lincoln-Lancaster County Health Department - Environmental Health Division
3140 "N" Street, Lincoln, NE. 68510
441-8022

White - EH Pink - Business Office Revised 1/98

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-780[illegible]

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER / LOA[illegible]

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 8/1/91

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 5E; SECTION 8; BLOCK NE¼

LOT 21; ADDITION NONE; Street Address 4455 S.W. 112

Directions to Property FROM SW 112 & WEST PIONEER GO SOUTH 1/8 MILE. SECOND DRIVEWAY.

Location of Well WEST OF HOUSE Tap Location: Inside ☐ Outside ☒

Location of Sewage System SOUTH OF HOUSE 100 YARDS Year Installed ____

	NAME	ADDRESS	PHONE
Present Owner:	LEWIS KAVAN	RR1 BOX 210 DENTON	795-6160
Tenant/Buyer:	SAME		
Return to:	SAME		

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Lewis J Kavan Address SAME

==========

HEALTH DEPARTMENT USE ONLY

Date Received AUGUST 1, 1991 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE AUGUST 2, 1991

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:	
Construction	☒	☐	Approved:	☐	Date 8/2/91	by C.H.
Bacteria	☒	☐	Provisional:	☐	Date 8/6/91	by C.H.
Nitrate	☒	☐	Disapproved:	☒	Date ____	by ____

Comments: NEED WARNING SIGNS ON LAGOON FENCE, FINISH MOWING, ADD WATER TO LAGOON, BUILD UP DIKE WHERE PIPE COMES INTO LAGOON. 8/6/91 Lagoon corrected. C.H. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☒	Provisional Approval: ☐

APPROVED BY Jerrold E. Hood R.S. DATE AUGUST 8, 1991

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832