012

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-7

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER /

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: April 20, 1992

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 5E; SECTION 8; BLOCK ____

LOT X; ADDITION ____; Street Address 4501 SW 112

Directions to Property 3rd house South of Pioneer on SW 112

Location of Well South Side of Chain link fense Tap Location: Inside ☒ Outside ☐

Location of Sewage System West of house Year Installed 77

	NAME	ADDRESS	PHONE
Present Owner:	Richard King	RI Box 21C Denton Ne 68339	795-6625
Tenant/Buyer:			
Return to:	American Charter C/O Sue Beckman	206 S 13th ST P.O. Box 82459 Lincoln 68501	435-3571

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Richard King Address RI Box 21C Denton 68339

==========

HEALTH DEPARTMENT USE ONLY

Date Received APRIL 21, 1992 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE APRIL 22, 1992

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:	
Construction	☒	☐	Approved:	☐	Date 4/22/92	by L.C.H.
Bacteria	☒	☐	Provisional:	☐	Date 4/27/92	by L.C.H.
Nitrate 5.4 p.p.m	☒	☐	Disapproved:	☒	Date ____	by ____

Comments: NEED WARNING SIGNS ON LAGOON, NEED GATE LOCKED SHUT, NEED DEAD VEGETATION CLEANED OUT OF LAGOON, NEED FENCE TIGHTENED UP & SECURED TO POSTS. all corrected 4/27/92 L.C.H. GOOD JOB! See Attached Letter ☐

WARNED ABOUT POSSIBLE LATER ACCUMULATION OF HORSE MANURE WITHIN 100 FEET OF WELL

FINAL STATUS

	WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
	Approved: ☒	Approved: ☒	Provisional Approval: ☐

APPROVED BY Jerrold C. Hood R.E.H.S. DATE APRIL 27, 1992

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

LOGICAL EXAMINATION OF DRINKING WATER

TO BE COLLECTED AND MAILED ON:

WK. ____ (2-3) DAY ____ (4) SAMP/DAY ____ (5) (6-7)

ACCOUNT NO. ____ (16-22) ADD. TESTS 2 (23) 1. FL 2. N 3. BOTH 4. TPC

DATE COLL. 4/22/92 3:00P.M. (9-16) MO./DAY/YR./HOUR BY L. C. Hood (17-28)

ADDRESS OR LOCATION SEC. 8, T9N, R5E (29-41)

NAME AND ADDRESS OF OWNER RICHARD KING
LINCOLN-LANCASTER COONTY
ENVIRONMENTAL HEALTH
2200 ST. MARY'S AVENUE
LINCOLN, NEBRASKA
68502

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

Source BUSINESS FORMS (402) 423-3450

FOR LABORATORY USE ONLY

SPECIAL REQUEST: ____ (42)
0. NONE 1. CHECK 2. REPLACEMENT

SAMPLE CONDITION: ____ (43)
1. GOOD 2. DAMAGED 3. INSUFFICIENT 4. OLD 5. RETURNED UNUSED

LABORATORY NO. 8540 (44-47)

DATE EXAMINED ____ (48-53)

COLIFORM 0 (54-56) /100 mL.

FLUORIDE ____ (57-60) mg/LITER

NITRATE ____ (61-64) mg/LITER

TPC ____ (65-68) /100 mL.

LAB. PROCEDURE ____ (69-75)

ANALIZED BY ____ (76-79)

IN APR 22 92 3:40

OUT APR 23 P4:52

WATER CHEMISTRY

STATE LAB NO. 15 2110

COMPLETE INFORMATION BELOW

DATE COLLECTED 4 (MO.) 22 (DAY) 92 (YEAR) 3:00 P.M. (HOUR)

SAMPLE COLLECTED BY JERROLD HOOD

SAMPLE LOCATION RICHARD KING

PROPERTY LEGAL DESCRIPTION: COUNTY LANCASTER

QRTR NE SECT 8 TWNSHP 9 N RANGE 5 E

NAME AND ADDRESS OF PERSON TO RECEIVE EXTRA REPORT:

PLEASE PRINT COMPLETE ADDRESS

THIS LAB REPORT IS TO BE MAILED TO:

LINCOLN-LANCASTER COUNTY
ENVIRONMENTAL HEALTH
2200 ST. MARY'S AVENUE
LINCOLN, NEBRASKA 68502

STATE OF NEBRASKA DEPARTMENT OF HEALTH LABORATORIES
3701 SOUTH 14th LINCOLN, NE 68502

FOR LABORATORY USE ONLY

TEST METHOD: USEPA METHOD 353.2

NITRATE ANALYSIS FOR DRINKING WATER

NITRATE — N 5.4 mg/l

NOT TESTED BECAUSE OF:
☐ INSUFFICIENT AMOUNT ☐ DAMAGE ☐ IMPROPER CONTAINER

TEST(S) BY

FOR ACCOUNTING USE ONLY

LWN 88

REPORTED APR 23 '92 P4:28

RECEIVED APR 22 '92 P3:50