LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

Division of Environmental Health
2200 St. Marys Ave Lincoln, NE 68502 (402) 471-8000

NON TRANSFERABLE

PERMIT

SEWAGE INSTALLATION

No. 91380070101

Issued 05/13/91
Expires 11/13/91

ESTABLISHMENT

DONALD PHILLIPS
T9N R5E SEC 26
WINSOR RIDGE WEST BLK 1 LOT 4

FEES: Permit 018754 $150.00

Total $150.00

PERMITTEE

DONALD PHILLIPS
5901 SPRUCE ST
LINCOLN NE 68516

Issued By COUNTY HEALTH

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE	
DATE	AMOUNT
5/20/91	PAID

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $ 150.00

FILE NO. _____

DATE: 05/13/91

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 5E ; Section 26 ;
   Block 1 : Lot 4 : Addition WINSOR RIDGE WEST
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 4 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

Donald A Phillips
Signature of Applicant (Owner or Lessee)

5901 SPRUCE LINCOLN, NE
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 5/13/91. Date Frwd. 5/13/91. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk: Date Rec'd. 5/13/91. Date Frwd. 5/13/91. ACTION: Approved ☒ Disapproved ☐ Signature: Paul Bauma

3. City or County Engineer: Date Rec'd. 5/13/91. Date Frwd. 5/13/91. ACTION: Approved ☒ Disapproved ☐ Signature: Ron Thomas

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 9/26/91 by: J. Cuff Sewer & tank in.
Date: 9/30/91 by: J. Cuff
Date: _____ by: _____

INSTALLATION FINAL WRITTEN APPROVAL
Date: 9/30/91 By: Jerrold Hood

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 23-43

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

B

FILE NO. _____

PROPERTY WHERE SOIL TESTED:

Location: Township _____; Range _____; Section & ¼ Section _____.
Property Dimensions: _____ ft. x _____ ft. Area: 5± acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐
Dates of Tests: 9-21-91 to 9-22-91. Weather: Precip. None Temp. 60's

OWNER: Phillips (Don & Kathy)

Address: 8701 SW 91st St Ct (Denton)

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Water Level (in.)	Time (Hr./Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	36	9/21/91	11:20A	9/21/91	5:10 PM	9/22/91	10:05AM	22 7/8	2:05 PM	23 3/4	30	7/8	
2	36	"	11:20A	"	5:10 PM	"	10:05AM	21 1/2	2:05PM	22 5/8	30	1 1/8	
3	36	"	11:20A	"	5:10PM	"	10:05PM	22	2:05PM	23	30	1	
4	36	"	11:20A	"	5:10PM	"	10:05AM	23 1/4	2:05PM	24 1/4	30	1	
5	36	"	11:20A	"	5:10PM	"	10:05AM	22 1/8	2:05PM	23 1/4	30	1 1/8	
6	36	"	11:20A	"	5:10PM	"	10:05AM	21 7/8	2:05PM	23 1/8	30	1 1/4	

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

D. Sc
Signature of Person Conducting Test

Address 4300 Lenox Ave 68510 Phone 488-3128

(Do not write below this line)

REVIEWING ACTION

Remarks: _____


Soil Type (SCS): _____

Date: _____

Approved Percolation Rate (a)
A. 28 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official

242'


SEPTIC TANK
APPX 130'
HOUSE
WELL
SW 81ST ST. CT.

Don & Kathy Phillips House

8701 SW 81st St. Ct. Denton, NE

