LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St. Marys Avenue Phone (402) 471-[illegible]8

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER / L[illegible]

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 9-10-90 $150.00

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is ~~$75.00~~

Legal Description of Property: TWP. [illegible]9N; RANGE [illegible]5E; SECTION [illegible]29; BLOCK ___

LOT 5; ADDITION _____; Street Address 8705 S.W. 119th Street

Directions to Property Denton, Nebraska From the 4 way stop in Denton go 2 miles West on West Denton Road, then 1¼ mile South on 119th Street. The house is to the west, a two-tone brown house. OR The house is 1/4 mile South of West Yankee Hill Road on SW 119th.

Location of Well to the west of house on hill at property line Tap Location: Inside ☒ Outside ☒

Location of Sewage System northeast corner of property Year Installed 1977

	NAME	ADDRESS	PHONE
Present Owner:	Elden Adden	4327 Starr Lincoln 68503	466-6158
Tenant/Buyer:	Lonnie Petrzilka	Rt. 1, Box 113, Pleasant Dale 68423	795-6395
Return to:	Ag-Land Realty, 225 No. Cotner Blvd., Suite 107, Lincoln NE 68505 Att: Sheryl	467-5263	

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant [signature] Address Ag-Land Realty 225 No. Cotner Blvd., Suite 107

HEALTH DEPARTMENT USE ONLY $150.00

Date Received SEPTEMBER 11, 1990 Received ~~$75.00~~ Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 9/12/90

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☐	☒	Approved:	☐	Date 9/12/90 by J.C.H.
Bacteria	☐	☐	Provisional:	☐	Date _____ by ___
Nitrate	☒	☐	Disapproved:	☒	Date _____ by ___

Comments: WELL IN PIT. SEWAGE SYSTEM BUILT WITHOUT PERMIT. TREES IN AND AROUND LAGOON. VEGETATION NEEDS CUTTING. LAGOON TOO CLOSE TO PROPERTY LINE. See Attached Letter ☐ NO FENCE AROUND LAGOON. PIPE COMING INTO LAGOON BROKEN. UNACCEPTABLE TAP FOR BACTERIAL SAMPLE. LAGOON DRY.

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☐	Approved: ☐	Provisional Approval: ☐

APPROVED BY _____ DATE _____

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832