LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 935-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — April 8, 1977
TYPE OF PERMIT — THIS PERMIT EXPIRES

Kenneth D. Mawwell — 3410 "X" Street, Lincoln, NE 68503
ISSUED TO — ADDRESS

T9N; R5E; Section NW NW SE¼ 29; Lot 1 I.T. (lagoon)
LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH
ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 934-C

DATE: 6 October 1976

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9 N ; Range 5E ; Section NW NW SE¼29 ; Block ; Lot 1 I.T. ; Addition .
Street Address 9300 SW 119th .

2. Property Use: Residential ☒; Commercial ☐
No. of Bedrooms 3
Describe:
Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☐; Other ☒

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Kenneth D Maxwell & Juanita L. Maxwell
Signature of Applicant (owner or lessee)

3410 "X" Street-Lincoln, NB. 68503
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
Filing Fee: $ 30.00

2. Site Visits:
Date: by:
Date: by:
Date: by:

3. Date: Approved ☒; Disapproved ☐ 10/8/76
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: by:

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 934-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 6 October 1976

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 05E; Section NW NW SE¼ 29
Block ____; Lot 1 I.T. ; Addition ____
Street Address 9300 SW 119th.

2. Property Use: Residential ____ /X/ ; Commercial ____ /__/
No. of Bedrooms 3 . Describe: ____
Other Use ____ /__/
Describe: ____

3. Type of Individual Sewage Disposal System: Septic Tank /__/ ; Other /X/

4. Distance to public sewer: 4 miles ft.

Kenneth D Maxwell Juanita L.
Signature of Applicant (Owner or Lessee)

3410 "X" Street-Lincoln, NB. 68503
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 10/8/76 . Date Frwd. 10/8/76 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold E. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 10/11/76 . Date Frwd. 10/11/76 . ACTION: Approved ☐ Disapproved ☐ Signature: ____

3. City or County Engineer : Date Rec'd. 10/8/76 . Date Frwd. 10/8/76 . ACTION: Approved ☒ Disapproved ☐ Signature: Allen K. Jensen

REMARKS OR REASONS FOR DISAPPROVAL ____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

X

FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 475-6221)

FILE NO. 934-C

PROPERTY WHERE SOIL TESTED:
Location: Township 9N ; Range 5E
Section & ¼ Sect. 29SE
Property Dimensions: 638 ft. x 330 ft.
Area: ~5 acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay [ ]; Silty Clay Loam [ ]; Sandy Loam [ ]
Silty Loam [ ]; Clay Loam [X]; Sandy Clay [ ]

Owner: Juanita L.& Kenneth D. Maxwell
Address 3410 "X" St-Lincoln 68503

Dates of Tests: 1 October 1976 to 2 October 1976. Weather: Precip. 0 Temp. 80°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	35	1 Oct	9:25	2 Oct	12:30	2/10	4:00	6"	4:30	5½"	30	½"	
2	36	"	"	"	"	"	"	7"	"	5"	"	2"	
3	34½	"	"	"	"	"	"	6½"	"	2½"	"	4"	
4	32	"	"	"	"	"	"	6½"	"	4"	"	2½"	
5	36	"	"	"	"	"	"	6¼"	"	5"	"	1¼"	
6	36	"	"	"	"	"	"	6½"	"	5½"	"	1"	
7	34½	"	"	"	"	"	"	6½"	"	5¼"	"	1¼"	
8	35½	"	"	"	"	"	"	6"	"	5½"	"	½"	

Sum of Percolation Rates
Average of Rates: 1.625
Mean of Rates:

Kenneth D. & Juanita L. Maxwell
Signature of Person Conducting Test

Address 3410 "X" Street-Lincoln, NB. 68503
Phone: 466-3449

(Do not write below this line)


REVIEWING ACTION

REMARKS: Lagoon would need lining.

Approved Percolation Rate(s)
A. 18 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: October 8, 1976

Jerrold C. Hood
Signature of Reviewing Official



Juanita L. Maxwell
Kenneth D. Maxwell
3410 X Street
Lincoln Nebr. 68503

Lot 1 NW NW SE¼ Twp. 9, Range ~~5~~ E Sec. 29