LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue — Phone (402) 471-7800

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER / LOA

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System — Date: 10-30-90

☒ Evaluation of the Sewage Disposal System — ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 6E of the 6th P.M.; SECTION 3; BLOCK ___

LOT 157 IT; ADDITION _____; Street Address 635 WEST CALVERT

Directions to Property VAN DORN to FOLSOM, SOUTH ON FOLSOM to WEST CALVERT EAST ON WEST CALVERT ¼ BLOCK HOUSE ON SOUTH SIDE OF STREET

Location of Well SOUTH WEST CORNER OF HOUSE Tap Location: Inside ☒ Outside ☒

Location of Sewage System NORTH EAST SIDE OF HOUSE Year Installed ORIGINAL 1915 ADDITIONS ADDED 1917

	NAME	ADDRESS	PHONE
Present Owner:	Mr. & Mrs. Richard H. ENDORF	635 WEST CALVERT	423-3947
Tenant/Buyer:			
Return to:	Richard ENDORF	635 WEST CALVERT	423-3947

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Richard H. Endorf Address 635 West Calvert Lincoln, Nebr. 68522

==========

HEALTH DEPARTMENT USE ONLY

Date Received NOVEMBER 1, 1990 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 11/1/90

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:	SITE VISIT:
Construction	☒	☐	Approved: ☐	Date 11/1/90 by C.E.H.
Bacteria	☒	☐	Provisional: ☒	Date _____ by ___
Nitrate	☒	☐	Disapproved: ☐	Date _____ by ___

Comments: PORTIONS OF THIS SEPTIC SYSTEM PREDATE REGULATIONS, THE LATERAL FIELD IS IN A CRAMPED SPACE HENCE APPROVAL IS PROVISIONAL. SEPTIC TANK SHOULD BE CHECKED TOO SEE IF IT NEEDS PUMPING. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☐	Provisional Approval: ☒

APPROVED BY Gerrold C. Hood R.S. DATE NOVEMBER 5, 1990

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

014

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

[X] Evaluation of the Individual Water System Date: 2-3-93

[X] Evaluation of the Sewage Disposal System [X] Enclosed is ~~$75.00~~ #150.00

Legal Description of Property: TWP. 9N; RANGE 6E; ~~1E 1W~~ SECTION SE¼ 3; BLOCK ____

LOT 157 I.T.; ADDITION ____; Street Address 635 W. Calvert, Lincoln, Nebraska

Directions to Property Go South off of Van Dorn at Folsom, take Folsom to W. Calvert, go east, 2nd house on south side of street

Location of Well SOUTHSIDE OF HOUSE BY KITCHEN Tap Location: Inside [ ] Outside [ ]

Location of Sewage System FRONT YARD, COVER NEAR BUSHES Year Installed ?

	NAME	ADDRESS	PHONE
Present Owner:	Dana Beringer	635 W. Calvert, 68522	421-2897
Tenant/Buyer:			
Return to:	ATI Title, ATTN: Sheryl	P.O.Box 67069, Lincoln, NE 68506-7069	434-3712

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant ATI Title By: Luann Kolze Address P.O.Box 67069, 68506-7069

==========

HEALTH DEPARTMENT USE ONLY #150.00

Date Received RECEIVED FEB 04 1993 Received ~~$75.00~~ Check [X] Cash [ ] #8862

PRELIMINARY STATUS--DATE 2/5/93

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	[X]	[ ]	Approved:	[ ]	Date 2/5/93 by J.C.H.
Bacteria	[X]	[ ]	Provisional:	[X]	Date ____ by ____
Nitrate	9.2p.p.m. [X]	[ ]	Disapproved:	[ ]	Date ____ by ____

Comments: THE SEPTIC SYSTEM IS IN A VERY CONFINED AREA, THERE IS NO ROOM FOR EXPANSION. HOWEVER, THERE WAS NO EVIDENCE OF MALFUNCTION. HENCE APPROVAL IS PROVISIONAL. IF THE SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED. THE NITRATE LEVEL OF THE WELL WATER IS VERY NEAR THE UPPER LIMIT OF 10P.P.M.. THIS SHOULD BE MONITORED CLOSELY. See Attached Letter [ ]

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: [X]	Approved: [ ]	Provisional Approval: [X]

APPROVED BY Jerrold C. Hood R.E.H.S. DATE FEBRUARY 11, 1993

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska
INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

FG.4120

064