Lincoln-Lancaster County Health Department

2200 St. Mary's Avenue, Lincoln, Nebraska 68

REAL ESTATE TRANSFER/LOAN AI

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☑ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☑ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 2924 SW 6th St.

Twp 9N Range 6E Section 3 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition ___

Directions to Property from Prospector Restaurant East to SW 6, South on SW 6th approx. 2 blocks, house is on east side of street w/woods Bros sign in front yard

Location of Well ___ Tap Location: Inside ☐ Outside ☐

~~Location of Sewage System~~ ___ Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Marvin Vostrez	1519 So. 7th Lincoln NE 68502	477-4772
Tenant/Buyer:	Lelia Berger	4747 Linden #6 LINCOLN NE 68516	489-9614
Return to:	Craig Loeck	Woods Bros. 7141 A LINCOLN NE 68510	430-8758

Signature of Applicant Lelia Berger/ag Address ___ Date 9/5/95

HEALTH DEPARTMENT USE ONLY

Date Received 9/6/95 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By JERROLD HOOD **DATE:** 9/6/95

MUNICIPAL SYSTEM

WATER SYSTEM:	Approved	Disapproved	**SEWAGE SYSTEM**	**Additional Site Visits**
Construction	☐	☒	Approved ☐	Date ___/___/___ by ___
Bacteria	☐ ___/ml	☐ ___/ml	Provisional ☐	Date ___/___/___ by ___
Nitrate	☒ 0.1 ppm	☐ ___ ppm	Disapproved ☐	Date ___/___/___ by ___

Comments: OLD WELL MUST BE PROPERLY ABANDONED. SCREEN IN AIR VENT HAS A HOLE IN IT. SAMPLE TAKEN FOR NITRATE ANALYSIS. CALL 441-8029 WHEN WELL WORK DONE. HAVE TO SAMPLE FOR BACTERIA AFTER WORK IS DONE. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☐ **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☐

Approved by ___ Date ___/___/___

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.