FILE NO. 1902

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

JANUARY 23,1983 — THIS LICENSE OR PERMIT EXPIRES

EWALD BOCKMAN RURAL ROUTE #1 KINCOLN NE 68522 — LICENSEE OR PERMITTEE / ADDRESS

T9N, R6E, SECTION 4, LOT 12, STOCKWELL ADDITION — NAME OF ESTABLISHMENT, IF ANY / ADDRESS

REMARKS: NONTRANSFERABLE EXTEND PERMIT

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE	
018754	410.16	148.14	6X2	

SERIAL NO.	DATE	AMOUNT
61877 8232		30.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

HEALTH APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1902

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 7-23-82

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☒, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 9N ; Range 6E ; Section 4 ;
Block ; Lot 12 ; Addition ~~[illegible]~~ STOCKWELL ADDITION
Street Address

2. Property Use: Residential ☒; Commercial ☐
No. Bedrooms 2
Describe
Other Use ☐
Describe

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: add 70' sew
4 100' lat 3' wide

5. Work to be done by: Owner ☐ ; or Contractor ☒, Jenlek
Contractor's Name

6. Estimated cost of project:

a. Materials	$
b. Labor	$
c. Other	$
TOTAL	$ 940

Ewald Bodeman
Signature of Applicant (owner or lessee)

R.R. 8 Lincoln Ne
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd:
Filing Fee: $ 30.00

2. Site Visits:
Date: 7/23/82 by: L.C.H.
Date: by:
Date: by:


3. Date: Approved ☒; Disapproved ☐
by: Jerrold E. Hood


4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 7/23/82 by: Jerrold E.

AS BUILT DRAWING OF SYSTEM

DATE 7-23-82 INSTALLER Sintek Sons Co

NO





FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: 7-23-82

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material PL ; Diameter 4 in.
2. Distance above basement floor _____ in., or below basement floor _____ in.
3. Distance between dwelling and septic tank _____ ft.
4. Number of clean-outs _____.
5. Distances to:
Well or Suction Line _____ ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material Conc ; No. of compartments 1.
2. Capacity 600 gals.;
3. Factory Built: Yes ☒ No ☐
(Company Precast)
4. Manholes: Over Inlet; diam. 4 in.
Over Outlet; diam. _____ in.
Riser Above ☒ Below ☐ Grade _____ in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☒
7. Depth of top of tank below finished grade 24 in.
8. Distances to:
Well or Suction Line 25 ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material Conc ; Number - available outlets 3.
2. Factory Built: Yes ☐ No ☒
(Company Self)
3. Distance from Septic Tank 5 ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☐ Perforated Pipe ☒
Diameter of Half Round _____ or Perforated Pipe 4.
Material: fiberglass ☐ ; plastic ☒ ; concrete ☐ ; other _____.
2. Lateral Lines:
Number 1 ; Length of each line 100, _____, _____, _____, _____ ft.;
Total length of laterals 100 ft.;
Distance between lateral lines _____ ft.
3. Trench dimensions: Width 36 ft.;
Slope 3 in/100 ft.; Average Depth 36 in.
4. Filter Material: Road Gravel
Depth of Material 2 in.
5. Distances to:
Well or Suction Line 100 ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN