LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-8000 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 11-17-98

☐ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 6E; SECTION 5; BLOCK ___

LOT ___; ADDITION ___; Street Address 2900 SW 6th

Directions to Property E 1 blk. S/o Van Dorn

Location of Well E/o House Tap Location: Inside ☐ Outside ☒

Location of Sewage System ___ Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Russell L. Porter P.R. for Lloyd Porter	6610 So. 84th Lincoln	483-5707
Tenant/Buyer:			
Return to:	Nancy Sudgmon Woods Bus.	7141 "A" St.	68510 FAX 434-3801

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Russell L. Porter Address 6610 So. 84th

==========

HEALTH DEPARTMENT USE ONLY

Date Received 11/20/98 Received $150.00 Check ☑ Cash ☐

PRELIMINARY STATUS--DATE NOVEMBER 23, 1998

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:	
Construction	☐	☒	Approved:	☒	Date 12/11/98	by J.C.H.
Bacteria	☒	☐	Provisional:	☐	Date 12/14/98	by J.C.H.
Nitrate 8.3 ppm	☒	☐	Disapproved:	☐	Date ___	by ___

Comments: FROST PROOF HYDRANT TOO CLOSE TO WELL. ELECTRICAL CONDUIT IS SEPARATED. SCREEN IN AIR VENT IS TILTED. CRACK IN CONCRETE AROUND WELL. DEPRESSION AROUND WELL. See Attached Letter ☐

FINAL STATUS 12/11/98 Corrections made. Now there is no outside sampling point. JCH

P5612-8

WATER SYSTEM:		SEWAGE DISPOSAL SYSTEM:		
Approved:	☒	Approved:	☒	Provisional Approval: ☐

APPROVED BY Paul Hoffman DATE 12-16-98

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

P5252-24