X closing December 27! Y 003

Lincoln-Lancaster County Health Department

2200 St. Mary's Avenue, Lincoln, Nebraska

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER/LOAN

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 1530 W Stockwell

Twp 9N Range 6E Section 4 1/4 ___ 1/4 ___ Block ___ Lot 2 Addition 1st

Directions to Property South to Folsom turn Left to W. Stockwell & turn Right go West.

Location of Well West of house Tap Location: Inside ☒ Outside ☐

Location of Sewage System ___ Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Richard Nooty	1530 W Stockwell	no phone
Tenant/Buyer:	Melvin Mettscher	415 NW 19 Apt Lincoln 68528	435 5556
Return to:	~~FIRSTIER~~ Attn: Barrie LINCOLN FEDERAL	~~NORTH~~ 110 "N" ST, LINCOLN 68508	

Signature of Applicant Sharon Mettscher Address 415 NW 19 Apt Lincoln Date 12/6/93

MIKE ISAACSON VONNE SAMUS 483-4683

HEALTH DEPARTMENT USE ONLY

Frank #1330

Date Received 12/6/93 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By Gerrold Hood **DATE:** 12/7/93

3/24/94 G.H.

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM	Additional Site Visits
Construction	☐	☒	Approved ☐	Date 12/23/93 by PD
Bacteria	☒ 0 /ml	☐ ___ /ml	Provisional ☒	Date 12/28/93 by PD
Nitrate	☒ <0.1 ppm	☐ ___ ppm	Disapproved ☐	Date 1/27/94 by GH

1/28/94 G.H.

Comments: FROST PROOF HYDRANT TOO CLOSE TO WELL, DEPRESSION NEAR WELL, WELL TOO CLOSE TO SEPTIC LATERAL. Paul confirms lateral is far enough away but septic tank is too close. See Attached Letter ☐

Hydrant abandoned new well put in. OLD WELL MUST BE ABANDONED. Old well abandoned should have a concrete cap cast on it. 1/28/94 G.H.

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☒

Approved by Gerrold C. Hood R.E.H.S. Date 3/4/94

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.